

CHARLES CENTER . P.O. BOX 1475 . BALTIMORE, MARYLAND 21203

LEON B. RUSSELL

MANAGER
CALVERT CLIFFS NUCLEAR POWER PLANT DEPARTMENT

January 11, 1990

U. S. Nuclear Regulatory Commission Washington, DC 20555

ATTENTION:

Document Control Desk

SUBJECT:

Calvert Cliffs Nuclear Power Plant

Unit No. 1; Docket No. 50-317

Technical Specification 3.7.11.1.c Special Report

Gentlemen:

On January 10, 1990 at 1005, while Unit 1 was in Mode 5 (cold shutdown), it was discovered that the Unit 1 Containment Isolation Valve (MOV-6200) for the Containment Hose Station Riser would not open upor remote initiation from the Control Room. The isolation valve is addressed by Calvert Cliffs Nuclear Power Plant Unit 1 Technical Specification 3/4.7.11.1.c. The associated Action Statement, 3.7.11.1.b, was entered as was the Action Statement for Unit 1 Technical Specification 3.7.11.4.a, "Fire Hose Stations."

Establishment of a back-up water supply was provided within one hour by manually opening MOV-6200 which pressurized the Unit 1 Containment Hose Station Riser. Therefore all Unit 1 Containment Fire Hose Stations are operable. This action satisfied Action Statement 3.7.11.1.b.1 and allowed Action Statement 3.7.11.4.a to be exited.

At 1700 on January 10, 1990 a telephone notification was made by the Shift Supervisor to the Nuclear Regulatory Commission duty officer. This telephone notification satisfies Action Statement 3.7.11.1.b.2.a. This letter provides written confirmation of the telephone report no later than the first working day following the event and satisfies Action Statement 3.7.11.1.b.2.b.

Immediate corrective actions, in addition to manually opening the valve, are focused on restoring the automatic capability of MOV-6200. A detailed Special Report will be provided within 14 days with additional information.

2001180362 05000317

TE22 Cut No 40509

Document Control Desk January 11, 1990 Page 2

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

2BRusself

LBR/CDS/CRS/bjd

cc: D. A. Brune, Esquire

J. E. Silberg, Esquire

R. A. Capra, NRC

S. A. McNeil, NRC

W. T. Russell, NRC

J. E. Beall, NRC

T. Magette, DNR