

January 11, 1990

Docket Nos. 50-424
50-425

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - VOGTLE BULLETIN 88-08
RESPONSE (TACS 69703/69704)

The NRC staff is reviewing the Vogtle responses to Bulletin 88-08, "Thermal Stresses in Piping Connected to Reactor Coolant Systems." The NRC staff finds that it needs additional information in order to complete its review. Enclosed is the request for additional information for which we request response. If you have any questions, contact me.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/
Jon B. Hopkins, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Distribution:

| | |
|------------------|------------------|
| Docket File | RIngram |
| NRC & Local PDRs | JHopkins |
| PDII-3 R/F | OGC (info. only) |
| SVarga | EJordan |
| CWHehl | ACRS(10) |
| DMatthews | Vogtle File |

OFFICIAL RECORD COPY

Document Name: VOGTLE RAI LTR

LA:PDII-3 PM:PDII-3 D:PDII-3
RIngram JHopkins:bld DMatthews
1/9/90 1/9/90 1/11/90

9001190110 900111
PDR ADOCK 05000424
Q PDC

RF01
11

Mr. W. G. Hairston, III
Georgia Power Company

Vogtle Electric Generating Plant

cc:

Mr. J. A. Bailey
Manager - Licensing
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Bruce W. Churchill, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mr. G. Bockhold, Jr.
General Manager, Vogtle Electric
Generating Plant
P.O. Box 1600
Waynesboro, Georgia 30830

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Office of the County Commissioner
Burke County Commission
Waynesboro, Georgia 30830

Office of Planning and Budget
Room 615B
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. C. K. McCoy
Vice President - Nuclear, Vogtle Project
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Resident Inspector
Nuclear Regulatory Commission
P.O. Box 572
Waynesboro, Georgia 30830

James E. Joiner, Esq.
Troutmen, Sanders, Lockerman,
& Ashmore
1400 Candler Building
127 Peachtree Street, N.E.
Atlanta, Georgia 30303

Mr. R. P. McDonald
Executive Vice President -
Nuclear Operations
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. J. Leonard Ledbetter, Director
Environmental Protection Division
Department of Natural Resources
205 Butler Street, S.E., Suite 1252
Atlanta, Georgia 30334

Attorney General
Law Department
132 Judicial Building
Atlanta, Georgia 30334

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

1. Provide more information regarding the Westinghouse recommendation for temperature monitoring locations and hardware specifications.
2. Provide the time intervals at which temperature readings are recorded and monitored for each Operating Mode.
3. Provide the basis for the delta T acceptance criterion of 50°F.
4. Provide more information regarding the baseline temperature data supplied by Westinghouse.