



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

January 4, 1990

Docket Nos. 50-321  
50-366

LICENSEE: Georgia Power Company  
FACILITY: Edwin I. Hatch Nuclear Plant, Units 1 and 2  
SUBJECT: SUMMARY OF NOVEMBER 14, 1989, MEETING WITH GEORGIA POWER ON THE PROPOSED MSIV CLOSURE TIME TECHNICAL SPECIFICATION AMENDMENT

On November 14, 1989, the NRC staff met with representatives of Georgia Power Company (GPC) and General Electric to address staff concerns regarding the application of the Moody homogeneous equilibrium model (incorporated into the SAFER Thermal Hydraulic Code) for calculating mass and energy releases following a postulated main steam line break (MSLB) outside containment. The revised MSLB integrated mass and energy release calculation was submitted in support of a proposed GPC Technical Specification (TS) amendment to increase the main steam isolation valve (MSIV) stroke time window from 3-5 seconds to 2-8 seconds.

The staff's chief concern with the use of the SAFER Code is whether the new calculated mass and energy releases for the MSLB (assuming the increased MSIV stroke time window), accounting for calculation uncertainties, are bounded by the current Hatch licensing basis equipment qualification (EQ) curves. To resolve this concern, the staff requested GPC to address three issues:

1. GPC should compare the best estimate (including friction effects if feasible) integrated mass and energy releases as calculated by SAFER against the current EQ basis curves for the MSLB. This comparison should discuss the uncertainties inherent in the SAFER calculation and address whether the SAFER calculation with uncertainties is bounded by the current EQ mass and energy release curves. In this regard, a margin of 20% is thought to be sufficient to bound SAFER calculation uncertainties.
2. GPC should provide a qualitative argument as to whether existing MSLB temperature versus time EQ profiles bound the temperature versus time profile expected to result from the new mass and energy release estimates calculated using SAFER with an 8 second MSIV closure time.
3. GPC should review any existing EQ failure modes and effects analyses for equipment whose environment is governed by the MSLB to ensure that these analyses remain valid for the new SAFER calculated releases.

*[Handwritten signature]*  
F01  
'11

The resolution of the above three concerns should provide an adequate basis for the staff to complete the SER for the proposed GPC TS amendment.

Meeting participants are listed in Enclosure 1. Slides presented by GPC are provided in Enclosure 2.

15/

Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II

Enclosures:  
As stated

cc w/encls:  
See next page

Distribution:

Docket file		T. Collins	8/E/23
NRC & Local PDRs		H. Walker	8/D/1
J. Sniezek	12/G/18	M. McCoy	8/E/23
PDII-3 R/F		C. Graves	NLS 314
S. Varga	14/E/4	OGC (info. only)	15/B/18
D. Matthews	14/H/25	E. Jordan	MNBB 3302
T. Reed	14/H/25	ACRS (10)	P1 135
L. Crocker	14/H/25	R. Borchardt	17/D/19
R. Ingram	14/H/25		

OFFICIAL RECORD COPY  
Document Name: HATCH MTG SUMMARY 11/14

*media done 12/29/89*

LA:PDII3  
RIngram  
12/6/89

PM:PDII3  
TRed:sa  
12/13/89

DST/SR.XB  
TCollins  
12/14/89  
*as modified*

*media done 12/29/89*  
DST/SR.XB  
HWalker  
*Completed on 12/19/89*

*DMatthews*  
D:PDII3  
DMatthews  
1/4/89

The resolution of the above three concerns should provide an adequate basis for the staff to complete the Safety Evaluation for the proposed GPC TS amendment.

Meeting participants are listed in Enclosure 1. Slides presented by GPC are provided in Enclosure 2.



Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:  
As stated

cc w/encls:  
See next page

Georgia Power Company

cc:

Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N. W.  
Washington, D.C. 20037

Mr. J. T. Beckham  
Vice President - Plant Hatch  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Mr. S. J. Bethay  
Manager Licensing - Hatch  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Mr. H. C. Nix  
General Manager, Nuclear Plant  
Georgia Power Company  
Route 1, Box 439  
Baxley, Georgia 31513

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 1, Box 725  
Baxley, Georgia 31513

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 2900  
Atlanta, Georgia 30323

Mr. Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Director  
Environmental Protection Division  
Department of Natural Resources  
205 Butler Street, S.E., Suite 1252  
Atlanta, Georgia 30334

Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, Georgia 31513

Mr. R. P. McDonald  
Executive Vice President -  
Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. W. G. Hairston, III  
Senior Vice President -  
Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

ATTENDANCE LIST

Georgia Power Company/NRC

Proposed MSIV Closure Time Technical Specification Amendment

November 14, 1989

<u>NAME</u>	<u>ORGANIZATION</u>
Tim Reed	NRC/DRP/PD11-3
Mike McCoy	NRC/DST/SRXB
Chuck Graves	NRC/RES
Harold Walker	NRC/DST/SPLB
Tim Collins	NRC/DST/SRXB
Gary Sozzi	GE Nuclear Energy
Larry Chi	GE Nuclear Energy
Ken McElroy	Georgia Power Company

NRC/GPC MEETING  
PROPOSED MSIV CLOSURE TIME TECHNICAL SPECIFICATIONS  
AMENDMENT

NOVEMBER 14, 1989  
WHITE FLINT BUILDING  
9:00 - 12:00 A.M.

OVERVIEW OF MSIV CLOSURE TIME SUBMITTAL

GPC

- o IMPACT OF SHORTER STROKE TIME
- o IMPACT OF LONGER STROKE TIME

IMPACT OF LONGER STROKE TIME ON EQ AND  
RADIOLOGICAL CONSEQUENCES

GE

- o CONSERVATISM IN CURRENT EQ BASIS
- o SAFER MODEL QUALIFICATION AND USE OF  
HEM BREAK FLOW MODEL
- o JUSTIFICATION OF HEM FOR EQ AND  
RADIOLOGICAL EVALUATIONS

DISCUSSION/OPEN ITEMS

ALL

OVERVIEW OF  
MSIV CLOSURE TIME SUBMITTAL

- 0 TECHNICAL SPECIFICATIONS (TS) AMENDMENT FOR PLANT HATCH  
SUBMITTED MAY 13, 1988
- 0 INCREASED MSIV STROKE TIME WINDOW FROM 3-5 SECONDS TO 2-8  
SECONDS. OTHER TS REQUIREMENTS NOT CHANGED
- 0 LARGER WINDOW MEANS LESS CHANCE OF FAILING QUARTERLY STROKE  
TIME TEST
- 0 FAILING STROKE TIME TEST ON INBOARD MSIV AT POWER CAUSES  
SHUTDOWN OR OPERATION WITH ISOLATED STEAMLIN
- 0 BASIS FOR EXTENDING INTERVAL EVALUATED BY GENERAL ELECTRIC AND  
INCLUDED IN MAY 13, 1988 SUBMITTAL

---

OPERATION WITH ISOLATED STEAMLINES REQUIRED  
IN 1986 & 1987 AFTER FAILING SURVEILLANCE

---

MSIV CLOSURE TIME (CONTINUED)

EXTENDING CLOSURE TIME INTERVAL REQUIRED REVIEW AND REEVALUATION OF DESIGN BASIS

- 0 SHORTER STROKE TIME (3 SECONDS TO 2 SECONDS)
- 0 LONGER STROKE TIME (5 SECONDS TO 8 SECONDS) PLUS INSTRUMENT DELAY TIME (0.5 SECONDS)

SHORTER STROKE TIME EVALUATIONS INCLUDE:

- 0 VESSEL OVERPRESSURE PROTECTION
- 0 THERMAL LIMITS (OTHER TRANSIENT EVENTS)
- 0 LOCA/ECCS
- 0 CONTAINMENT
- 0 STEAMLINE AND MSIV INTEGRITY

---

TO DATE, NRC HAS REQUESTED NO ADDITIONAL  
INFORMATION ON THESE EVALUATIONS

---



MSIV CLOSURE TIME (CONTINUED)

- 0 LONGER STROKE TIME EVALUATIONS INCLUDE:
  - 0 LUCA/ECCS
  - 0 TRANSIENTS
  - 0 CONTAINMENT
  - 0 RADIOLOGICAL RELEASE
  - 0 ENVIRONMENTAL QUALIFICATION
  
- 0 POSTULATED MSL BREAK OUTSIDE CONTAINMENT INPUT TO EQ AND RADIOLOGICAL RELEASE CALCULATIONS
  
- 0 GE REEVALUATED MSLB WITH NEW "SAFER" THERMAL HYDRAULIC CODE
  - 0 SAFER/GESTR-LOCA APPLICATION METHODOLOGY
  - 0 8 SECOND MSIV CLOSURE TIME
  - 0 HEM FOR SATURATED FLUID
  
- 0 ANALYSIS SHOWED EXISTING (CONSERVATIVE) EQ BASIS (5-SECOND CLOSURE) BOUNDS 8-SECOND CLOSURE IN TERMS OF BREAK FLOW AND BREAK ENERGY

---

NRC REVIEWERS NOT CONVINCED NEW CALCULATION  
IS SUFFICIENTLY CONSERVATIVE

---