



GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775
AREA CODE 504 835-6084 346-8651

January 3, 1990
RBG- 32048
File Nos. G9.5

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

River Bend Station - Unit 1
Docket No. 50-458

In response to a request by Mr. W. A. Paulson concerning additional information on ponding of rainwater on building roofs at River Bend Station (RBS), attached is a submittal providing the requested information.

Specifically requested were copies of two (2) structural calculations referred to in previous submittals. Also included are copies of the reinforcing steel drawings applicable to the roof slabs of the diesel generator building and standby cooling tower pump house.

The NRC structural representative requested clarification of the detail section on page 7 of calculation C29.0.1-3B. This detail is a simplified representation of a 12 inch wide section of the diesel generator building roof slab. Though the detail only illustrates the presence of tension reinforcing steel, the design drawing, EC-29H, included in this submittal clearly indicates the presence of both compression and tension steel. This should therefore resolve the concern regarding this matter.

To eliminate any possible confusion, the attached submittal contains both copies of the original calculations and the design drawings previously transmitted to the NRC. The attachment to this letter lists each enclosure included in this submittal.

9001230181 900103
PDR ADDOCK 05000458
P PNU

Pool Drawings
To: Files

If you have any questions concerning this document or this issue in general contact L. L. Dietrich at (504) 381-4866.

Sincerely,

J. E. Booker

J. E. Booker
Manager-River Bend Oversight
River Bend Nuclear Group

JEB/LAE/LLD/WJS/ns
JEB/LAE/LLD/WJS/ns

cc: U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

Walt Paulson
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852

Attachment

ATTACHMENT

<u>Enclosure</u>	<u>Description</u>	<u>Number</u>
1	Standby Service Water Cooling Tower Roof and Wall design calculations	C47.540-0B C47.540
2	Diesel Generator Building Slab design calculations	C29.0.1-3B C29.0.1
3	Station Design Criteria	200.010 page 3-4
4	Station Design Criteria	200.010 page 4-6
5	Station Design Criteria	200.010 page 2-1
6	Diesel Generator Building Floor Plan Drawings	EC-29G-3 EC-29H-3
7	Standby Cooling Tower Pumphouse Drawings	EC-47DA-2 EC-47BA-3



CALCULATION TITLE PAGE ENGINEERING DEPARTMENT

1. CALCULATION NUMBER		REV
C47.	540	- 0B
2. NO.		
PAGE 1	OF 14	

2. CALCULATION TITLE- Standby S.W. Cooling Tower - Design of Roofs @ EL. 152'-6" & 163'-4" and Walls From EL. 152'-6" to EL. 163'-4"

3. SUPERSEDES CALC. OR REVISION NO:
12210-C47.540-0A

4. OBJECTIVE OF CALCULATION:
The objective of this calculation is to prove the adequacy of the roof slab at elev. 152'-6" to support a maximum height of ponded rainwater, assuming that the scupper drains provided in the surrounding parapet wall are blocked. (Note: This is a very conservative approach since the drains will not completely prevent the flow of water.)

5. CALCULATION METHOD/ASSUMPTIONS:
The method employed in this calculation, for determining the adequacy of the roof slab, involves the simple comparison of existing ultimate design moments in each section of the slab, to a revised moment based upon the additional loadings imposed by the ponded rainwater. If the revised ultimate moment is less than that originally calculated, no additional review is required. However, if the revised moment exceeds the original design, additional calculations and/or justification for acceptability will be provided.

- 6. SOURCES OF DATA/EQUATIONS (REFERENCES):**
1. Calculation 12210-C47.540 Rev. 0; "Standby S.W. Cooling Tower - Design of Roofs @ EL. 152'-6" & 163'-4" and Walls From EL. 152'-6" to EL. 163'-4". "
 2. Structural Design Criteria - Doc. No. 200.010, Rev. 5, dated 3/15/85
 3. Design Handbook, ACI 318-71, Publication SP-17(73)
 4. Drawing EA-59C-1; "Partial Roof Plans & Dets STBY SVCE WTR CLG tower"
 5. HVAC Calculation G13.18.2.1*28
 6. Modification Request (MR) No. 85-0445 (Welding of doors SP154-1 & 2)
 7. Drawing EC-47DA-2; Plan Elev. 152'-6", Reinforcing plan.
 8. "Standard Handbook for Civil Engineers"; Merritt; Second Edition; 1968

7. CONCLUSIONS:
Since the revised ultimate design moments for each section of the roof slab at elev. 152'-6" are enveloped by the original design, the additional loading imposed by the maximum height of ponded rainwater will not compromise the structural integrity of the roof slab.

8. REASON FOR REVISION (IF APPLICABLE):
The reason for this addendum is to provide a technical review of the adequacy of the roof slab at elev. 152'-6" to support the maximum potential height of ponded rainwater. Though the slab design is adequate to support the rainwater, the specific loading imposed by water was not individually identified in the original calculation.

9. RELATED DOCUMENTS:
N/A

10. QA CATEGORY
 I-NUCLEAR
 SAFETY RELATED
 II
 III

11.

 PREPARER _____ DATE 7/5/89

12.

 CHECKER/REVIEWER _____ DATE 7/06/89

13.

 INDEPENDENT REVIEWER _____ DATE 7/06/89

14. DATA REQUIRING CONFIRMATION:
N/A

DATA CONFIRMED BY: _____ **DATE** _____

00000003



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C47.	540	- 08
JOB NO.		
PAGE 3	OF	14

OBJECTIVE:

As stated on page 1, the objective of this calculation is to confirm the adequacy of the roof slab of the Standby Cooling Tower Pumphouse, at elevation 152'-6", to support the loading imposed by the maximum potential height of ponded rainwater.

METHOD and SOLUTION:

An outline of the configuration of the roof slab at elevation 152'-6" is shown on page 5 of this calculation. In this outline of the slab, it can be seen that the overall roof structure is divided into several different sections for which an analysis was performed to determine the design loading and subsequently the reinforcing requirements for the overall slab. (These sections are specifically identified on page 8.)

On pages 6 and 7 of this calculation, an outline of the roof slab is provided showing the physical layout of the roof area with all scupper drain locations, the directional slope of the slab, and the height of the surrounding parapet wall. The purpose of the outline on page 6 is to indicate the maximum height of rainwater that could be contained within the parapet wall on the Pumphouse roof. Since the top elevation of the parapet wall is 154'-10" and the low-point elevation of the roof slab is 152'-6", the maximum depth of ponded rainwater that will be contained on the roof slab prior to breaching the top of the parapet wall, is 2'-4".

- A. The method employed by this calculation, to verify the adequacy of the roof slab, will be to extract the design loading determined from the original calculation for that portion of the slab design being considered; apply the revised loadings, based upon the assumptions stated below and the additional loading from the ponded rainwater, to determine the ultimate applied moment (M_u) for each section; compare this moment with the one originally calculated; if the new moment is less than the original, the roof slab is acceptable, if the new moment exceeds the original, a justification/analysis will be provided.
- B. The following assumptions/credits are taken in this calculation:

1. The originally applied Live Loading of 30 pounds per square foot (psf) will be deleted from the overall loading condition. The justification for this is due to the absence of any equipment loading in this area and the elimination of general personnel access to the roof area itself. Since the only Live loading possible on the roof slab would be from rainwater, the additional 30 psf loading can be eliminated from consideration as a simultaneous loading.
2. The temperature gradient (T_o) specified in the Structural Design Criteria (Ref. #2) of 50°F will be reduced to 20°F due to actual HVAC system design (Ref. #5). The 50°F gradient specified in the Design Criteria was an overall conservative number used in most structural calculations prior to the final design of the building HVAC systems. In this particular case, an actual differential of 20°F is applicable.

REF	PAGE
6	-
7	-
2	3-4
5	-



CALCULATION WORK SHEET

1. CALCULATION NUMBER		REV
C47.	540	- 0B
JOB NO.		
PAGE 4	OF	14

REF	PAGE
-----	------

C. It should be noted that the approach defined above is very conservative in nature due to the low probability that the scupper drains in the surrounding parapet wall will become totally blocked. Though some blockage may occur, it is more likely that the drains will allow the passage of some water and the maximum height of ponded rainwater, 2'-4", will be reduced.

ANALYSIS:

To adequately review the entire slab design for the additional loading imposed by a conservative, uniform depth, of ponded rainwater, we will analyze each individual section of the roof slab as it was broken down in the original design calculation.

Referring to page 8 of this calculation, each analyzed section of the roof slab is identified by the letters "A" thru "E".

To simplify this analysis, we will first determine the revised ultimate moment due to the temperature gradient (M_{ut}), as indicated on page 3 of this calculation. Then a distributed load due to a ponded rainwater height of 2'-4" shall be determined, which will be added to the ultimate applied moment (M_u) for each slab section. Upon calculating the revised ultimate moments for each section, a comparison will be made with the originally determined moment to illustrate that the revised condition is enveloped by the original design.

I. Revised Temperature Gradient Moment (M_{ut}):

As indicated on page 3 of this calculation, the actual temperature gradient for the upper elevations of the Standby Cooling Tower Pumphouse is 20°F. (This was provided in Reference #5.) Therefore, based upon an original factored moment, M_{ut} , of 21 ft.-kips, the revised moment will be:

$$M_{ut} = 21 \text{ ft-kips} \times \frac{20^\circ\text{F}}{50^\circ\text{F}} = 8.4 \text{ ft-kips}$$

This revised moment will be utilized throughout the remainder of this calculation for the determination of ultimate applied moments for each section of the roof slab.

II. Distributed Load Due to Ponded Rainwater (W_w):

As stated on page 3 of this calculation, the maximum depth of rainwater than can pond on the roof of the Standby Cooling Tower Pumphouse prior to breaching the top of the parapet wall, is 2'-4". Therefore, based upon this depth, the resultant loading will be: (The water load is considered to be dead weight. Therefore, the weight will be factored as Dead Load and the loading due to the seismic acceleration of the weight will be added to determine the total distributed load.)

(continued on page 9)

5
1 5

REF 7004



CALCULATION WORK SHEET


P. CALCULATION NUMBER	REV
C47.540	-08
SEE NO.	
PAGE 5	OF 14

CALCULATION SHEET

J. W. & H. E. ENGINEERING CORPORATION

NO. / D.S. / CALCULATION NO.	REVISION	PAGE
12210 / C47.540	0	C47.540.4
PREPARED / DATE	REVIEWER / CHECKED / DATE	INDEPENDENT REVIEWER / DATE
L. J. [unclear] / 10-20-81	T. [unclear] / 11.16.81	T. [unclear] / 11.16.81
SUBJECT / TITLE		QA CATEGORY / CODE CLASS
STANDBY SERVICE WATER COOLING TOWER DESIGN OF SLABS EL. 163'-4" & 152'-6"		I

REF	PAGE
1	4



PARTIAL PLAN EL. 152'-6" & 163'-4" (SC 4763-1)
SCALE: 1/8" = 1'-0"

REVISED

ESP-013 1/77


FOR INFORMATION ONLY



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C47.	540	-0B
JOB NO.		
PAGE 6	OF 14	

REF	PAGE
4	-



PUMPHOUSE ROOF
PLAN-OUTLINE

Note: Doors SP154-1 and 2 were welded closed in accordance with Modification Request (MR) No. 85-0445. Therefore, access to the roof area of the pumphouse has been eliminated.

10000004

100-013 1 07


FOR INFORMATION ONLY



CALCULATION WORK SHEET

P. CALCULATION NUMBER	REV
C47.540	-08
NO.	
PAGE 7	OF 14

NOT PAGE



13-13
D-4
1'-1.0'

4 -

REVISIONS

009-013 1/07


FOR INFORMATION ONLY



CALCULATION WORK SHEET

1. CALCULATION NUMBER	REV
C47	540 - 08
JOB NO.	
PAGE 8	OF 14

REF	PAGE
1	4



PARTIAL PLAN EL. 152'-6"

11/27/00-4

CP-013 1/07

FOR INFORMATION ONLY



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C47.	540	- 0B
JOB NO.		
PAGE	9	OF 14

II. (continued from page 4):

$$W_w = 1.4 \text{ D.L.} + 1.9(g_v) \text{ D.L.}$$

(Density of Water = 62.4 lb/ft³)

$$g_v = \text{OBE vert. accel.} = 0.162$$

$$W_w = 1.4 (62.4 \times 2.33') + 1.9 (0.162) (62.4 \times 2.33') = 248.4 \text{ psf}$$

(Note: 2.33' = 2'-4" the depth of the water)

**Referring to page 8 of this calculation, the following slab sections are analyzed:

III. Roof Slab Section 'A':

From the original calculation, the slab section is approx. 4'-6" wide by 18' long. The depth (d) of the reinforcing steel (distance from extreme compression fiber to the centroid of the reinforcing) was determined to be 39.885" in the original calculation.

In addition to the dead weight of the slab, an additional Dead Load due to the wall on top of the slab (see page 8) must be added. Therefore, the loadings are:

$$\begin{aligned} \text{Dead Load (DL)} &= \text{Wall Load} + \text{Wt. of Slab} = \\ &= 4.9 \text{ kips/ft} + (4.5' \times 44''/12 \times 150 \text{ pcf}/1000) \\ &= 7.38 \text{ kips/ft} \end{aligned}$$

$$\begin{aligned} \text{Live Load (LL)} &= 0.23 \text{ kips/ft (this load comes strictly from the wall} \\ &\text{on top of the slab. There are no} \\ &\text{additional live loads as defined on} \\ &\text{page 3 of this calculation.)} \end{aligned}$$

$$\begin{aligned} \text{Seismic Load} &= g_v (\text{DL} + \text{LL}) = 0.162 (7.38 \text{ k/ft}) + 0.23 \text{ k/ft} = 1.23 \text{ k/ft} \\ \text{(Note: } g_v = 0.162 \text{ is conservative in the original calc.; actually } g_v = 0.160) \\ \text{Therefore, the total loading (U) is:} \end{aligned}$$

$$\begin{aligned} U &= 1.4 \text{DL} + 1.7 \text{LL} + 1.9 \text{ OBE} \\ &= 1.4 (7.38) + 1.7 (0.23) + 1.9 (1.23) = 13.06 \text{ kips/ft} \end{aligned}$$

The resultant bending moment in the slab, utilizing the equation given in the original calculation which best approximates the support conditions of the slab is: (Note: '9' is used as a denominator to be conservative, fixed end beams usually use 12.)

$$M = \frac{w l^2}{9} = \frac{(13.06 \text{ k/ft})(18')^2}{9} = 470.2 \text{ ft-kips}/4.5' \text{ width}$$

$$\text{Moment due to ponded water} = \frac{(248/1000)(18')^2}{9} = 8.9 \text{ ft-kips}$$

$$\begin{aligned} M_u &= 470.2 + 8.9 = 479.1 + M_{ut} = 479.1 + 8.4 \text{ ft-kips/ft} (4.5') \\ &= 487.5 \text{ ft-kips}/4.5' \end{aligned}$$

REF	PAGE
2	4-6
8	15-9
1	8
-	8
1	8
1	7&8
1	8
1	8
2	4-6

FOR INFORMATION ONLY



CALCULATION WORK SHEET

C47.	540	- OB
NO.		
PAGE 10	OF	14

III. (continued from page 9):

As indicated in the original calculation, an additional moment is added to the overall loading to compensate for pipe supports and cable trays. This loading will simply be transferred to this calculation and is unchanged. Therefore, the total ultimate applied moment to slab section 'A' is:

$$M_u = 487.5 \text{ ft-kips} + 65 \text{ ft-kips} = 552.5 \text{ ft-kips}/4.5' \text{ width}$$

The originally calculated M_u for the slab was 640.5 ft-kips/4.5' width. Since this moment was utilized to design the reinforcing requirements for the slab and it is greater than the revised moment determined here, it can be concluded that the additional loading imposed by the ponded rainwater will not affect the structural integrity of slab section 'A'.

IV. Roof Slab Section 'B':

As can be seen from the drawing on page 8 of this calculation, and as defined in the original calculation, slab section 'B' is essentially a cantilevered member fixed on one end by the vertical wall of the structure and extending to the edge of the concrete plug opening.

From the original calculation, the Dead Load contribution from the concrete plugs is 1.65 kips. Therefore, neglecting the Live Load, as stated on page 3 of this calculation, and applying the same loading combination equation utilized throughout this design:

- The loading on the slab due to the concrete plugs is:

$$P_u \text{ (point load @ end of cantilever)} = 1.4DL + 1.9 g_v \text{ (DL)}$$

$$= 1.4 (1.65 \text{ kips}) + 1.9 (0.162) (1.65 \text{ kips}) = 2.82 \text{ kips}$$

The additional loading on the cantilever due to the curbing around the concrete plugs, from the original calculation, is

$$P = 0.53 \text{ kips}$$

Therefore, the total applied point load at the end of the cantilever is:

$$P_u = 2.82 \text{ kips} + 0.53 \text{ kips} = 3.35 \text{ kips}$$


- From the original calculation, the Dead Load of the slab for section 'B' is:

$$D.L. = 2' \text{ thick} \times 1' \text{ width} \times 150 \text{ pcf}/1000 = 0.3 \text{ pounds per foot}$$

Neglecting the Live Load, but including the seismic loading, the distributed loading along the length of the slab section is:

$$W_u = 1.4DL + 1.9 g_v \text{ (DL)} = 1.4(0.3) + 1.9(0.162)(0.3) = 0.51 \text{ K/ft}$$

REF	PAGE
1	8
1	8
1	B&9
1	9
1	9



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C47.	540	- 0B
JOB NO.		
PAGE	11	OF 14

IV. (continued from page 10):

As indicated in the original calculation, an additional loading is added to account for pipe supports and cable trays. This loading will simply be transferred here, thereby making the total distributed loading on the slab section:

$$W_u = 0.51 \text{ k/ft} + 0.4 \text{ k/ft} = 0.91 \text{ k/ft}$$

Utilizing the loadings calculated above and an overall length of slab section of 11.5 ft, as stated in the original calculation, the ultimate revised moment applied to slab section 'B' will become:

$$\begin{aligned} M_u &= P_u \times 11.5 \text{ ft} + \frac{W_u(L)^2}{2} + M_{ut} + \frac{W_w(L)^2}{2} \\ &= 3.35 \text{ k} \times 11.5 \text{ ft} + \frac{0.91 \text{ k/ft}(11.5 \text{ ft})^2}{2} + 8.4 \text{ ft-k/ft} + \\ &\quad \frac{(0.248 \text{ ksf})(11.5 \text{ ft})^2}{2} \end{aligned}$$

$$M_u = 123.5 \text{ ft-kips}$$

Since the originally calculated ultimate moment was 126.5 ft-kips and the revised moment determined in this calculation was found to be less, 123.5 ft-kips, it can be concluded that the additional loading imposed by the ponded rainwater will not affect the structural integrity of slab section 'B'.

V. Roof Slab Section 'C':

As can be seen from the drawing on page 8 of this calculation, slab section 'C' is the longest clear span on the roof. In addition, the distributed loading applied to section 'C' is the same as that applied to section 'B'. That is:

The distributed loading as a result of the weight of the slab is:

$$W_u = 0.51 \text{ k/ft} \text{ (from page 10 of this calculation)}$$

Added to that is the loading from pipe supports and cable trays of 0.4 k/ft, thereby making the total distributed load:

$$W_u = 0.51 \text{ k/ft} + 0.4 \text{ k/ft} = 0.91 \text{ k/ft}$$

Utilizing the equations provided in the original calculation for the bending moment in the slab that conservatively approximates the support conditions, the ultimate moment applied to the slab section is:

$$\begin{aligned} M_u &= \frac{W_u(L)^2}{9} + M_{ut} + \frac{W_w(L)^2}{9} \\ &= \frac{(0.91 \text{ k/ft})(30 \text{ ft})^2}{9} + 8.4 \text{ ft-k/ft} + \frac{(0.248 \text{ ksf})(1 \text{ ft})(30 \text{ ft})^2}{9} \end{aligned}$$

REF	PAGE
1	9
1	9
1	9
-	10



CALCULATION WORK SHEET

P. CALCULATION NUMBER	REV
C47.	540 - 0B
JOB NO.	
PAGE 12	OF 14

V. (continued from page 11):

$$M_u = 91 \text{ ft-k} + 8.4 \text{ ft-k/ft (1 ft width)} + 24.8 \text{ ft-k}$$

$$= 124.2 \text{ ft-kip}$$

The resulting applied ultimate moment from the original calculation was 118 ft-kips. However, this moment was compared with that utilized for the design of slab section 'B', which was 126.5 ft-kips. Therefore, since the revised moment calculated here is 124.2 ft-kips and is less than the governing design moment of 126.5 ft-kips, it can be concluded that the additional loading imposed by the ponded rainwater will not affect the structural integrity of slab section 'C'.

REF	PAGE
-----	------

1	9
1	9

VI. Roof Slab Section 'D':

Based upon a review of the original calculation, slab section 'D' was found to be the most critical section due to the highest applied ultimate moment.

Slab section 'D' is a cantilevered section with a span of 13'-0". Therefore, the analysis performed here will be similar to that performed for slab section 'B'.

1	9
1	9

- Referring to the original calculation, the effective width of the concrete plugs which contribute to a point load at the end of the cantilevered section is 2.29 ft. Therefore, the Dead Load of the plugs (2 ft. thick) is:

$$D.L. = 2 \text{ ft.} \times 2.29 \text{ ft.} \times 150 \text{ pcf/1000} = 0.687 \text{ k/ft}$$

Therefore, the factored point load from the concrete plugs is:

$$P_u = 1.4 D.L. + 1.9 g_v (D.L.) \quad (\text{neglecting live load, as stated on page 3})$$

$$= 1.4(0.687 \text{ k/ft}) + 1.9 (0.162)(0.687 \text{ k/ft})$$

$$P_u = 1.17 \text{ k/ft}$$

1	9
7	-

The additional loading on the cantilever due to the curbing around the concrete plugs, from the original calculation, is:

$$P = 0.53 \text{ kips/ft}$$

Therefore, the total applied point load at the end of the cantilever is:

$$P_u = 1.17 \text{ k/ft} + 0.53 \text{ k/ft} = 1.70 \text{ k/ft or } 1.70 \text{ kips for } 1 \text{ ft. width}$$

1	9
---	---

- The ultimate moment for slab section 'D' is calculated as follows:

$$M_u = P_u(L) + \frac{W_{u1}(L)^2}{2} + \frac{W_{u2}(L)^2}{2} + M_{ut}$$

REF-013



CALCULATION WORK SHEET

1. CALCULATION NUMBER		REV
C47.	540	- 0B
JOB NO.		
PAGE	13	OF 14

VI. (continued from page 12):

$$P_u = 1.7 \text{ kips}$$

$$W_u = 0.91 \text{ kips same as that determined for slab section 'C'}$$

$$W_w = 0.248 \text{ ksf or } 0.248 \text{ k/ft for 1 ft. width of slab analyzed}$$

$$M_{ut} = 8.4 \text{ ft-k/ft or } 8.4 \text{ ft-kip for 1 ft. width of slab analyzed}$$

Therefore, the total applied ultimate moment for slab section 'D' is:

$$M_u = (1.7)(13 \text{ ft}) + \frac{(0.91)(13)^2}{2} + \frac{(0.248)(13)^2}{2} + 8.4 \text{ ft-k}$$

$$M_u = 128.35 \text{ ft-k}$$

Since this revised moment is slightly higher than the originally calculated moment of 126.9 ft-k, the remainder of the analysis will be performed to determine the area of reinforcing steel required, as compared to that provided in the original design.

1. From reference #3, "Flexure 1.1", page 105;

$$F = \text{flexural coeff.} = \frac{bd^2}{12000}$$

$$b = 12 \text{ inches (width of slab being analyzed)}$$

$$d = 19.885 \text{ inches ('d' was previously defined on page 9, however this area of the roof is 2 ft. thick thereby reducing 'd' to 19.885" from 39.885")}$$

$$F = \frac{(12")(19.885")^2}{12000} = 0.395$$

From ref. #3, page 105,

$$K_u = \text{strength coeff. of resistance} = \frac{M_u}{F} = \frac{128.35 \text{ ft-k}}{0.395} = 324.94$$

therefore, from the table on page 105: (by interpolation)
using $f'_c = 3000 \text{ psi}$ and $f_y = 40,000 \text{ psi}$

$$\rho = \text{tension reinf. ratio} = 0.0098$$

Therefore, the Area of Steel required is:

from ref. #3, page 105

$$A_s = \rho b d = 0.0098 \times 12" \times 19.885" = 2.338 \text{ sq. in.}$$

The Area of Steel provided in the original design was:

$$\#11 \text{ bars @ } 8" \text{ Top \& Bottom} = 2.34 \text{ sq.in.}$$

Therefore, sufficient steel is provided as required by the revised moment.

REF PAGE

- 11
- 9
- 4

1 9

3 105

1 9

2 2-1

3 105

3 160



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C47.	540	- 08
JOB NO.		
PAGE 14	OF	14

VI. (continued from page 13):

Therefore, since sufficient steel area is provided in the slab to satisfy the requirements of the revised moment determined herein, it can be concluded that the additional loading imposed by the ponded rainwater will not affect the structural integrity of slab section 'D'.

(Note: Since the applied loadings from P_u and W_u are smaller than those originally calculated, the check for shear is acceptable by observation, including the small amount of loading added by ponded water.)

REF	PAGE
1	9
-	11
1	9
1	10
7	-
1	-

VII. Roof Slab Section 'E':

The analysis for slab section 'E' is similar to that performed for section 'C' (see page 11 of this calculation).

Referring to pages 5 and 8 of this calculation and page 10 of the original calculation, the span of section 'E' is 22'-4". The distributed loading on the slab is the same as that applied to slab section 'C', that is:

$$W_u = 0.91 \text{ k/ft (representing slab weight, cable tray and pipe support loads)}$$

$$M_u = \frac{W_u(L)^2}{9} + M_{ut} + \frac{W_w(L)^2}{9} \quad \begin{array}{l} W_w = 0.248 \text{ ksf (page 9)} \\ M_{ut} = 8.4 \text{ ft-k (page 4)} \end{array}$$

Therefore:

$$M_u = \frac{(0.91 \text{ k/ft})(22.33\text{ft})^2}{9} + 8.4 \text{ ft-k} + \frac{(0.248\text{ksf})(1\text{ft})(22.33\text{ft})^2}{9}$$

$$M_u = 72.56 \text{ ft-k}$$

Since the ultimate applied moment determined here of 72.56 ft-k is less than the design governing moment of 126.5 ft-k to which slab section 'C' was compared, and since the reinforcing steel design is the same as section 'C', the slab loading is acceptable. The additional loading imposed by the ponded rainwater will not affect the structural integrity of the slab.

VIII. Conclusion:

As determined by this calculation, it can be seen that the additional loading imposed by the maximum height of ponded rainwater that may occur, 2'-4", will not affect the structural integrity of the roof slab at elevation 152'-6". The original design calculation (reference #1) provided more than adequate reinforcing steel, so that the conditions reviewed herein are enveloped by the original design parameters.

(Note: The remaining slab sections of the roof structure that were not identified and were not analyzed in the original calc. or here, are sections which are considered to be enveloped by those sections that were analyzed.)

FD-203 1-67



RIVER BEND STATION
GULF STATES UTILITIES COMPANY

DESIGN DOCUMENT
NO. CALCULATION
647.540-08

DESIGN REVIEW CHECKLIST (REF. EDP-AA-58)

	YES	NO	N/A
1. Were the inputs correctly selected and incorporated into the design?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Are the assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Are the appropriate quality and quality assurance requirements specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4. Are the applicable codes, standards, and regulatory requirements, including issue and addenda, properly identified and are their requirements for design met?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Have applicable construction and operating experience been considered?.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6. Have the design interface requirements been satisfied?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7. Was an appropriate design method used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Is the output reasonable compared to inputs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Are the specified parts, equipment, and processes suitable for the required application?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
10. Are the specified materials compatible with each other and with the design environmental conditions to which the material will be exposed?.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
11. Have adequate maintenance features and requirements been specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
12. Are accessibility and other design provisions adequate for the performance of needed maintenance and repair?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
13. Has adequate accessibility been provided to perform the in-service inspection expected to be performed during the plant life?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14. Has the design properly considered radiation exposure to the public and to plant personnel?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
17. Are adequate handling, storage, cleaning and shipping requirements specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
18. Are adequate identification requirements specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
19. Are requirements for record preparation, review, approval, retention, etc. adequately specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20. Have environmental, safety, and seismic adequacy been considered?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. Have recommended spare parts been specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
22. Have fire hazard analysis impacts been considered?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Verifier's Summary:

DESIGN VERIFIED

Richard J. Kern
Verifying Engineer

7/06/89
Date

CALCULATION TITLE PAGE

*SEE INSTRUCTIONS ON REVERSE SIDE

AS 1010 (FRONT)

CLIENT & PROJECT GULF STATES UTILITIES CO. RIVER BEND				PAGE 1 OF 25 (INCL. ATT.) C47.540		
CALCULATION TITLE (Indicative of the Objective): STANDBY S.W. COOLING TOWER DESIGN OF ROOFS @ EL. 152'-6" & 163'-4" AND WALLS FROM EL. 152'-6" TO EL. 163'-4"				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER		
CALCULATION IDENTIFICATION NUMBER						
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.		
12210	STRUCTURAL	C47.540	N/A	N/A		
* APPROVALS - SIGNATURE & DATE				REV. NO. OR NEW CALC NO	SUPERSEDES * CALC. NO OR REV. NO.	CONFIRMATION * REQUIRED (✓) YES NO
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)				
<i>J.E. Dorval</i> 11-18-81	<i>Patel</i> 11-19-81 (T.C. PATEL)	<i>Patel</i> 11-19-81 (T.C. PATEL)	0	N/A		✓
FOR INFORMATION ONLY						
<div style="border: 1px solid black; padding: 5px; display: inline-block;"> DESIGN ENGINEERING CONTROL COPY SDC </div>						
RECEIVED JUN 09 1989 SDC						
DISTRIBUTION *						
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)	
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	D. MARTIN - 4R	✓				
FOR INFORMATION ONLY						

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

6501001

J.O. / P.O. / CALCULATION NO.

12210 / C47.540

REVISION

0

PAGE

C47.540

PREPARED / DATE

L.E. Orzol 11-18-81

REVIEWER / CHECKER / DATE

R. Lopez 11-18-81

INDEPENDENT REVIEWER / DATE

J. (at) 11-19-81

SUBJECT / TITLE

STANDBY S.W. COOLING TOWER
DESIGN OF ROOF SLABS @ EL. 152'-6" & 163'-4" AND
WALLS FROM 152'-6" TO 163'-4"

QA CATEGORY / CODE CLASS

I

TABLE OF CONTENTS

PAGE	DESCRIPTION
C47.540	TITLE PAGE
C47.540.1	TABLE OF CONTENTS
C47.540.1.1	HISTORICAL DATA
C47.540.2	CALCULATION SUMMARY
C47.540.3	DESIGN CHECKLIST
C47.540.4 To C47.540.10 + 10A	{ DESIGN OF ROOFS (EL. 152'-6") AND DES. OF WALLS (152'-6" TO 163'-4") }
C47.540.11 & C47.540.12	{ SKETCHES OF REINFORCEMENT }
C47.540.13	PARTIAL PLAN OF ROOF (EL. 163'-4")
C47.540.14 - 16	DESIGN OF ROOF SLAB (EL. 163'-4")
C47.540.17, 18	SKETCHES OF REINF. (ROOF @ 163'-4")
C47.540.19	EMB. PLATES FOR MONORAIL (163'-4")
-	LIST OF ATTACHMENTS (INCL. ATTC.#1)

FOR INFORMATION ONLY

NOTE:-


WORK THIS SHEET WITH
HISTORICAL DATA SHEET.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

PROJECT / CALCULATION NO. **12210 / C47.540** REVISION **0** PAGE **C47.540.11**

PREPARED / DATE: **T.E. DARR / 11-18-81**
 REVIEWER / CHECKER / DATE: **M. [unclear] / 11-19-81**
 INDEPENDENT REVIEWER / DATE: **T. [unclear] / 11-19-81**
 PROJECT / TITLE: **STANDBY S.W. COOLING TOWER DESIGN OF SLABS & WALLS (EL. 152'-6" ~ 163'-4")**
 QA CATEGORY / CODE CLASS: **I**

HISTORICAL DATA - REVISION 

REASON FOR CHANGE AND SOURCE OF INFORMATION:

PAGE	DESCRIPTION
	<p style="text-align: center;">FOR INFORMATION ONLY</p>

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.B. / B.C. CALCULATION NO.

12210

C 47.540

REVISION

0

PAGE

C 47.540.2

ASD1001

PREPARED / DATE

W.E. PEARL / 11-18-81

REVIEWED / CHECKER / DATE

T. RAY / 11-19-81

INDEPENDENT REVIEWER / DATE

T. RAY / 11-19-81

SUBJECT / TITLE

STANDBY S.W. COOLING TOWER
DESIGN OF ROOFS @ EL. 152'-6" & 163'-4" AND WALLS
BETWEEN 152'-6" & 163'-4"

QA CATEGORY / CODE CLASS

I

CALCULATION SUMMARY

PURPOSE:

TO DETERMINE THE SIZE AND REINFORCEMENT FOR THE SLABS @ EL. 152'-6" & 163'-4" AND THE WALLS BETWEEN EL. 152'-6" & 163'-4"

REFERENCES:

- STRUCTURAL DESIGN CRITERIA FOR RIVER BEND UNITS 142 DOC. # 200.010, REV. 1
- SEISM. ANALYSIS OF STANDBY COOLING TOWER BY ENG'G MECH. DATE: 9-20-80 CALC # 201.120
- ACI- 318-71
- ENG'G MONOGRAPHS BY BUREAU OF RECLAMATION, U.S. GOVERN. PRINTING OFFICE WASHINGTON D.C. 1970
- PCA NOTES ON ACI 318-71.
- AISC - 7TH EDITION.
- ACI SP 17-73

CONCLUSION:

SEE PAGES: C 47.540.11, 12; C 47.540.17, 18

CALCULATION STATUS:

PRELIMINARY _____

FINAL _____

SUPERSEDED _____

CODE CLASS:

N/A

SOURCE OF DATA:

12210 EC-47 SERIES.
CALC No. MC 2.1
" " 570.375 FOR INFORMATION ONLY

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

12210

CALCULATION NO. / *C47.526*

REVISION
0

PAGE
C47.540.3

SD1001

PREPARED / DATE
L.E. O'Neal / 11-18-81

REVIEWER / CHECKER / DATE
Relat / 11.19.81

INDEPENDENT REVIEWER / DATE
Relat / 11.19.81

SUBJECT / TITLE
STANDBY S.W. COOLING TOWER
DESIGN OF ROOF SLABS @ 152'-6" & 163'-6" AND WALLS,
FROM 152'-6" TO 162'-6"

SA CATEGORY / CODE CLASS
I

DESIGN CHECKLIST

LOAD CONSIDERATIONS	✓
DEAD	✓
LIVE	✓
EQUIPMENT	✓
PIPE	
WIND	
TORNADO	✓
POSITIVE PRESSURE	
NEGATIVE PRESSURE	
SEISMIC	✓
THERMAL	✓
HYDROSTATIC	
EARTH PRESSURES	
MISSILE	
CONSTRUCTION	
SNOW AND ICE	

MATERIAL	GRADE/ STRENGTH
CONCRETE	$f'_c = 3000$ psi
REINFORCEMENT	$f_y = 40000$ psi
STRUCTURAL STEEL	-
HIGH STRENGTH BOLTS	-
COMMON BOLTS	-
WELD RODS	-
ANCHOR BOLTS	A-307
STUDS	-

FOR INFORMATION ONLY


CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

ASD 101 B1

J.O./W.O./CALCULATION NO. 12210 / C47.540	REVISION 0	PAGE C47.540.4
PREPARED BY / DATE L. J. [unclear] / 10-28-81	REVIEWER / CHECKER / DATE [unclear] / 11.16.81	INDEPENDENT REVIEWER / DATE [unclear] / 11.16.81
SUBJECT / TITLE STANDBY SERVICE WATER COOLING TOWER DESIGN OF SLABS EL. 163'-4" & 152'-6"		QA CATEGORY / CODE CLASS I

← --- CALLED NORTH



PARTIAL PLAN EL. 152'-6" & 163'-4" (EC 478J-1)
SCALE: $\frac{3}{8}'' = 1'-0''$

FOR INFORMATION ONLY

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./B.O./CALCULATION NO. 12210/C47.540		REVISION 0	PAGE C47.540.5
PREPARED/DATE E. Onorol 10-29-81	REVIEWER/CHECKER/DATE T. Latal 11.16.81	INDEPENDENT REVIEWER/DATE T. Latal 11.16.81	
SUBJECT/TITLE STANDBY SERVICE WATER COOLING TOWER DESIGN OF SLABS EL 163'-4" & 152'-6"		QA CATEGORY/CODE CLASS I	

TEMPERATURE MOMENT: (FOR 2'-0" SLABS)

$$\Delta T = 50^\circ F$$

$$\alpha = 0.55 \times 10^{-5} / F$$

$$E_c = 57000 \sqrt{f_c} = 57000 \sqrt{3000} = 4.5 \times 10^5 \text{ ksi}$$

$$\gamma = 0.2$$

$$n = 9 (f_c = 3000)$$

ASSUMING 6#
60%
 $H = 2' = 24"$
 $d = 24 - 2 - 1.5 \times 1.41 = 19.885"$
 $d' = 24 - 4 - 3 \times 1.41 = 15.77"$

$$K_1 = \frac{K_1 H}{H} = \frac{19.885}{24} = 0.83$$

$$K_2 = \frac{K_2 H}{H} = \frac{15.77}{24} = 0.66$$

* STRUCTURAL DESIGN (A.I.T.F.)
FOR RIVER BUILT UNIT 902
SECT.: 3E. (ATT. # 3.E-1)
DOC. # 200.010

Assuming #11 @ 10" @ E.F

$$f = \frac{1.87}{12 \times 24} = 0.0065 \quad f' = \frac{1.87}{12 \times 24} = 0.0065$$

$$N = -n(f + 2f') \pm \sqrt{n^2(f + 2f')^2 + 2n[2f'(K_1 - K_2) + K_1 f']}$$

$$= -9(0.0195) \pm \sqrt{81(0.0195)^2 + 18[0.0130(0.83 - 0.66) + 0.83 \times 0.0065]}$$

$$= -0.1755 \pm 0.4095$$

$$N = 0.234$$

$$M_T' = (\alpha N^2 H^2 \Delta T E_c) / 2 \left[(K_1 - \frac{N}{3}) + (4n(N - K_1 + K_2) f' K_2) / N^2 \right]$$

$$= 0.55 \times 10^{-5} (0.234)^2 (2)^2 \times 50 \times 4.5 \times 10^5 \left[(0.83 - \frac{0.234}{3}) + (36(0.234 - 0.83 + 0.66) \times 0.0065 \times 0.66) / (0.234)^2 \right]$$

$$M_T' = 12.64 \text{ k-ft}$$

$$M_T = M_T' / (1 - \gamma) = 12.64 / (1 - 0.2) = 15.8 \text{ k-ft}$$

$$1.3 M_T = 1.3 \times 15.8 = 20.54 \text{ k-ft SAY } 21 \text{ k-ft}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

12210 / C47.540

REVISION

0

PAGE

C47.540.7

6801061

PREPARED/DATE

I.E. VAND/ 10-29-81

REVIEWER/CHECKER/DATE

PLAZA 11.16.81

INDEPENDENT REVIEWER/DATE

R. L. Lutz 11.16.81

PROJECT/TITLE

STANLEY SERVICE WATER COOLING TOWER
DESIGN OF WALL FROM 152'-6" TO 163'-4"

QA CATEGORY/CODE CLASS

I

SPAN IS ~ 28' (SCALED)

HEIGHT = 10'-10" THICK = 2'

FOR INFORMATION ONLY

ASSURE IT TAKES 5'-6" WIDE 163'-4" SLAB

$$DL = 2 \times 5.5' \times 0.15 + 10.83 \times 2 \times 0.15 = 4.90 \text{ k/l}$$

$$LL = 7.6 \times 0.03 = 0.23 \text{ k/l}$$

$$5.13 \text{ k/l}$$

* Seismic Profiles
F_o/F_o = 24 ksi

$$S_{\text{seismic}} = 5.13 \times 0.162$$

$$0.83 \text{ k/l}$$

$$W_u = 1.4 \times DL + 1.7LL + 1.9 \times S_{\text{seismic}}$$

$$W_u = 1.4 \times 4.9 + 1.7 \times 0.23 + 1.9 \times 0.83 = 8.82 \text{ k/l}$$

$$M_u = wL^2/8 = 8.82 \times 28^2/8 = 865.34 \text{ k-ft}$$

Assume deep beam $d = 0.75 \times 10.83' \Rightarrow 8.12' \Rightarrow 97.5"$

$$F = bd^2/12000 = \frac{24 \times 97.75^2}{12000} = 19.11$$

$$K = M_u/F = \frac{865.34}{19.11} = 45 \Rightarrow \rho = 0.0015$$

$$A_s = 0.0015 \times 24 \times 97.75 = 3.5 \text{ in}^2$$

$$A_s/FT/ft = \frac{3.5}{5.4 \times 2} = 0.32 \text{ in}^2$$

SHEAR $V_c = \frac{V}{0.85bd} = \frac{8.82 \times 14' \times 1000}{0.85 \times 24 \times 97.5} = 62 \text{ psi} < 110 \text{ psi O.K.}$

$$\text{Min } A_s = 0.0025 \times 12 \times 24 = 0.72 \text{ in}^2 < 1.87 \text{ in}^2$$

USE #11 @ 10" E.F. H (min req'd for missile protection)

VERTICAL REINFORCEMENT

Seismic force: $2 \times 0.15 \times 0.439 = 0.13 \text{ k-l}$ $M_T = 21 \text{ k-ft}$
 $1.9 \times 0.13 = 0.25 \text{ k-l}$ (ASSUME SAME M_T 2' SLAB)

$$A_s = \frac{M_u}{m \cdot d} = \frac{25}{2.95 \times 22} = 0.39 \text{ in}^2$$

$$M_u = 0.25 \times 10.83^2/8 + 21 = 25 \text{ k-ft}$$

$$K_u = M/F = \frac{25}{3.95} = 63 \Rightarrow \rho = 2.95$$

USE #11 @ 10" E.F.V. ($1.87 \text{ in}^2 > 0.39 \text{ in}^2$)

MIN REQ'D FOR MISSILE PROTECTION

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./B.O./CALCULATION NO. 1220 / C47.540		REVISION 0	PAGE C47.540.8
PREPARED BY I.E. Choro / 10.29.81	REVIEWER / CHECKER / DATE R. Patel / 11.16.81	INDEPENDENT REVIEWER / DATE R. Patel / 11.16.81	
SUBJECT / TITLE STANDBY SERVICE WATER COOLING TOWER DESIGN OF 152'-6" SLABS		QA CATEGORY / CODE CLASS I	

1. PORTION OF THE SLAB BETWEEN OPENINGS FOR INFORMATION ONLY

SLAB IS 4'-6" WIDE \approx 18' LONG (SCALED) $d = 44 - 2 - 1.5 \times 1.41 = 39.885'$

$$DL = 4.9 + 4.5 \times 3.67 \times 0.15 = 4.9 + 2.48 = 7.38 \text{ k/ft}$$

$$LL = 0.23 + 0.03 \times 4.5 = 0.37 \text{ k/ft}$$

$$S_{\text{eism}} = 0.162 \times (7.38 + 0.37) = 1.26 \text{ k/ft}$$

$$w_u = 1.4DL + 1.7LL + 1.9 \times S_{\text{eism}} = 9.01 \text{ k/ft}$$

$$w_u = 1.4 \times 7.38 + 1.7 \times 0.37 + 1.9 \times 1.26 = 13.36 \text{ k/ft}$$

$$M = wL^2/8 = 13.36 \times 18^2/8 = 480.96 \text{ k-ft}$$

$$\text{Total } M = 480.96 + M_T = 480.96 + 21 \times 4.5 = 575.5 \text{ k-ft}$$

Additional moment due to pipe & cable tray $\Rightarrow [(1.7 \times 0.200 + 1.9 \times 0.162 \times 0.200) \times 4.50] \times \frac{18^2}{8} = 65 \text{ k-ft} \Rightarrow M_u = 575.5 + 65 = 640.5$

$$\frac{M_u}{\phi f'_c b d^2} = \frac{640.5 \times 12}{0.85 \times 3 \times 54 \times (39.885)^2} = 0.0351 \Rightarrow u = 0.036$$

(PCA NOTES ON ACI 318-77, Pg. 9-7)

$$f = u \frac{f'_c}{f_y} = 0.036 \frac{3}{40} = 0.0027$$

$$A_s = \rho b d = 0.0027 \times 54 \times 39.885 = 5.82 \text{ in}^2$$

$$A_s/FT = 5.82/4.5 = 1.29 \text{ in}^2$$

USE #11 @ 8" E.W. T & B (2.34) / 1.29 in² = O.K.

CHECK ON SHEAR $\Rightarrow u_v = \frac{13.36 \times 9 \times 1000}{0.85 \times 54 \times 39.885} = 65.7 < 110 \text{ psi} = \text{O.K.}$

CHECK ON CANTILEVER PORTION:

Assume it takes 1/2 of conc. plug load

$$D.L = \frac{2 \times 5.5 \times 0.15}{p} = 1.65 \text{ k} \quad LL = 0.03 \times 5.5 = 0.165$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 12210 / C47.540		REVISION 0	PAGE C47.540.9
PREPARED/DATE I.E. Orazol 11-2-81	REVIEWER/CHECKER/DATE T. L. Lutz 11.16.81	INDEPENDENT REVIEWER/DATE T. L. Lutz 11.16.81	
SUBJECT/TITLE STANDBY SERVICE WATER COOLING TOWER DESIGN OF 152'-6" SLAB		QA CATEGORY/CODE CLASS I	


FOR INFORMATION ONLY

$$P_u = 1.4 \times 1.65^k + 1.7 + 0.165 + 1.9 \times 0.162 (1.65 + 0.165)$$

$$P_u = 3.15^k \quad \text{Additional } P_u = (1.25 \times 2' \times 0.15) 1.4 = 0.53^k \quad (\text{ignore seismic})$$

due to curb. Tot. $P_u = 3.6^k$

$$\text{SLAB} \Rightarrow 12' \times 1' \times 0.15 = 0.3 \quad L = 0.03 \times 1' = 0.03$$



$$w_u = 1.4 \times 0.3 + 1.7 \times 0.03 + 1.9 \times 0.162 \times 0.36 = 0.57 \quad \left. \begin{array}{l} \\ \\ \end{array} \right\} w_u = 0.9$$

$$w_{\text{slab}} = 0.200 \times 1.7 + 1.9 \times 0.162 \times 0.200 = 0.400$$

$$M_u = 3.6 \times 11.5 + 0.97 \times 11.5^2 / 2 + 21 = 126.5^k \Rightarrow M/F = \frac{126.5}{.395} = 320$$

$$A_s = 0.0097 \times 12 \times 14.885 = 2.31 \text{ in}^2 \quad p = 0.0097$$

USE #11 @ 8" T & B. E.W (2.34 > 2.31)

Longest span = 30'

$$M_u \approx wL^2/9 + M_T \Rightarrow M_u = \frac{0.97 \times 30^2}{9} + 21 = 118^k < 126.5^k$$


conservative USE #11 @ 8" T & B.

check on cantilever portion (N-S) span = 13.0'

$$P_u = 1.4(2 \times 2.29 \times 0.15) + 1.7(0.03 \times 2.29) + 1.9 \times 0.162(0.75) = 1.31$$

$w_u = 0.97$ Total $P_u = 1.31 + 0.53 = 1.84$

$$M_u = 1.84 \times 13.0 + 0.97 \times 13.0^2 / 2 + 21 = 126.9^k$$



$$(4.5 + 11) / 2 = 7.75$$

$$7.75 / 11 = 0.704$$

$$E_w d = 7.25 \times 0.704 = 5.11$$

$$K_u = \frac{M}{F} = \frac{126.9}{.395} = 321 \Rightarrow p = 0.0097$$

$$A_s = 0.0097 \times 12 \times 14.885 = 2.31 \text{ in}^2$$

USE #11 @ 8" T & B (2.34 > 2.31) O.K.

CHECK ON SHEAR

$$v_c = \frac{V}{0.85 \times b \times d} = \frac{(1.84 + 0.97 \times 13.) \times 1000}{0.85 \times 12 \times 14.885} = 71.3 \text{ psi} < 110 \text{ psi}$$

O.K.

CALCULATION SHEET

J.O./C.O./CALCULATION NO.

12210 / C47.540

REVISION

0

PAGE

C47.540.10

05/10/81

PREPARED/DATE

I.E. Ojani 11.2.81

REVIEWER/CHECKER/DATE

T. Latif 11.16.81

INDEPENDENT REVIEWER/DATE

T. Latif 11.16.81

SUBJECT/TITLE

STANDBY SERVICE WATER COOLING TOWERS
DESIGN OF 152'-6" SLAB

QA CATEGORY/CODE CLASS

I

RECTANGULAR PORTION OF 152'-6" SLAB


MAX SPAN = 22'-4" A. OR simple supported

$$M_{max} = wL^2/8 = 0.97 \times \frac{22.33^2}{8}$$

$$= 53.74 \text{ k-ft}$$

∴ USE #11 @ 8" E.W. T & B

CANTILEVER WALL PORTION



DESIGN OF SEAB:

$$P_u = 1.4(6 \times 22 \times 0.15) + 1.9 \times 1.8 \times 0.162$$

$$= 3.1 \text{ k}$$

$$w_u = 0.97 \text{ k/ft}$$

$$M_u = 0.97 \times \frac{4^2}{2} + 3.1 \times 4 = 20.2 \text{ k-ft}$$

$$M_u = 20.2 \text{ k-ft}$$

USE #11 @ 8" E.W. T & B

SINCE WALL WILL CARRY ONLY ITS OWN WEIGHT

USE #11 @ 10" E.F.H & VERTICAL FOR WALL

FOR 1' THICK INTERIOR WALLS; USE MIN. REINF.

$$A_s = \rho b d = 0.002 \times 12 \times 10.5' = 0.25 \text{ in}^2$$

USE #8 @ 12" E.F. E.W (FOR 1' THICK WALLS)

FOR INFORMATION ONLY



CALCULATION TITLE PAGE ENGINEERING DEPARTMENT

Job #G13.1.2

12210-C29.	0.1	- 3B
JOB NO.		
PAGE 1	OF 9	

2. CALCULATION TITLE:
Diesel Generator Bldg. - Slab Design

3. SUPERSEDES CALC. OR REVISION NO.:
C29.0.1 Rev. 3, Add. A

4. OBJECTIVE OF CALCULATION:
The objective of this calculation is to prove the adequacy of the roof slab at elev. 126'-0" to support a maximum height of ponded rainwater, assuming that the scupper drains provided in the West wall of the building are clogged. (Note: This is a very conservative approach since the drains will not completely block and water will drain.)

5. CALCULATION METHOD/ASSUMPTIONS:
The method employed in this calculation for determining the adequacy of the slab is a simple determination of the reserve capacity of the slab based upon designed loading, as compared to the maximum potential loading from ponded rainwater. If the reserve capacity of the slab exceeds the potential water loading, the slab is acceptable. If the reserve capacity does not exceed the rainwater loading, additional analysis and/or justification is provided to insure the adequacy of the existing slab design.

- 6. SOURCES OF DATA/EQUATIONS (REFERENCES):**
1. Calculation 12210-C29.0.1 Rev. 3; "Diesel Generator Bldg. - Slab Design"
 2. Structural Design Criteria - Doc. No. 200.010, Rev. 5, dated 3/15/85
 3. Design Handbook ACI 318-71, Publication SP-17(73)
 4. Drawing EC-29G-3; "Floor Plan EL. 126'-0", Outline, Diesel Generator Bldg."
 5. "Standard Handbook for Civil Engineers"; Merritt; Second Edition; 1968

7. CONCLUSIONS:
Based upon the reserve capacity of the existing roof slab at elevation 126'-0", the additional loading imposed by the maximum potential height of ponded rainwater will not compromise the structural integrity of the slab.

8. REASON FOR REVISION (IF APPLICABLE):
The reason for this addendum is to provide a technical review of the adequacy of the roof slab at elev. 126'-0" to support the maximum potential height of ponded rainwater. Though the slab design is adequate to support the rainwater, the specific loading imposed by water was not individually identified in the original calculation.

9. RELATED DOCUMENTS: N/A	10. QA CATEGORY <input checked="" type="checkbox"/> I-NUCLEAR <input type="checkbox"/> SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III
-------------------------------------	--

11. DESIGNER <i>Tim Roun</i> 6/27/89	12. CHECKER/REVIEWER <i>Tim Roun</i> 6/27/89	13. INDEPENDENT REVIEWER <i>Tim Roun</i> 6/27/89
--	--	--

14. DATA REQUIRING CONFIRMATION:
N/A

DATA CONFIRMED BY: _____ **DATE:** _____



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C29.	0.1	- 3B
JOB NO.		
PAGE	3	OF 9

OBJECTIVE:

As stated on page 1, the objective of this calculation is to confirm the adequacy of the roof slab of the Diesel Generator Bldg. at elev. 126' to support the loading imposed by the maximum potential height of ponded rainwater.

METHOD and SOLUTION:

An outline of the configuration of the roof slab at elevation 126'-0" is shown on page 4 of this calculation. In this outline the slab is divided into sections, S1, S2, and S3, for which an original analysis was performed to determine the design loading and subsequently the slab reinforcing requirements for the overall slab.

On page 5 of this calculation, an outline of the roof slab at elev. 126'-0" is provided showing the physical layout of the roof cubicles with all passageway openings and the scupper drain locations in the West wall of the building. The purpose of this page is to indicate the maximum height of rainwater that could be contained within each cubicle of the roof slab, 7 inches, prior to the water draining into the adjacent cubicle and eventually off the roof through the opening in the North wall of the roof. (See page 8, conclusions, for additional explanation.)

- A. The method employed by this calculation, to verify the adequacy of the roof slab, will be to extract the design loading determined from the original calculation; determine the actual capacity of the slab based upon the reinforcing steel provided; determine the reserve capacity of the slab; and compare the reserve capacity to the loading imposed by the maximum potential height of ponded rainwater.
- B. It should be noted that the approach defined above is very conservative in nature for the following reasons:
 1. This method of review assumes that the scupper drains in the West wall of the roof structure are totally clogged and do not allow any drainage of water. Since this condition is extremely unlikely, the maximum ponded height of rainwater, 7 inches, will more than likely be reduced due to drainage.
 2. Though the potential for simultaneous loadings, from the full value of the original design loads, for Live and Temperature Differential, are potentially reduced during a max. height of ponded rainwater, no reductions in these loads will be considered.
 3. In this calculation we are analyzing the effect of the ponded rainwater on slab section "S2" as compared to section "S1". Since the slabs are sloped in the direction of slab S1, the ponded depth will actually occur on top of S1. However, the original calc. determined that the max. stresses occurred in slab S2. In addition, the unsupported span length of section S1 is shorter than that of section S2. Therefore, it is very conservative to analyze section S2 and distribute the maximum depth of ponded water over the entire section to determine structural adequacy.

REF	PAGE
1	C29. 9

11/27/00-4



CALCULATION WORK SHEET

C29.	2.1	-33
JOB NO.		
PAGE 4 OF 9		

CALCULATION SHEET

STRUCTURE & REVISION ENGINEERING CORPORATION

J.O. / S.D. / CALCULATION NO.

REVISION 3 PAGE

REF PAGE
1 C29.
9

AMERICAN

12210

C29-9

PREPARED / DATE

REVIEWED / CHECKED / DATE

INDEPENDENT REVIEWER / DATE


K. A. Blak / 1-18-85

M. Ahmad / 1-21-85

M. Ahmad / 1-21-85

SUBJECT / TITLE
DIESEL GENERATOR HLDG
FLOOR SLAB DESIGN BL 126-0

QA CATEGORY / CODE CLASS
I



REF 70004

FD-713 1-87

FOR INFORMATION ONLY



CALCULATION WORK SHEET

P. CALCULATION NUMBER		REV
C29.	0.1	- 3B
JOB NO.		
PAGE 6	OF	9

REF	PAGE
1	C29.10 & 11
1	C29.13 & 11

Referencing Page 4 of this calculation, which is page C29.9 of the original design calculation for the slab at elev. 126'-0";

From the original calculation performed, it is found that the most critical slab section exhibiting the highest stresses was section "S2".

The maximum applied moment (M_u) for slab S1 is :

$$M_u = 66.0 \text{ KFT} + 19.8 \text{ KFT/FT (diff. temp. } T_o)$$

The maximum applied moment (M_u) for Slab S2 is:

$$M_u = 86.0 \text{ KFT} + 19.8 \text{ KFT/FT (diff. temp. } T_o)$$

Slab "S3" is not considered in this review since it is located outside of the "containment" area of the roof. The slab area identified as "S3" is located on the North end of elev. 126'-0" and is bounded on the South side only. The remaining edges of the slab are open and therefore permit runoff of rainwater.

Since the maximum applied moment for the slab at elev. 126'-0" is found to exist in section "S2", we will utilize this section for the determination of structural adequacy to support ponded rainwater loads. To clarify the origin of the loading on this section of the slab, we will re-state the loading combination equation and results found in the original calculation on pages C29.12 and C29.13:

The load combination equation utilized in the original calculation is:

$$U = 1.4D + 1.7L + 1.9 \text{ OBE} + 1.3 T_o \text{ (EQ. \#3, Ref. 2, Pg. 4-6)}$$

D = Dead Load; L = Live Load; OBE = Operational Basis Earthquake;
 T_o = Loads due to Temp. Gradient

From page C29.13 of the original calculation:

$$\begin{aligned} 1.4D &= 1.4(372 \text{ psf}) = 520.8 \text{ psf} & g_v &= \text{OBE Vert. Accel.} \\ 1.7L &= 1.7(100 \text{ psf}) = 170 \text{ psf} \\ 1.9\text{OBE} &= 1.9[(g_v)(DL + LL)] = 1.9[(.164)(372 + 100)] = 147.08 \text{ psf} \\ 1.3T_o &= 1.3(15.25) = 19.8 \text{ KFT/FT} = M_{ut} \text{ (moment from temp.)} \end{aligned}$$

$$U = 838 \text{ psf} \text{ excluding temp. loads which are added separate}$$

The distributed load as a result of the temp. gradient moment (M_{ut}) is:

From page C29.13, Ref. 1;

$$M_{ut} = \frac{w_u L^2}{10} \quad w_u = \frac{M_{ut} \times 10}{L^2} = \frac{19.8 \times 10 \times 1000}{32^2} = 193.4 \text{ psf}$$

(Note: L = 32 ft. from the section diagram in the orig. calc. on page C29.13)



CALCULATION WORK SHEET

T. CALCULATION NUMBER		REV
C29.	0.1	- 3B
JOB NO.		
PAGE 7	OF	9

REF	PAGE
3	105
2	2-1
3	105
3	105
1	
5	15-9

Therefore, the total distributed loading on slab "S2" is:

$$W_u = 838 \text{ psf} + 193.4 = 1031.4 \text{ psf}$$

As indicated on page C29.13 of the original calculation, the area of steel (A_s) provided in the slab is equal to 1.87sq.in/ft(#11 bars @ 10" spacing). In addition, "d" in the original calculation is given as 21.9".

Using the slab design, determine the maximum allowable distributed loading:

For $A_s = 1.87 \text{ sq.in.}$, $d = 21.9"$, and $b = 12"$ (one foot sect. of slab)

From Ref. #3, "Flexure 1.1", page 105:


$$p = \frac{A_s}{bd} = \frac{1.87}{(12 \times 21.9)} = 0.0071$$

$$F = \frac{bd^2}{12000} = \frac{12(21.9)^2}{12000} = 0.48$$

using $f'_c = 3000 \text{ psi}$ and $f_y = 40,000 \text{ psi}$:

$K_u = 240$ by interpolation from Flex. 1.1
(K_u is the strength coefficient of resistance)

$$M_u = F K_u = 0.48 (240) = 115 \text{ KFT}$$



Therefore, the maximum moment capacity of the slab is 115 KFT.

From this capacity, we determine the maximum allowable distributed load on the slab;

From the original calc., page C29.13:

$$W_u = \frac{M_u \times 10}{L^2} = \frac{115 \times 10 \times 1000}{32^2} = 1123 \text{ psf}$$

Therefore, comparing the max. allowable dist. load to the actually applied loading, we can determine the reserve capacity of the slab as being:

$$W_u \text{ margin} = W_u \text{ capacity} - W_u \text{ applied} = 1123 \text{ psf} - 1031 \text{ psf} = 92 \text{ psf}$$

Determine the max. allowable head of water based upon the margin of dist. load remaining in the slab:

Since the head of water will act as a dead load and as a live load during a seismic event, the dist. load margin will be divided by the combined unit loading of the two cases to determine the permissible head of water:

$$\text{Allow. Head} = \frac{W_u \text{ margin}}{(\text{water den})1.4 + (\text{water den})(g_v)1.9}$$

(Density of water = 62.4 lb/ft³)



CALCULATION WORK SHEET

9. CALCULATION NUMBER		REV
C29.	0.1	- 3B
JEN NO.		
PAGE 8	OF	9

$$\text{Allow. Head} = \frac{92 \text{ psf}}{(62.4)1.4 + (62.4)(0.164)1.9} = 0.86 \text{ ft.}$$

The allowable head of ponded rainwater that can be distributed over the roof slab at elevation 126'-0" is 0.86 ft.

Reviewing the designed configuration of the roof structure at elevation 126', as shown on page 5 of this calculation, it can be seen that the slab is sloped from East to West with a difference in elevation of 7 inches. In addition, it can be seen that the slab itself is divided into three (3) cubicles with a passageway opening connecting each cubicle. It can be seen that the center and South bays represent the worse case locations for the ponding of rainwater, which, due to the slope of the slab, the existence of passageways and the opening to an unrestricted roof on the North end of elev. 126', the maximum ponding that can occur is a depth of 7 inches.

Therefore, since the maximum permissible depth of water on the slab is 10 inches based upon a distributed loading and the maximum possible depth of ponded rainwater that the slab can contain on one end is 7 inches, the roof slab at elevation 126'-0" of the Diesel Generator Building is structurally adequate to support ponded rainwater.

REF	PAGE
-----	------

4

12/27/04



RIVER BEND STATION
GULF STATES UTILITIES COMPANY

DESIGN DOCUMENT
NO. *Calculation*

C29.0.1-3B
Page 9 of 9

DESIGN REVIEW CHECKLIST (REF. EDP-AA-58)

	YES	NO	N/A
1. Were the inputs correctly selected and incorporated into the design?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Are the assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Are the appropriate quality and quality assurance requirements specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4. Are the applicable codes, standards, and regulatory requirements, including issue and addenda, properly identified and are their requirements for design met?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Have applicable construction and operating experience been considered?.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Have the design interface requirements been satisfied?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7. Was an appropriate design method used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Is the output reasonable compared to inputs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Are the specified parts, equipment, and processes suitable for the required application?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
10. Are the specified materials compatible with each other and with the design environmental conditions to which the material will be exposed?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
11. Have adequate maintenance features and requirements been specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
12. Are accessibility and other design provisions adequate for the performance of needed maintenance and repair?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
13. Has adequate accessibility been provided to perform the in-service inspection expected to be performed during the plant life?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14. Has the design properly considered radiation exposure to the public and to plant personnel?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
17. Are adequate handling, storage, cleaning and shipping requirements specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
18. Are adequate identification requirements specified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. Are requirements for record preparation, review, approval, retention, etc. adequately specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20. Have environmental, safety, and seismic adequacy been considered?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. Have recommended spare parts been specified?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
22. Have fire hazard analysis impacts been considered?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Verifier's Summary:

DESIGN VERIFIED

Timothy Brown 6/27/89
Verifying Engineer Date

A 5010 (4) (FRONT)				CLIENT & PROJECT GULF STATES UTILITIES CO. RIVER BEND		PAGE 1 OF 101 ENCL. ATTACH. C29.0.1		
CALCULATION TITLE (Indicative of the Objective): DIESEL GENR BLDG SLAB DESIGN						QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER		
CALCULATION IDENTIFICATION NUMBER								
J. O. OR W. O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.				
12210	STRUCTURAL ENGG / DESIGN	C29.0.1	N/A	N/A				
* APPROVALS - SIGNATURE & DATE						REV. NO. OR NEW CALC NO	SUPERSEDES * CALC NO OR REV NO	CONFIRMATION * REQUIRED (✓) YES NO
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)						
S. V. MODI 7-18-80	K. B. Shah / 3-19-80	K. B. Shah / 3-19-80	1	0			✓	
K. B. Shah / 3-14-81	M. Ahmed / 3-27-81	M. Ahmed / 3-27-81	1	0			✓	
G. C. Shah / 7-4-81	K. B. Shah / 9-15-81	K. B. Shah / 9-15-81	1	0			✓	
K. B. Shah / 5-8-82	G. C. Shah / 5-10-82	G. C. Shah / 5-10-82	2	1			✓	
* G. C. Shah / 5-7-82	K. B. Shah / 5-8-82	K. B. Shah / 5-2-82						
* FOR LIST OF ATTACH & ATTACH #10 ONLY								
K. B. Shah / 4-10-85	M. Ahmed / 4-11-85	M. Ahmed / 4-11-85	3	2			✓	
RECEIVED JUN 10 1989 SDC								
NOTE: FOR REV. 0 PER / REV 1 / 2ND REV SEE P. C29.2.2 REV 2 FOR REV 1 " " " " " " P. C29.2.3 REV 2								
DISTRIBUTION *								
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)			
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	D. MARTIN - 4P	✓						
FOR INFORMATION DESIGN ENGINEERING CONTROL COPY SDC								

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O. / S.O. / CALCULATION NO.

12210

REVISION

3

PAGE

C29.0.2

6501081

PREPARED / DATE

K. B. Slab / 3-13-81

REVIEWER / CHECKER / DATE

MOLANOS 3-27-81

INDEPENDENT REVIEWER / DATE

MOLANOS 3-27-81

SUBJECT / TITLE DIESEL GENR BLDG
SLAB DESIGN

QA CATEGORY / CODE CLASS
I

TABLE OF CONTENTS AND HISTORICAL DATA

TABLE OF CONTENTS

PAGE NOS	DESCRIPTION	REVISION		REMARKS
		NO	DATE	
C29.01	TITLE PAGE			
C29.02 C29.03, C29.0.4, C29.0.5	} TABLE OF CONTENTS & HISTORICAL DATA "			
C29.1		CALCULATION SUMMARY		
C29.2	DESIGN CHECKLIST			
	<u>BODY OF CALCULATIONS</u>			
C29.3 - C29.8	SLAB DESIGN EL 137'-0			
C29.9 - C29.15	SLAB DESIGN EL 126'-0			
C29.16 - C29.20	SLAB DESIGN EL 110'-0			
C29.21 - C29.80	SLAB DESIGN EL 98'-0			
-	LIST OF ATTACHMENT,			

NOTE: WORK THIS SHEET WITH HISTORICAL DATA SHEETS & VOID PAGES (ATTACHMENT #10)

FOR INFORMATION ONLY

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O. / W.O. / CALCULATION NO. **12210** REVISION **1** PAGE **C29.03**

PREPARED / DATE: **C.C. Shah 9-4-81**
 REVISOR / CHECKER / DATE: **K. B. Shah / 9-15-81**
 INDEPENDENT REVISOR / DATE: **K. B. Shah**
 SUBJECT / TITLE: **DIESEL GENF. BUILDING. SLAB DESIGN.**
 QA CATEGORY / CODE CLASS: **I**

TABLE OF CONTENTS AND HISTORICAL DATA

HISTORICAL DATA

PAGE NOS.	DESCRIPTION	REVISION		REMARKS
		NO.	DATE	
C29.01	TITLE PAGE	1	3-27-81	ADDED AS REQ'D BY EAP 5.3 REV. 3, STP 11.5.0
C29.02	TABLE OF CONTENTS AND HISTORICAL DATA	1	3-27-81	
C29.03	"	1	9-4-81	
C29.01	CALCULATION SUMMARY	1	9-2-81	ADDED CALC. W. REF.
C29.21	SEISMIC LOAD	1	3-6-81	PAGE ADDED TO CHECK REVISED ϕ VALUES.
C29.3, C29.8, C29.8.1, 49.8.2, C29.8.3	ROOF AT EL. 141'-0"	1	3-6-81	ADDED REVISED FOR MISSILE PROTECTION. SUPPLEMENTED C29.3, 4, C29.8.2 REV. 10. PAGES ADDED. RT-F FOR SILENCE. MISSILE PROTECT
C29.9	SLAB DESIGN AT EL. 141'-0"	1	3-6-81	ADDED NOTES. REVISED WALL LAYOUT.
C29.24	SLAB DESIGN AT EL. 126'-0"	1	5-6-81	ADDED ATTACHMENT NOTE REF
C29.44	" " " "	1	9-2-81	" "
C29.55	" " " "	1	9-3-81	" "
C29.55	SKETCH REIN. AT EL. 96'-0"	1	11-2-79	ADDED. TO SHOW REIN. ARRANGEMENT.
C29.81, 82	SLAB @ EL. 98'-0" ELECT. DUCT.	1	12-21-79	ADDED. CHECK FOR BLEED. DUCT. SEC'D W/ 12" DIA. EE 37A
C29.83 TO C29.86	SLAB @ EL. 98'-0" AT DE LINE	1	3-19-80	ADDED. ADDITIONAL CHECK FOR WALL LOAD
C29.87 TO C29.89	SLAB @ EL. 98'-0" & EL. 126'-0". ADDITIONAL WALL LOAD	1	3-19-80	" " "
-	LIST OF ATTACHMENT. INCL. W. 1, F. 10	1	9-4-81	ADDED AS REQ'D BY EAP 5.3, REV. 3; STP 11.5.0

FOR INFORMATION ONLY

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.B. / C.S. / E.S. / C.W. / J.O.B. NO.

12210

REVISION

2

PLANT

C29.0.4

PREPARED / DATE

K. B. CAM / 5-2-82

REVISOR / CHECKED / DATE

G. C. Shah / 5-10-82

INTERPRETER / REVISOR / DATE

G. C. Shah / 5-10-82

SUBJECT / TITLE

DIESEL GENR BLDG. - SLAB DESIGN

QA CATEGORY / CODE CLASS

I

TABLE OF CONTENTS AND HISTORICAL DATA

HISTORICAL DATA

PAGE NOS.	DESCRIPTION	REVISION		REMARKS
		NO.	DATE	
C29.0.2	TABLE OF CONTENTS	2	5-10-82	ADMINISTRATIVE CHANGE
C29.0.4	HISTORICAL DATA	2	5-10-82	ADMIN. CHANGE - PAGE ADDED
C29.2.1	SEISMIC LOADS	2	5-7-82	SUPERSEDES P. C29.2.1 REV 1 REVISED SEISMIC LOADS
C29.2.2, 2.3	PREP/REV/INA REVIR BREAKDOWN FOR REV 0 & 1	2	5/10/82	ADMIN CHANGES. PAGE ADDED
-	LIST OF ATTACHMENTS	2	5-10-82	ADMIN. CHANGES
-	LIST OF VOID PAGES (ATTACHMENT #15)	2	5-10-82	ADMIN. CHANGES

FOR INFORMATION ONLY

081001

12210

REVISION 3

PAGE
CA9.0.9

PREPARED BY

K. A. Spak / 4-10-85

REVISOR / CHECKER / DATE

M. Ahmed / 4-11-85

INDEPENDENT REVIEWER / DATE

M. Ahmed / 4-11-85

SUBJECT / TITLE

DIESEL GENERATOR ALDG
SLAB DESIGN

QA CATEGORY / CODE CLASS

I

HISTORICAL DATA - REVISION 

REASON FOR CHANGE AND SOURCE OF INFORMATION:

- ① ADMINISTRATIVE CHANGES
- ② CALC UPDATE
- ③ REVISED FLOOR LAYOUT

PAGE	DESCRIPTION
CA9.0.2	TABLE OF CONTENT PAGE REVISED ①
CA9.0.5	HISTORICAL DATA PAGE ADDED ②
CA9.9-13	SLAB DESIGN EL 126'-0" - SUPERSEDES By CA9.9-13 REV 0/1 ②
CA9.20.1	SLAB EL 97'-6" PAGE ADDED ②
CA9.55.1	SLAB EL 97'-6" PAGE ADDED ③
-	LIST OF ATTACHMENT - REVISED ①
-	VOID PAGES ATTACHMENT #13 - REVISED ①
-	ADDED ATTACHMENT #2 (COMPUTER RUN)
CA9.1	COMPUTER RUN NOTE ADDED

FOR INFORMATION ONLY

GULF STATES UTILITIES CO

1 Client RIVER BEND Location W. FELICIANA, LA Est. No. 1221

2 Subject DIESEL GEN. BLDG. Date 3-22-77 By K.R.Sh.

3 SLAB DESIGN Checked 3-24-77 By K.R.Sh.

4 Based on Revised 9-2-81 By B.L.L.

5 CH'D: M. Ahmed / 4-11-85 CH'D: 9-8-81 BY K.R.Sh.

RIVER BEND STATION UNIT-1
DIESEL GENERATOR BLDG. - SLAB DESIGN

PURPOSE: TO DESIGN FLOOR SLABS FOR GIVEN LOADS AND
DETERMINE REBAR SIZE & SPACING

REFERENCE: REFER SMT C29.E CALC. C29A, REV. 1 ADD

CONCLUSION: REINFORCEMENT SIZE & SPACING AS CALLED OUT

ON SMT C29.03, C29.09, C29.16, C29.55, C29.78, C29.7
C29.8.8, 8.9, 9, 55.81, 85 ADD

B.A. CAT: I

CALCULATION STATUS:

PRELIMINARY: _____

FINAL: ✓

SUPERSEDED BY: _____

CODE CLASS: N/A

ADD
FOR SLAB EL. 2ND COMPUTER RUN (ATTN)
3D-STRUDL 3D PLANE FRAME GEN. LIA.
REF ST-DIG RUN DT. 6-9-77 VER/REV 09/0.
PROGRAM BENCHMARKING COMPLETED BY
SDM (SMC) - 84/8 CASE 8A2. REF # 26

SOURCE OF DATA:

1. STRUCTURAL DESIGN CRITERIA FOR RIVER BEND NUCLEAR STATION UNIT #1 & #2
2. SEISMIC ANALYSIS OF DIESEL GENERATOR BLDG FROM ENGG MECHANICS CAL. BOOK # 030
3. MACHINE LOCATION STANDBY DIESEL GEN. BLDG DWG. 12210-EM-13A

FOR INFORMATION ONLY

12210

229.9

4501081

PREPARED / DATE

K. B. Shah / 1-18-85

REVIEWER / CHECKER / DATE

M. Ahmad / 1-21-85

INDEPENDENT REVIEWER / DATE


M. Ahmad / 1-21-85

SUBJECT / TITLE

DIESEL GENERATOR BLDG
FLOOR SLAB DESIGN EL 126'-0"

QA CATEGORY / CODE CLASS

I



CALCULATION SHEET

STORE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

REVISION 5

PAGE

12210

289-10

ASD 1081

PREPARED BY/DATE

K. B. Shah / 1-18-85

REVIEWER/CHECKER/DATE

M. Ahmed / 1-21-85

INDEPENDENT REVIEWER/DATE

M. Ahmed / 1-21-85

SUBJECT/TITLE

DIESEL GENERATOR BLDG
FLOOR SLAB DESIGN EL 126'-0

QA CATEGORY/CODE CLASS

I

SLAB S1

SPAN C/C = 13'-0

LOADS: DL: 2'-3" THICKNESS WILL BE CONSIDERED FOR DESIGN
= 338 PSF

ROOFING = $\frac{8}{346}$ " (STRUCT DES. CRITERIA REV 8, 2-10
346 "

ROOF LL = 30 PSF (" " " " , 5.6.2)
NO EQUIPMENTS IN THIS AREA

SEISMIC VERT OBE 'g' = 0.164 (Pg C29.2-1 REV 2)

WALL LOADS: FROM ROOF SLAB EL 137'-1 1/2 (REF DWG EC-296E, J)

$$= \left(\frac{6}{2} + 2 + \frac{5.25}{2} \right) 350 \text{ PSF} = 2669 \text{ PLF ON WALL}$$

SELF WT FROM EL 126'-0 TO EL 135'-0 = 9' x 12' x 150 = 2700 PLF

$$\text{TOTAL} = 2669 + 2700 = 5369 \text{ PLF}$$

SEE PG C29-11 REV 3

$$U = 1.4D + 1.7L + 1.9 \text{ OBE} + 1.3T_o$$

VERT 'g' REF # 11

$$= 1.4 \times 346 + 1.7 \times 30 + (1.9 \times 0.164) (346 + 30) = 653 \text{ PSF}$$

WALL LOAD U = 1.4 x 5369 + 1.9 x 0.164 x 5369 = 9190 PLF FOR 1'-0 SLAB WIDTH

= 4595 PLF USE 5000 PLF/FT WIDTH

$$R_L = 0.653 \times \frac{13}{2} + (5.0 \times 30) 10/13 = 27.3 \text{ K}$$

$$R_R = 0.653 \times \frac{13}{2} + (5.0 \times 6) 3/13 = 11.2 \text{ K}$$


$$\text{ZERO SHEAR FROM LEFT} = \frac{37.3}{(5.0 + 0.653)} = 4.8'$$

$$M_U = 27.3 \times 4.8 - 5.653 (4.8)^2 / 2 = 66.0 \text{ K-FT}$$


$$f'_c = 3 \text{ ksi} \quad d = 24" - 3" \text{ OVER} - 1.41 (11) - \frac{1.41}{2}$$

$$= 24 - 4.1 = 19.9"$$

$$F = \frac{bd^2}{12000} = \frac{12 \times 19.9^2}{12000} = 0.395$$



FOR INFORMATION ONLY



CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O. / W.O. / CALCULATION NO.

12210

REVISION 3

PAGE

C29-11

AS010.01

PREPARED / DATE
K. R. Shah / 1-18-85

REVIEWED / CHECKED / DATE
M. Ahmed / 1-21-85

INDEPENDENT REVIEWER / DATE
M. Ahmed / 1-21-85

SUBJECT / TITLE
DIESEL GENERATOR BLDG
FLOOR RAB DESIGN EL 126'-0

QA CATEGORY / CODE CLASS
I

SLAB S1 (cont)

$$K_u = \frac{M_u}{F} = \frac{66}{.395} = 167 \quad \alpha_u = 2.88$$

$$R_s = \frac{M_u}{\alpha_u d} = \frac{66}{2.88 \times 19.9} = 1.15 \text{ } 10^3 / \text{LF}$$

TEMP EFFECT (REF: AIA 3-5 STR DESIGN CRITERIA REV 3)

$$A_s = A_s' = 11 \text{ } \emptyset 10'' = 1.87 \text{ } in^2$$

$$\rho = \rho' = \frac{A_s}{bH} = \frac{1.87}{12 \times 24} = 0.0065$$

$$H = 24''$$


$$K_1 H = 19.9 \quad K_1 = 0.83$$

$$K_2 H = 19.9 - 4.1 = 15.8'' \quad K_2 = 0.66$$

$$\alpha = 5.5 \times 10^{-6} \quad \Delta_T = 50^\circ \text{ FOR ROOF}$$

$$E_s = 29,000,000 \text{ } psi \quad E_c = 57,000 \sqrt{f_c} = 57,000 \sqrt{3,000} = 3,122,000 \text{ } psi \quad n = \frac{E_s}{E_c} = 9.29$$

$$\gamma = \text{POISSON'S RATIO} = 0.15 \quad \rho + 2\rho' = 0.0195$$



$$m = -n(\rho + 2\rho') \pm \sqrt{n^2(\rho + 2\rho')^2 + 2n[2\rho'(K_1 - K_2) + K_1\rho]}$$

$$= -9.29(0.0195) \pm \sqrt{(9.29)^2(0.0195)^2 + (2 \times 9.29)[2 \times 0.0065(0.83 - 0.66) + 0.83 \times 0.0065]}$$

$$= -0.1812 \pm \sqrt{0.328 + 0.1418}$$

$$= -0.1812 \pm 0.4173 = 0.2361$$

$$M_e' = \frac{\alpha N^2 H^2 \Delta_T E_c}{2} \left[\left(K_1 - \frac{N}{3} \right) + \frac{4n(N - K_1 + K_2) \rho' K_2}{N^2} \right]$$

$$= \frac{5.5 \times 10^{-6} (0.2361)^2 (24)^2 50 \times (3.122 \times 10^6)}{2} \left[\left(0.83 - \frac{2361}{3} \right) + \frac{(4 \times 9.29)(0.2361 - 0.83 + 0.66) \cdot 0.0065 \times 0.66}{(0.2361)^2} \right]$$

$$= 13,783 [0.7513 + 0.1890] = 12,960 \text{ } Lbin/in = 12,960 \text{ } Lbft/ft$$

$$M_t = \frac{M_e'}{1 - \gamma} = \frac{12,960}{1 - 0.15} = 15.25 \text{ } Kft/ft$$

$$M_u = 1.3 M_t = 1.3 \times 15.25 = 19.8 \text{ } Kft/ft$$

FOR INFORMATION ONLY

12210

4801081

PREPARED / DATE K. E. Shah / 1-21-85	REVIEWER / CHECKED / DATE M. Ahmad / 1-21-85	INDEPENDENT REVIEWER / DATE M. Ahmad / 1-21-85
SUBJECT / TITLE DIESEL GENERATOR BLDG FLOOR SLAB DESIGN SL 12210		QA CATEGORY / CODE CLASS I

SLAB S1 (cont)

TEMP EFFECT (cont)

$$A_s = \frac{M_u}{\phi f_y} = \frac{19.8}{2.08 \times 19.7} = 0.35 \text{ in}^2/\text{LF}$$

TOTAL A_s REQ'D = 1.15 + 0.35 = 1.50 in²/LF < A_s PROVIDED #11 @ 10" = 1.87 in²/LF

1.85 in²/LF REQ'D FOR MISSILE PROTECTION = 1.85 in²/LF BW, EF
(PARA 2-10 STRUCT DESIGN CRIT. REV 3)

SLAB S2

LOADS: DL SLAB THICKNESS AT LOW POINT = 2'-2" + 3" DECKING
LOAD = 345 PCF

(DL AT HPT WILL BE GREATER, SO WOULD THICKNESS WHICH TEND TO REDUCE REINF)

ROOFING = 8 PCF (PARA 2-10, STR CRITERIA REV 3)

$$\text{TOTAL DL} = 345 + \overset{\text{DECK}}{8} + 7 + 12 = 372 \text{ PCF}$$

2 STEEL FANG


LL: ROOF LL = 30 PCF HOWEVER THIS AREA HAS EXHAUST SILENCER
(EQUIP I.D. 56W NO. 244-700-041-033E)
1 HVP-SIL 1A

EQUIPMENT LOAD WT = 15,635 #

FOR MIDDLE SUPPORT
ASSUME 50% WT
DISTRIBUTED ON (7'-6" + 3'-6") x (2'-0" + 3'-6")

$$= \frac{0.5 \times 15635}{11.0 \times 5.5} = 130 \text{ PCF}$$

FOR SIMPLICITY OF DESIGN
USE LL = 100 PCF ON ENTIRE
AREA WHICH IS CONSERVATIVE.



SILENCER SUPPORTS (REF: DWG EC-276)

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

S.O./W.O./CALCULATION NO.

REVISION 3

PAGE

029.13

12210

ASD1081

PREPARED/DATE

K. B. Shah / 1-21-85

REVIEWER/CHECKER/DATE

M. Ahmed / 1-21-85

INDEPENDENT REVIEWER/DATE

M. Ahmed / 1-21-85

SUBJECT/TITLE DIESEL GENERATOR BLDG

FLOOR SLAB DESIGN EL 126'-0

QA CATEGORY/CODE CLASS

I

5 SLAB S2 (CONT)

f TO BE ADDED SEPARATELY

$$U = 1.4D + 1.7L + 1.9OE + 1.3T_o$$

$$= 1.4 \times 372 + 1.7 \times 100 + 1.9 \times 164 (372 + 100)$$

VERT 3 VALUE = 0.164

(Pg 029.2.1 REV 2)

$$= 858 \text{ PLF}$$

$$M_u = \frac{w_u l^2}{10} = \frac{858 \times 32^2}{10} = 8.6 \text{ KFT}$$

$$A_s \text{ REQ'D} = \frac{M_u}{a_u d}$$

$$= \frac{86}{2.85 \times 21.9}$$


$$= 1.38 \text{ in}^2/\text{LF}$$

SEE S1

$$d = 26'' - 4.1$$

$$= 21.9''$$

$$a_u \approx 2.85$$



$$\text{DUE } T_o = 0.35 \text{ (Pg 029.13 REV 3)}$$

$$1.73 \text{ in}^2 < A_s \text{ PROVIDED } \#11 @ 10'' = 1.89 \text{ in}^2 \text{ (DWG EC-29 H)}$$

MINIMUM REQ'D FOR MISSILE PROTECTION = 1.85 in² EW, LF
(PARA 3.10 STR CRITERIA REV 3)

FOR INFORMATION ONLY

The live load used for design shall be shown on each concrete and steel floor plan.	4.7
All grating and checkered plate platforms shall be designed for live loads of 100 psf unless otherwise specified.	4.9
Stairs, stair landings, and elevator machine rooms shall be designed for 100 psf live loads unless otherwise specified.	4.10
	4.11
	4.12
The roof live load shall be 30 psf applied normal to the roof surface and shall not be combined with wind uplift to reduce net uplift.	4.14
	4.15
<u>3.5 Thermal Loads</u>	4.18
<u>Operating Condition: To</u>	4.20
Unless otherwise stated, all structural components shall be designed to withstand the following differential temperatures between the two faces (except for structural steel).	4.22
	4.24
	4.25
Structural Steel - 20°F	4.28
Exterior Concrete Walls and Roof - 50°F	4.29
Interior Concrete Walls, Foundation and Floor Slab, and Exterior Concrete Walls Below Grade - 20°F	4.30
	4.31
	4.32
Where compressible material is used in shake space, design differential temperature can be reduced to 20°F.	4.36
Simplified cracked section analysis, as shown in Attachment 3.5.1, can be used to determine the effect of temperature stresses in designing the structures. This method of analysis shall not be used while designing water-retaining structures under constant hydrostatic pressure head.	4.39
	4.40
	4.41
	4.42
Some specific areas with high temperatures are listed in Section 5 under each individual structure. For details of design ambient temperatures for all areas of various buildings, see Document No. 215.150, Environmental Design Criteria for RB Station.	4.46
	4.48
	4.49
<u>High Energy Pipe Break Accident Condition: Ta</u>	4.52
Loads due to the temperature gradient through the concrete or steel element associated with the corresponding high energy pipe break shall be listed for each individual element (or structure) in Section 5, as they become available.	4.54
	4.57
	4.58

<u>Normal Operating Conditions</u>	5.24
1. $U = 1.4D + 1.7(L + F + H + Pv + SRV_1) + 1.3(To + Ro)$	5.26
<u>Severe Environmental Condition</u>	5.28
2. $U = 1.4D + 1.7(L + F + H + Pv + W + SRV_1) + 1.3(To + Ro)$	5.30
2.1 $U = 1.2D + 1.7W$	5.32
3. $U = 1.4D + 1.7(L + F + H + Pv + SRV_1) + 1.3(To + Ro)$ + 1.9Feqs/2	5.34 5.35
3.1 $U = 1.2D + 1.9 Feqs/2$	5.37
4. $U = 0.9D + 1.4F + 1.7H + 1.3W$	5.39
5. $U = 0.9D + 1.4F + 1.7H + 1.45 Feqs/2$	5.41
NOTE: Equations 4 and 5 are primarily to check against overturning.	5.43 5.44
<u>Extreme Environmental Condition:</u>	5.47
6. $U = 1.0(D + L + To + F + Pv + H + Ro + Wt + SRV_1)$	5.49
7. $U = 1.0(D + L + To + F + Pv + H + Ro + Feqs + SRV_1)$	5.51
8. $U = 1.0(D + L + To + Pv + H + Ro + F' + SRV_1)$	5.53
<u>Abnormal/Severe Environmental Condition:</u>	5.56
9. $U = 1.0(D + L + F + H + Ta_1 + Ra + Rm + Rj + Rr$ + $SRV_2 + LOCA) + 1.25 (Pa_1 + Feqs/2)$	5.58 6.1
9.1 $U = 1.0(D + L + F + H + Ta_2 + Ra + Rm + Rj + Rr$ + $SRV_3 + LOCA) + 1.25 (Pa_2 + Feqs/2)$	6.2 6.3
<u>Abnormal/Extreme Environmental Condition:</u>	6.7
10. $U = 1.0(D + L + F + H + Pa_1 + Ta_1 + Ra + Rm + Rj$ + $Rr + Feqs + LOCA + SRV_2)$	6.9 6.10
10.1 $U = 1.0(D + L + F + H + Pa_2 + Ta_2 + Ra + Rm + Rj$ + $Rr + Feqs + LOCA + SRV_3)$	6.11 6.12
<u>Abnormal Loading Condition</u>	6.16
11. $U = 1.0(D + L + F + H + Ta_1 + Ra) + 1.25 SRV_2$ + 1.5 (Pa ₁ + LOCA)	6.18 6.19
11.1 $U = 1.0(D + L + F + H + Ta_2 + Ra) + 1.25 SRV_3$ + 1.5 (Pa ₂ + LOCA)	6.20 6.21
NOTES: 1. Loads resulting from thermal stratifi-	6.24

2. <u>MATERIALS</u>	1.8
2.1 <u>Concrete</u>	1.12
Structural concrete shall have 28-day specified compressive strength of 3,000 psi, unless otherwise specified in Section 5. If higher strength concrete is required for a particular design requirement, discuss the situation with the Lead Structural Engineer.	1.15 1.17 1.18
Working mat concrete shall have a 28-day specified compressive strength of 2,000 psi.	1.20 1.21
Lightweight concrete shall not be used on this project.	1.23
2.2 <u>Reinforcing Steel</u>	1.26
Reinforcing steel bars No. 3 through No. 11 shall be Grade 40 conforming to the Specifications for Deformed Billet Steel Bars for Concrete Reinforcement, ASTM A615, Supplement S-1. All reinforcing steel bars No. 14 and No. 18 shall be special chemistry steel with a minimum yield stress of 50,000 psi and 60,000 psi (for reactor building only) conforming to the specifications for Deformed Billet Steel Bars for Concrete Reinforcement ASTM A615, Supplement S-1.	1.28 1.30 1.31 1.32 1.34
Reinforcing steel bars No. 14 and No. 18 shall be spliced using Cadweld T-Series full-tension reinforcing steel splice sleeves. Rebar to plate splices shall be made using Cadweld B-Series splice sleeves.	1.36 1.37 1.38
2.3 <u>Structural Steel</u>	1.41
Structural steel shall be ASTM A36 unless otherwise specifically specified in Section 5 of the criteria. If a higher strength steel is required for a specific design requirement, discuss the situation with the Lead Structural Engineer. Structural steel outside the containment is galvanized while reactor building steel within the containment is shop primed.	1.43 1.46 1.47 1.48 1.49
2.4 <u>Structural Connections</u>	1.52
The structural members shall be field bolted with ASTM A325 high strength bolts with friction type connections. Bearing-type connections may be used when the connection is not subject to stress reversal. If higher strength bolts are required for a specific design requirement, ASTM A490 could be used after discussion with the Lead Structural Engineer.	1.54 1.55 1.57 1.58 2.1

**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS

04

APERTURE CARD/HARD COPY AVAILABLE FROM

RECORDS AND REPORTS MANAGEMENT BRANCH