

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077-0004

JOHN D. SIEBER  
Vice President - Nuclear Group

(412) 393-5255

January 11, 1990

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Application for Exemption from GDC-57

Gentlemen:

Duquesne Light Company hereby requests an exemption from General Design Criterion (GDC) 57 requirement for an automatic, or locked closed, or remote manual containment isolation valve in the recirculation spray heat exchanger river water radiation monitor sample lines. (Reference UFSAR Figure 9.9-1A, penetrations 83, 84, 85 and 86).

The existing plant configuration presents no adverse effects as a result of postulated accidents since flow of contaminated fluid through the sample line would require that a passive failure be assumed (recirculation spray heat exchanger tube leak) in the short term following the initiating accident. Assumption of this type is not within the BVPS-1 licensing basis for a passive failure in addition to design bases events.

A postulated tube failure presents no adverse effects in the long term since existing operating procedures contain provisions for shutdown of the recirculation spray pump to stop any releases. This removes the driving force for the tube leak since the containment is subatmospheric and provides time for operators to complete manual isolation of the sample line as well.

Based on the above, continued operation of the plant with the existing configuration will not present an undue risk to the public health and safety.

Special circumstances are present in that application of GDC-57 in this particular case is not necessary to achieve the underlying purpose of the rule.


9001240094 900111  
PDR ADOCK 05000334  
P PDC

Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Page 2

The attachment represents our justification for continued operation during the interim period while the exemption request is being evaluated.

Please contact my office if additional information is required.

Very truly yours,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. W. T. Russell, NRC Region I Administrator  
Mr. P. Tam, Sr. Project Manager  
Mr. R. Saunders (VEPCO)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 2, 1980

Docket No. 50-334

LICENSEE: Duquesne Light Company

SUBJECT: MEETING SUMMARY - ECCS DECAY HEAT EXCHANGER INTEGRITY FOR  
BEAVER VALLEY UNIT NO. 1

On April 22, 1980, the licensee and Stone and Webster met with the Staff to discuss the consequences of failure and methods to assure integrity of the recirculation spray heat exchanger system for the Beaver Valley Unit No. 1. The list of attendees is attached (Attachment 1).

The licensee had previously met with the Staff on March 25, 1980. The details of that meeting and background information are included in the meeting summary dated April 7, 1980. This meeting was held to discuss the consequences of failure of the heat exchanger and components and methods to mitigate unacceptable consequences.

Discussion

The consequence analysis performed by Stone and Webster assumed the TID 14844 source term in the reactor containment sump and with the releases held to the 10 CFR 20 limits, the recirculation heat exchanger leak rate can be no more than  $2 \times 10^{-4}$  gpm from the 3400 tubes in the four heat exchangers. Assuming a dilution factor of 10 in the river, the doses in the drinking water at the Midland water intake would be as follows for one liter of water consumed:

Adult Thyroid Dose	190 mrem
Child Thyroid Dose	583 mrem
Infant Thyroid Dose	1400 mrem

The potential air borne dose would be less than  $10^{-2}$  mrem/hr at the site boundary when 2% evaporation rate is assumed in the cooling tower. It is not clear that this accounts for potential iodine releases from the water as the sump leakage pH drops from 8 in the sump to 7 in the cooling tower. The significance of the dose calculations is that almost any leakage in the heat exchanger would produce unacceptable results. The  $2 \times 10^{-4}$  gpm leakage is for less than one tube breaking out of the 3400; it is something just larger than a pin hole leak in a single ube.

The licensee provided a basic information sheet on the recirculation heat exchangers which is attached (Attachment 2). Stone and Webster investigated the design for vibration damage between the tubes and tubes/baffle plates. Little potential exists for damage of this type. The tubes are rolled into a double groove in the tubesheets and seal welded so that a high initial integrity can be assumed. The tubes, baffles, and tubesheets are all 304L stainless steel and operate in an environment which is not expected to produce stress corrosion cracking or other modes of failure. While it is not apparent that the heat exchanger will deteriorate and fail, there is no assurance against tube degradation and eventual failure over the 30-40 year life of the plant.

The licensee had hydrotested the heat exchanger during construction and due to the containment isolation configuration, they had also performed a type C leak test on the tube side. No failures had been detected by these means. To provide further assurance of integrity, the licensee performed a freon test on the tube side. Water was drained from both the tube and shell side and about 10 to 20 lbs of freon at 70 psig was applied to the tubes. The test was allowed to "soak" for a period of time to allow any freon leak to accumulate on the shell side. A portable detection instrument with a sensitivity of  $1 \times 10^{-7}$  freon/cc of air did not detect any leakage from the four heat exchangers.

The radiation monitors on the discharge river water side are set for a sensitivity of  $10^{-6}$   $\mu$  ci/cc with a background of 5 mrem/hr. The licensee did not quantify the expected radiation levels in the area of the monitors following an accident although the largest source of radiation is expected to be from the sample line from the failed heat exchanger (assuming an accident and a leaking recirculation spray heat exchanger). The radiation monitors are seismic Class I designed to the 1968 ASME Code. The Hi-Hi alarm setpoint is equivalent to  $2.2 \times 10^5$  cpm which also corresponds to 10 CFR 20 limits. The monitor pumps, flow indicators and radiation detector/circuitry are tested and calibrated periodically.

The river water piping, the bellows expansion joints, and pressure relief valves were not tested during the freon tests by the licensee. The river water piping is carbon steel. A carbon steel to stainless steel transition joint is employed outside the heat exchanger on the inlet and outlet lines. Following a LOCA, it is not clear how a leak in the river pipes or bellows expansion joint inside containment would be detected and boron dilution of the sump prevented. The pressure relief valve outside containment on the river water discharge will relieve to the auxiliary building sump. Water discharge will be detected by the sump pump operation and by area monitors in the auxiliary building.

#### Conclusions and Positions


The licensee proposed an 18 month freon test of the heat exchangers tube side, as being adequate to detect leakage and assure integrity. While the Staff

believes the freon test to be highly sensitive to leaks and does provide adequate assurance of the existing leak-tightness, it does not provide information on the required integrity for the subsequent periods of operation should the heat exchanger be called upon. The test recently performed by the licensee and the fact that the heat exchangers are relatively young in life led the staff to conclude there is reasonable assurance of continued integrity so that the Beaver Valley Unit No. 1 can be returned to power following the current outage without a tube degradation inspection.

The licensee was instructed to include a freon test at each refueling outage (normal 18 month cycle) to be preceded by a pneumatic or other pressure test along the requirements of Section XI of the ASME Code. This test is expected to produce leaks that are about to occur and then be detected by the freon test. The details of such a test are to be developed by the licensee and included in their Inservice Inspection Program before the second refueling outage.

The test for tube and tubesheet degradation is an open issue. At some point in the heat exchanger life, the licensee must begin to examine for degradation to assure continued integrity should operation ever be required. The licensee was instructed to consider means for testing for heat exchanger degradation including a schedule and basis for beginning such testing. The type of test, basis for acceptance criteria, and schedule for periodic performance of the tests is to be developed by the licensee, submitted to the NRC for review, and subsequently included in the licensee's Inservice Inspection Program.

The Staff did not reach a position on the preferred normal condition of the heat exchanger. The licensee was requested to develop a position and provide a technical basis for draining and drying the heat exchanger to include discussion of concentrating chlorine by drying and creating a water hammer problem by having a river water system charging to an empty heat exchanger.

  
Dave Wigginton, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Attachments:

1. List of Attendees
2. Heat Exchanger Spec Sheet

cc: w/attachments  
See next page

Meeting Summary for  
Beaver Valley 1

- 4 -

Docket Files  
NRC PDR  
Local PDR  
URbl Reading  
NRR Reading  
H. Denton  
E. Case  
D. Eisenhut  
R. Tedesco  
G. Zech  
B. Grimes  
W. Gamill  
L. Shao  
J. Miller  
R. Volimer  
T. J. Carter  
A. Schwencer  
D. Ziemann  
P. Check  
G. Lainas  
D. Crutchfield  
B. Grimes  
T. Ippolito  
R. Reid  
V. Noonan  
G. Knighton  
D. Brinkman  
Project Manager  
OELD  
UI&E (3)  
C. Parrish/P. Kreutzer  
ACRS (16)  
NRC Participants  
NSIC  
TERA  
Licensee  
Short Service List

DECAY HEAT EXCHANGERMEETINGBEAVER VALLEY POWER STATION 1APRIL 22, 1980

<u>Name</u>	<u>Organization</u>
D. Wigginton	NRC
D. Shum	NRC
J. D. Sieber	DLC - Licensing
K. D. Grada	DLC- Operations
P. C. Hearn	NRC
Frank H. Timpano	VEPCO
R. E. Vanasse	Stone and Webster
C. E. Ader	Stone and Webster
R. C. Tappan	Stone and Webster
C. F. Andreone	Stone and Webster
W. C. Drotleff	Stone and Webster
B. Turovlin	NRC
H. F. Conrad	NRC
J. E. Rosenthal	NRC
L. B. Engle	NRC
R. Woods	NRC
C. Y. Cheng	NRC
George Johnson	NRC
K. R. Wichman	NRC
J. Zudans	NRC
Vince Noonan (part time)	NRC



# INDUSTRIAL PROCESS ENGINEERS

ATTACHMENT 2

8 LISTER AVE. NEWARK, N. J.

## HEAT EXCHANGER SPECIFICATION SHEET

Page 1 of 2

Customer Stone & Webster Engineering Corporation		Job No. 6301	
Address Boston, Massachusetts		REFERENCE No J. O. 21-11700	
Plant Location Shippingport, Pennsylvania		PROPOSAL No 18977	
Service of Unit Recirculation Spray Coolers		DATE 5/26/69	
Size 31-144 Type CEN		Item No RS-E-1A, B, C, D	
No Ft SURF/UNIT 5150 SHELLS/UNIT One		CONNECTED IN Parallel	
		So Ft SURF/SHELL 5150	
PERFORMANCE OF ONE UNIT (Four Required)			
		SHELL SIDE	
		TUBE SIDE	
FLUID CIRCULATED	Recirculated Spray Water	Ohio River Water	
TOTAL FLUID ENTERING, #/HR	1750000	2000000	
VAPOR:			
LIQUID:	1750000	2000000	
STEAM:			
NON-CONDENSABLES:			
FLUID VAPORIZED OR CONDENSED:			
STEAM CONDENSED:			
GRAVITY DENSITY #/ft <sup>3</sup>	61.6	62	
VISCOSITY:			
MOLECULAR WEIGHT:			
SPECIFIC HEAT:	1 BTU/LB°F	1 BTU/LB°F	
THERMAL CONDUCTIVITY:	BTU/HR-FT-°F	BTU/HR-FT-°F	
LATENT HEAT:	BTU/LB	BTU/LB	
TEMPERATURE IN:	139 °F	85 °F	
TEMPERATURE OUT:	104 °F	115.6 °F	
OPERATING PRESSURE:	0-100 PSIG	45 Ext (1) 100 INT PSIG	
NO PASSES PER SHELL:	One	One	
VELOCITY:	206 #/Sec ft. 2 Ft/Sec	6.6 Ft/Sec	
PRESSURE DROP Allow/Calc:	10/10 PSI	10/7 PSI	
FOWLING RESISTANCE (MIN):	0.0	0.0	
HEAT EXCHANGED-BTU/HR	61000000	MTD(CORRECTED)-°F 21.2	
TRANSFER RATE-SERVICE:	564	CLEAN 564	
CONSTRUCTION OF ONE SHELL			
DESIGN PRESSURE:	150 PSI	150 INT, 48 EXT PSI	
TEST PRESSURE:	Code	Code PSI	
DESIGN TEMPERATURE:	280 °F	280 °F	
TUBES 304L SS SM1A <sub>0</sub>	850 OD 5/8" BWG 20 Min LENGTH 37'-0" PITCH 7/8" 2R1		
SHELL 304L SS	ID 31" <del>30"</del>	SHELL COVER (INTEG)(REMDY)	
CHANNEL OR PINNET	C.S.	CHANNEL COVER C.S. (2)	
TUBESHEET-STATICARY	304L	TUBESHEET-FLOATING	
BAFFLES-CROSS	304SS 25" spc type dbl seg 25% cut	FLOATING HEAD COVER	
BAFFLES-LONG	TYPE	IMPINGEMENT PROTECTION S.S.	
TUBE SUPPORTS:			
TUBE TO TUBESHEET JOINT:	Expanded and seal welded		
BASKETS:	(2)		
CONNECTIONS-SHELL SIDE:	IN 10" (3)	OUT 12" RATING BW	
CONNECTIONS-CHANNEL SIDE:	IN 14"	OUT (14) RATING BW Sch 40	
CORROSION ALLOWANCE-SHELL SIDE:		TUBE SIDE	
CODE REQUIREMENTS:	ASME III C (4)		TEMA CLASS R
REMARKS:	(1) External Pressure on channels and channel covers under "Accident" conditions.		
	(2) Welded Diaphragm seal		
	(3) 10" x 14" Dome at shell inlet & 12" x 14" @ outlet to avoid excessive velocities		
	(4) 100% Radiographed		





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

13

*RFB - info,*  
*file*  
*S.*

March 12, 1981

Docket No. 50-334

Mr. C. N. Dunn, Vice President  
Operations Division  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Dear Mr. Dunn:

*M.J. Appata to*  
*provide test*  
*procedure*

The NRC staff met with members of your staff and your architect-engineer of April 22, 1980, to discuss the system integrity of the recirculation spray heat exchangers for Beaver Valley, Unit No. 1. As specified in the meeting summary dated May 2, 1980, Duquesne Light Company agreed to conduct a freon test at each refueling outage (normal 18 month cycle) to be preceded by a pneumatic or other pressure test along the requirements of Section XI of the ASME Code. The details of such a test are to be developed by the licensee and included in their Inservice Inspection Program before the second refueling outage.

It is requested that you propose a change to your Inservice Inspection Program to satisfy this requirement.

Sincerely,  
*Steven A. Varga*  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc: See next page

Mr. C. N. Dunn  
Duquesne Light Company

cc: Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Karin Carter, Esquire  
Special Assistant Attorney General  
Bureau of Administrative Enforcement  
5th Floor, Executive House  
Harrisburg, Pennsylvania 17120

Mr. Roger Tapan  
Stone and Webster Engineering  
Corporation  
P. O. Box 2325  
Boston, Massachusetts 02107

Mr. F. Noon  
R & D Center  
Westinghouse Electric Corporation  
Building 7-303  
Pittsburgh, Pennsylvania 15230

B. F. Jones Memorial Library  
663 Franklin Avenue  
Aliquippa, Pennsylvania 15001

Mr. John Carey, Director  
Nuclear Operations  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburgh, Pennsylvania 15219

Mr. James A. Werling  
Plant Superintendent  
Beaver Valley Power Station  
P. O. Box 4  
Shippingport, Pennsylvania 15077

Mr. John A. Levin  
Public Utility Commission  
P. O. Box 3265  
Harrisburg, Pennsylvania 17120

Mr. J. D. Sieber, Superintendent  
of Licensing and Compliance  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Irwin A. Popowsky, Esquire  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

Mr. Charles E. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

March 12, 1981

Docket No. 50-334

Mr. C. N. Dunn, Vice President  
Operations Division  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Dear Mr. Dunn:

The NRC staff met with members of your staff and your architect-engineer of April 22, 1980, to discuss the system integrity of the recirculation spray heat exchangers for Beaver Valley, Unit No. 1. As specified in the meeting summary dated May 2, 1980, Duquesne Light Company agreed to conduct a freon test at each refueling outage (normal 18 month cycle) to be preceded by a pneumatic or other pressure test along the requirements of Section XI of the ASME Code. The details of such a test are to be developed by the licensee and included in their Inservice Inspection Program before the second refueling outage.

It is requested that you propose a change to your Inservice Inspection Program to satisfy this requirement.

Sincerely,

A handwritten signature in dark ink, appearing to read "Steven A. Varga".

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc: See next page

Mr. C. N. Dunn  
Duquesne Light Company

cc: Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Karin Carter, Esquire  
Special Assistant Attorney General  
Bureau of Administrative Enforcement  
5th Floor, Executive House  
Harrisburg, Pennsylvania 17120

Mr. Roger Tapan  
Stone and Webster Engineering  
Corporation  
P. O. Box 2325  
Boston, Massachusetts 02107

Mr. F. Noon  
R & D Center  
Westinghouse Electric Corporation  
Building 7-303  
Pittsburgh, Pennsylvania 15230

B. F. Jones Memorial Library  
663 Franklin Avenue  
Aliquippa, Pennsylvania 15001

Mr. John Carey, Director  
Nuclear Operations  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburgh, Pennsylvania 15219

Mr. James A. Werling  
Plant Superintendent  
Beaver Valley Power Station  
P. O. Box 4  
Shippingport, Pennsylvania 15077

Mr. John A. Levin  
Public Utility Commission  
P. O. Box 3265  
Harrisburg, Pennsylvania 17120

Mr. J. D. Sieber, Superintendent  
of Licensing and Compliance  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Irwin A. Popowsky, Esquire  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

Mr. Charles E. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077