

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission  
Advisory Committee on Reactor Safeguards

Title: 357th ACRS General Meeting

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, January 11, 1990

PAGES: 1 - 99

ACRS Office Copy - Retain  
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

9001240349 900111  
FOR ACRS  
T-1778 PDC

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

PUBLIC NOTICE BY THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: Thursday, January 11, 1990

The contents of this transcript of the  
proceedings of the United States Nuclear Regulatory  
Commission's Advisory Committee on Reactor Safeguards,  
(date) Thursday, January 11, 1990,  
as reported herein, are a record of the discussions recorded at  
the meeting held on the above date.

This transcript has not been reviewed, corrected  
or edited, and it may contain inaccuracies.



## 1 UNITED STATES OF AMERICA

## 2 NUCLEAR REGULATORY COMMISSION

3  
4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

## 5 357TH ACRS GENERAL MEETING

6  
7  
8 Nuclear Regulatory Commission

9 Room P-110

10 7920 Norfolk Avenue

11 Bethesda, Maryland

12  
13 Thursday, January 11, 199014  
15 The above-entitled proceedings commenced at 8:30  
16 o'clock a.m., pursuant to notice, Carlyle Michelson, Vice  
17 Chairman of the Committee, presiding.

## 18 PRESENT FOR THE ACRS SUBCOMMITTEE:

19 James C. Carroll, Member

20 Ivan Catton, Member

21 William Kerr, Member

22 Harold W. Lewis, Member

23 Paul G. Shewmon, Member

24 Chester P. Siess, Member

25 David A. Ward, Member

## 1 PARTICIPANTS:

2

3 R. Fraley

4 T. Murley

5 S. Diab

6 R. Barrett

7 J. Murphy

8 G. Burdick

9 J. O'Brien

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

## P R O C E E D I N G S

[8:30 a.m.]

1  
2  
3 MR. MICHELSON: The meeting will now come to order.  
4 This is the first day of the 357th meeting of the Advisory  
5 Committee on Reactor Safeguards. During today's hearing, the  
6 Committee will discuss and/or hear reports on the following:  
7 Interfacing Systems LOCA; preparation for meeting with NRC  
8 Commissioners; meeting with the NRC Commissioners; future ACRS  
9 activities; and, ACRS Subcommittee activities. Items for  
10 tomorrow's discussion are posted at the back of this meeting  
11 room.

12 This meeting is being conducted in accordance with  
13 the provisions of the Federal Advisory Committee Act and the  
14 Sunshine Act. Raymond F. Fraley is the designated Federal  
15 official for the initial portion of the meeting. A transcript  
16 of portions of the meeting is being kept, and it is requested  
17 that each speaker identify himself or herself and speak with  
18 sufficient clarity and volume so that he or she can be readily  
19 heard. We have received no written comments or requests to  
20 make oral statements from members of the public regarding  
21 today's meeting.

22 The first item on today's schedule I think is items  
23 of interest. There are a couple of items of interest. The  
24 first one is, we believe that we can probably complete this  
25 meeting on Friday, which is tomorrow of course, but there are a



1 couple of questions that I need to ask first to be sure. Hal  
2 Lewis is not here and two or three items are his. Until we  
3 know whether he has a coherence letter or a report on the State  
4 of Nuclear Power letter we are not sure if we can finish  
5 tomorrow. If he does not propose to put out those letters at  
6 this meeting, then we will be able to finish by 6:00 o'clock.

7 The Interfacing Systems LOCA letter, I assume Ivan,  
8 you will have one ready and we do intend to get it out. Those  
9 are the three letters that are on the agenda. Are there any  
10 others that I am unaware of that are anticipated?

11 [No response.]

12 Seeing none, then we assume that unless Hal has a  
13 plan to get his letters out we can certainly finish by 6:00  
14 o'clock tomorrow. Another item of interest is that Florida  
15 experienced a rolling blackout during Christmas Eve and  
16 Christmas Day. It was caused in part, perhaps, by the fact  
17 that the Turkey Point units were shut down at the time but it  
18 is rumored at least that the blackout would have been required  
19 anyway, but probably less extensive.

20 MR. KERR: Some reindeer got tangled up in the  
21 powerline?

22 MR. MICHELSON: I think it was just a whole lot of  
23 load. My daughter cooked Christmas Eve and Christmas Day on  
24 the grille. It was bitterly cold in Tampa. It was a three  
25 degree chill factor that evening and that day, so everybody was

1 loading it up.

2 Another item of interest to the Committee is that our  
3 proposed meeting with the Advisory Committee's of France and  
4 Germany and a similar type group from Japan has been deferred  
5 indefinitely. The reason given is that the French Group,  
6 Permanante and apparently other advisory groups in France are  
7 undergoing some kind of a reorganization. Until that gets  
8 straightened out, they are unprepared to meet. So, we don't  
9 know when that will be, but certainly it will probably be  
10 several months off would be my guess.

11 The Crystal River Plant has been fined \$50,000.00 for  
12 accepting some non-safety grade components for use in safety  
13 grade systems. Apparently, they also had a problem of  
14 accepting a five bladed propeller when they should have been --  
15 when a seven blade propeller was ordered. So, somewhere along  
16 the way their system had broken down.

17 The last item of interest is that about 12 percent of  
18 over 300,000 fingerprint cards that have been processed for  
19 unescorted access authorization to restricted areas of nuclear  
20 power plants, since April of 1987, there has been 300,000.  
21 About 12 percent have uncovered arrest records for the people  
22 filing the fingerprint cards. This seemed to us to be a fairly  
23 sizeable number, but we are not sure what it means.

24 MR. SHEWMON: Is this grounds for dismissal or just  
25 perjury charges if they said they hadn't, or what?

1 MR. MICHELSON: No. In order to get unauthorized,  
2 unescorted access, you have to file fingerprint cards and so  
3 forth. In the process of screening those --

4 MR. SHEWMON: That is not my question though.

5 MR. MICHELSON: In the process of screening those  
6 through the system -- I don't know of the consequence.

7 MR. SHEWMON: Okay.

8 MR. MICHELSON: This only came from the screening  
9 process.

10 MR. SHEWMON: Is that for DUI?

11 MR. MICHELSON: No, I think that DUI you have to --

12 MR. CATTON: It depends on the traffic violation.

13 MR. MICHELSON: Yes. At any rate, 12 percent is an  
14 interestingly large number. Those are the only items of  
15 interest. Do any other members have anything that they would  
16 like to bring up at this time? Hal is here now, okay.

17 MR. KERR: While you were talking about fines, to me  
18 a more interesting one is this fine of Duke Power because of  
19 something that happened at the Catawba Plant where apparently  
20 the NRC people disagreed with the way in which some  
21 surveillance of maintenance was done on a feed water pump. It  
22 is sort of incredible to me that a \$50,000.00 fine would have  
23 been assessed for what happened there, but perhaps the news  
24 release doesn't describe it accurately.

25 MR. MICHELSON: Hal, the first item of interest to us



1 was whether we can finish tomorrow night. It is dependent upon  
2 two letters that I think you have in your mind at least, and we  
3 wanted to know if you actually intend to get out. One is the  
4 coherence and the other is state of nuclear power plants.

5 MR. LEWIS: Okay. I am sort of overcome with the  
6 flush of power I can tell people whether they will get home  
7 tomorrow night or not. I had to think about that. The state  
8 of nuclear power, I didn't think was on a short time fuse. So,  
9 my plan was to hope we would get some opportunity today so I  
10 could solicit ideas. I have my own ideas, but I would like to  
11 get input from everybody to put together something that has a  
12 chance of being a Committee letter.

13 As far as a coherence letter is concerned, I have  
14 outlined and have to step up to a word processor and write it,  
15 which I will try to do during the day today so we will have a  
16 letter. Then, it is a matter for the Committee whether it has  
17 a sense of urgency about getting it out at this meeting or not.  
18 When I finish it, of course, I will be willing to approve it  
19 but that doesn't guarantee anything.

20 MR. MICHELSON: Well, there is, I think, adequate  
21 time to get the coherence letter out before 6:00 o'clock  
22 tomorrow.

23 MR. LEWIS: Okay, when would we --

24 MR. MICHELSON: That was the key one.

25 MR. LEWIS: That would be fine. When would we be

1 working on it, so that I know when I have to have the draft  
2 ready.

3 MR. MICHELSON: I would have to look at the schedule.  
4 When is it Paul? There is some time allotted for it, but there  
5 is a quite a bit tomorrow afternoon. Four to 6:00 o'clock of  
6 course, tomorrow afternoon we have only one letter for sure --  
7 well, your coherence letter and the Interfacing System LOCA  
8 letter would be the two.

9 MR. LEWIS: Okay.

10 MR. MICHELSON: We get a hit at those ahead of time,  
11 at least the Interfacing Systems LOCA.

12 MR. LEWIS: Realistically, I have no doubt that we  
13 will need two goes at the coherence letter. We will need a  
14 first go in which everybody gets the shouting at me out of  
15 their system, and then a second go at a real letter.

16 MR. MICHELSON: Is there space today anywhere? We  
17 will try to get the first shot in whenever we can. If we are  
18 getting ahead anywhere we will put it in.

19 MR. LEWIS: Okay, then I will get a draft done as  
20 quickly as I can.

21 MR. MICHELSON: Because you kind of need overnight to  
22 think on it so we can get a final one out.

23 MR. LEWIS: Well, there were some off the record  
24 comments just made across the table. If I could select the  
25 people to leave even earlier it could even go faster.

1           MR. MICHELSON: Well, we are intending to be here  
2 until 6:00 o'clock to get these two letters out. I think we  
3 can do it.

4           MR. LEWIS: If we work until 6:00, it's up to you.

5           MR. MICHELSON: Certainly by that time. I am hoping  
6 that both of these letters can get out by Friday night, but not  
7 necessarily before 6:00 o'clock tomorrow night. I think we may  
8 have to work all the way until 6:00 to do it. We will just  
9 plan on that.

10           If there are no other items of immediate interest,  
11 then I believe we will go to the first agenda item which is  
12 going to be the NRC Interfacing System LOCA program. I believe  
13 we are scheduled first for a short Subcommittee report from  
14 Ivan Catton, and that will be followed by a presentation by  
15 NRR. So, Ivan.

16           MR. CATTON: We had a Subcommittee meeting on the 7th  
17 of December, and then I gave a fairly lengthy Subcommittee  
18 report at the last full Committee meeting. So, I would just  
19 like to make a brief statement at this time.

20           In summary, the ISLOCA was described by the staff as  
21 a problem of sufficient risk potential, that a special effort  
22 for its resolution is warranted. The basis for this view is  
23 that a ISLOCA creates the potential for loss of two of the  
24 three barriers to fission product release. Further, under some  
25 circumstances, the lost coolant cannot be recovered. While we



1 share the staff's concerns, I believe the Subcommittee  
2 consensus was that we do not believe they had demonstrated that  
3 the ISLOCA is a problem of sufficient magnitude; that it needs  
4 attention outside of the IPE program.

5 I think at this point, I would like to turn it over  
6 to the staff, maybe to convince us different.

7 MR. MURLEY: Thank you, Mr. Chairman and Ivan. My  
8 name is Tom Murley from the staff. Since I guess I am the one  
9 who raised the sensitivity of this issue in recent years, I  
10 thought I would come down and explain why I am concerned and  
11 why we are doing the study.

12 First, I think I need to just mention that I think  
13 all of our jobs is to be constantly aware of what operating  
14 experience is telling us and whether there might be precursors  
15 in that experience to unexpected accident sequences. In  
16 particular, I am sensitive to the need not to be lulled into  
17 complacency by predictions by PRA's; that an accident sequence  
18 may have a very low probability. I will give one example that  
19 we all know, and that was in the area of the pressure vessels.  
20 Back when WASH 1400 was done there was a pressure vessel  
21 failure probability given of 10 to the minus seventh per  
22 reactor -- per vessel year.

23 It probably was a good estimate for a fresh vessel  
24 back then, but it didn't consider the risk from pressurized  
25 thermal shock sequences and the fact that those risks increase

1 with time. And, fortunately, we maintained a vigorous research  
2 program in that area. And fortunately, in examining some  
3 operating events, particularly the Rancho Seco event, the staff  
4 concluded there was a need to protect against a sequence that  
5 wasn't even considered in WASH 1400. I think this is a good  
6 example of how the system is supposed to work.

7 Now, of course, the Intersystems LOCA sequence -- and  
8 we are going to find out it really many sequences but as a  
9 class -- was found in WASH 1400 as the so-called Event V  
10 sequence. And, as I read through the NUREG 1150 analysis, here  
11 again we are seeing that the predictions are of very low  
12 probability. The Surry Plant, the sequence frequency as I read  
13 it, is 1.6 times 10 to the minus sixth per year, per reactor  
14 year. Sequoia is even lower, 6.5 times 10 to the minus seven.  
15 Zion is 1.5 times 10 to the minus six per reactor year. At  
16 Peach Bottom in Grand Gulf, it doesn't even show up on their  
17 sequences.

18 But, in recent years, we have seen a number of events  
19 that one could characterize as precursors to an Intersystem  
20 LOCA, events like check valve failures, isolation valve  
21 leakage, human errors leading to incorrectly opening isolation  
22 valves, operators ignoring indications of leaking isolation  
23 valves. And, the list is quite extensive, as a matter of fact.

24 Overall, I guess of most concern to me personally is  
25 a general lack of sensitivity to the potential for over

1       pressuring low pressure systems, lack of sensitivity on the  
2       part of the people that operate the plants and, even to some  
3       extent, on the NRC staff, particularly inspection staff. I  
4       think we perhaps over the years have been lulled into a kind of  
5       sense of complacency that this sequence is not to be worried  
6       about.

7                So, that gets us to I guess the root of my concern.  
8       But also, I think we have to ask, isn't this being addressed  
9       and isn't it being looked at in current programs. Here, I  
10      think not, because some of these precursors involve sequences  
11      that have not been modeled at any PRA. Therefore, my staff and  
12      I believe that current PRA methodology may not be adequate and  
13      probably is not adequate to give a true picture of the  
14      Intersystems LOCA frequency.

15               MR. CATTON: Tom, that's kind of where I lose it a  
16      little bit. What is wrong with the methodology?

17               MR. MURLEY: You are going to find out today.

18               MR. CATTON: Oh, okay.

19               MR. MURLEY: They will tell you why a lot of these  
20      things are not modeled in PRA's.

21               MR. CATTON: I understand that sometimes they are  
22      just left out, but that isn't that we don't know how to do it.  
23      They just don't do it.

24               MR. MURLEY: Yes.

25               MR. CATTON: Or, things like we know with respect to



1 the valves that the failure rate should be a lot higher but  
2 they don't seem to get into the PRA's. I think that's where  
3 the problem is.

4 MR. MURLEY: It's not just a matter -- it is not just  
5 a matter of putting in a different failure rate for a valve.  
6 One has to go in and look at what I call the sneak paths or the  
7 various sequences where you can overpressurize a low pressure  
8 system. That's not been systematically done.

9 MR. CATTON: But it should be, or the PRA is no good.

10 MR. MURLEY: Well, that's right.

11 MR. CATTON: I think we agree with you on that.

12 MR. MURLEY: Didn't I just say that we don't have  
13 much confidence that the current methodology is adequate for  
14 this sequence, and that's why I have decided that a separate  
15 comprehensive study is needed. One could, of course, delay the  
16 IPE and wait I don't know how many years until we get the  
17 methodology and then send it back out again. I don't think  
18 that's a wise thing to do.

19 I think there's very little chance that we will get  
20 the analysis we need from the IPE's that are being done right  
21 now. I have looked over the IDCOR methodology in this area for  
22 example, and I have set aside myself that it is not adequate.  
23 And, furthermore, I don't want to wait three to five years to  
24 find out that it was inadequate all the time.

25 MR. LEWIS: Tom, I'm the known statistical purist in

1 this crowd, so let me complain just very slightly. You used  
2 the term a little earlier of true picture This is in line  
3 with your conversation with Ivan. A probabilistic risk  
4 assessment, of course, only gives a probabilistic picture,  
5 nothing gives the true picture except hindsight and even that  
6 is a little bit iffy to many own people's self-interest.

7 So, the issue is only all the PRA does is reflect the  
8 best thinking and the best data available at the time if it is  
9 done conscientiously and well. So, it never tells the truth  
10 and one should never be surprised when a PRA is wrong, but one  
11 should be less surprised when a PRA is right. And, that's  
12 really all it is for.

13 MR. MURLEY: Yes.

14 MR. LEWIS: So, your complaint is that it hasn't been  
15 done as well as it could have been done.

16 MR. MURLEY: That's a better way to say it.

17 MR. LEWIS: And I wish I knew an exception to that  
18 comment in real life.

19 MR. MURLEY: I accept that. A true picture is --  
20 what I should have said is that we know there are some  
21 weaknesses in the methodology to treat this sequence so let's  
22 go and deal with it. I think we have got the tools to do it.  
23 I think you are going to hear today how they are proposing to  
24 do it.

25 MR. CARROLL: I guess one other clarification that I

1 am interested in, clearly every small leak between systems does  
2 not have the potential for creating an unrecoverable LOCA. In  
3 your laundry list of precursors, many of the things were a  
4 valve just cracked causing pressurization of a RHR System. But  
5 you certainly have to make a distinction between a small flow  
6 that is easily handled by makeup systems and precursor  
7 situations where there is a real potential for a LOCA that you  
8 can't recover from.

9 MR. MURLEY: Yes. I agree fully that not all events  
10 where you, in fact where you overpressurize a low pressure  
11 system lead to any consequences at all. We have seen many  
12 already. My point is in the past I am afraid that they have  
13 been dismissed for that very reason, that it is just a small  
14 leak. I have to confess to this Committee, I was embarrassed  
15 when I was the Regional Administrator in Region I we had one,  
16 and a BWR where the suction to the RHR pump was overpressurized  
17 and received system pressure and temperature, and it didn't  
18 even come to my attention. I mean, the inspectors didn't even  
19 think it was a big enough deal. All it did is fail some seals  
20 in the pump.

21 I read about it in an AEOD report where they analyzed  
22 the sequence. So, I think when I did find out about it, I  
23 certainly raised the consciousness of my inspectors to look for  
24 things like this. I think we are slowly raising the  
25 sensitivity of everyone to look for this and be sensitive to



1 it.

2 MR. CARROLL: But you do agree that there is a whole  
3 bunch of events that occur out there that clearly aren't  
4 precursors to anything?

5 MR. MURLEY: Sure. Let me conclude because I do have  
6 to put this in perspective. I am not saying and we have not  
7 concluded that there is an immediate safety problem, nor that  
8 any plant improvements are needed. It is quite possible that  
9 we will find that the risks are acceptably low, even in view of  
10 this precursor experience that we have seen. I do believe,  
11 however, that we need to promote an increased sensitivity of  
12 this issue on the part of the plant operators as well as the  
13 NRC staff.

14 So, we have scoped out a closure strategy which Mr.  
15 Barrett and the staff will talk to the Committee about. But,  
16 briefly though, we are first going to scope out the problem.  
17 One thing I think that I need to emphasize is that in scoping  
18 out the problem we have to take a broad view of the operating  
19 record of the plants and, particularly, we have to consider all  
20 check valve and isolation valve failures that can contribute to  
21 the precursor record even if they did not happen in systems  
22 considered for Intersystems LOCA.

23 Nonetheless, one has to consider that that event  
24 could have happened in a sensitive system or a system  
25 connecting say the primary system to a secondary system.

1 Furthermore, I think we have to consider all human errors where  
2 valves are left open or incorrectly operated that could  
3 contribute to the precursor record for the same reason.

4 We are going to do a comprehensive search for  
5 possible Intersystems LOCA sequences; we are going to improve  
6 our PRA models which you will hear today; and then, we are  
7 going to do thermal hydraulic and stress analysis to find out  
8 in fact whether even if you do pressurize some of this low  
9 pressure piping, maybe it can withstand it and not fail. So,  
10 by way of background, that is why I have decided to undertake  
11 this task. I think it is important. Quite frankly, I think it  
12 is my job to do things like this, to be sensitive to things  
13 that might have been overlooked and to study them, just like we  
14 did pressurized thermal shock. Maybe it will lead nowhere, but  
15 on the other hand it might lead to some improvements.

16 In any case, I think what we are doing is raising the  
17 sensitivity of people to the issue, and I think that in itself  
18 is going to turn out to be useful.

19 MR. WARD: Tom, I think you have made a good case.  
20 There certainly is a risk issue here. Whether it is worthy of  
21 being singled out for the attention it is getting, I think I  
22 still have some question about. In particular, I would like to  
23 hear your views on why this one is singled out in comparison  
24 with another issue, and that is the one of loss of decay heat  
25 removal during a shutdown. There was a generic issue 99.

1           That particular issue seems to have some of these  
2 same characteristics that you are concerned about, and I think  
3 rightly concerned about in this one. This is an accident that  
4 could occur under conditions when the containment is open, the  
5 pressure vessel is open, administrative controls are relaxed.  
6 There have been precursors which indicate this is a threat.  
7 Even though decay powers are low in this instant compared to  
8 the one you are concerned about, this is somewhat -- the fact  
9 that water levels can be quite low, the net effect is about the  
10 same.

11           In further, PRA doesn't deal with this type of issue  
12 or any shutdown issues. But yet, this one is being -- GI 99 or  
13 this decay heat removal issue at shutdown is being handled kind  
14 of a low keyed way.

15           MR. MURLEY: I agree with you, Dave, that it is an  
16 equally -- a sequence of equal concern in this sense, that it  
17 hasn't been dealt with adequately and there was not the  
18 sensitivity on the part of operators. There is a general  
19 feeling out there I can guarantee you, that once a plant is  
20 shut down and in Mode V or Mode VI, that there is nothing to  
21 worry about and that's not the case.

22           But we did a lot of work on it. My staff worked for  
23 over a year looking at the various ways you can get into  
24 trouble in shutdown decay heat removal loss, and we issued a  
25 bulletin to each licensee and made them take corrective



1 actions. And, I personally wrote to each licensed operator in  
2 the United States and told them, you better be concerned about  
3 serious accidents can happen during shutdown and here's the  
4 bulletin and you better read it.

5 Now, if you think we should do more, maybe we need to  
6 improve our PRA models more or something like that. I would be  
7 glad to hear that, because I don't disagree this is an issue.  
8 Why the Intersystems LOCA is of particular concern to me is the  
9 high consequence it can have. It can bypass the containment  
10 and it effectively can bypass any effective emergency planning,  
11 because it can happen in a fairly short time. It is just  
12 because of those consequences that I think we need to pay  
13 attention to it.

14 MR. CATTON: So, is your goal to do the same thing  
15 with the Interfacing LOCA? You are going to say gee, this  
16 could be serious, you better pay attention to it?

17 MR. MURLEY: I guess the question is, are we going to  
18 do the same thing in terms of sending information out to  
19 operators and things on Intersystems LOCA as we did on Midloop  
20 Operation.

21 MR. CATTON: Right.

22 MR. MURLEY: I haven't reached that conclusion yet,  
23 although if that's what it takes to increase the sensitivity of  
24 operators and people we may have to do that. Right now I  
25 wouldn't know exactly what to tell them, other than some

1 exhortations of good practice or something.

2 MR. CATTON: But, increased sensitivity ought to  
3 improve the PRA they do or the IPE and it should. It should  
4 turn up, and I think that is an admirable goal.

5 MR. MURLEY: If we do it right and if they do pay  
6 attention, then it will show up in the precursor records with  
7 time, yes. But just me sending a letter out, I don't know that  
8 I can take credit for that in any kind of risk analysis. It  
9 has got to show up in actual changes in operating practice.

10 I should say, there seems to have been an effect on  
11 our Midloop Operation Bulletin because people are sensitive. I  
12 personally talked with operators who said that they weren't  
13 aware of the problem and they thought that was a good bulletin,  
14 and they read it and paid attention to it. But, we had done a  
15 lot of homework before that and we were able to give them some  
16 real meat and some real substance. I don't think we are quite  
17 there yet in Intersystems LOCA.

18 MR. CARROLL: I can confidently report that the  
19 operators at Diablo are very sensitive to it.

20 MR. MURLEY: Good. I am glad to hear that.

21 MR. MICHELSON: Tom, I have two questions regarding  
22 Interfacing Systems LOCA, or maybe they are more like  
23 observations. The first one deals with the PRA that one would  
24 have to do properly to understand the effects of an Interfacing  
25 Systems LOCA. The difficulty I foresee is that once you have

1 looked at say overpressurization, you will perhaps find that  
2 the pipe isn't the first thing to rupture but perhaps it's an  
3 instrument blows off or a seal relieves itself or whatever.

4           These perhaps are even relatively modest leaks in  
5 terms of gallons of minute, but they are released to an  
6 atmosphere which is not necessarily a confined atmosphere and  
7 controlled, a large amount of water vapors, some amount of heat  
8 and so forth. The PRA, to be done right, has to first of all  
9 determine the probabilities of this happening and then it has  
10 to have in the model, the consequence so that you can really  
11 determine whether this is a core melt contributor or just what  
12 it is.

13           And, it appears to me in inquiring in a number of  
14 areas, we don't know how to determine the effect of these  
15 unusual environments upon sensitive equipment, particularly  
16 electronics equipment. We pursued this at great lengths on the  
17 APWR yesterday, and clearly it hasn't been explored. So, one  
18 of the parts of your program somehow has to be what are the  
19 consequential effects so we can determine that blowing an  
20 instrument off is not a big deal. You don't just look at the  
21 drain lines and see if the water can be carried away. That's  
22 only part of the problem. You have to look at the first  
23 protection to see if it is set off and a number of other  
24 possibilities.

25           MR. MURLEY: I agree.



1 MR. MICHELSON: So, that's just kind of an  
2 observation. I assume that part of your program is going to  
3 have to be to think about control of the environment or  
4 analyzing the consequences of the adverse --

5 MR. MURLEY: You will hear more about that today.  
6 But if it's not in there, I think you ought to point that out  
7 to the staff.

8 MR. MICHELSON: The second observation deals with a  
9 system which I think is particularly vulnerable to the problem  
10 because, in particular, the system is a reactor water cleanup  
11 on a boiling water reactor. It's an Interfacing System. It is  
12 at full reactor pressure and essentially full temperature for a  
13 portion of it during normal operation. If any kind of a  
14 failure occurs, then you have a problem of how do you isolate  
15 the break. It is a LOCA until isolated.

16 And, how do you isolate it, can you isolate it, do  
17 you have valves that will even close under those conditions,  
18 and what are the consequences to the environment in the plant  
19 because this is, again, outside of containment until such time  
20 as you get it isolated and under control. Again, I don't see  
21 these in the models. I see the probability of the failure in  
22 the model, but I don't see the consequence being adequately  
23 modeled to be sure where we are.

24 MR. MURLEY: I agree. In addition to the typical  
25 eventries and faultries that one has to do, there is a lot of

1 deterministic kind of analysis that has to go with it that has  
2 never been done before. Of course, we don't have an infinite  
3 budget to do this and an infinite program, but I think we do  
4 have to look at some of these types of questions that have  
5 never been looked at before.

6 Just to give another example Carl that happened at  
7 Arkansas, as I recall, some of the piping outside containment  
8 received primary system temperature and pressure and the piping  
9 was designed for the pressure but it wasn't designed for the  
10 temperature. Therefore, you can get who knows what kind of  
11 expansion stresses and bending stresses and so forth you can  
12 get. These kinds of things have been, as far as I can tell,  
13 totally overlooked in this kind of analysis before.

14 MR. LEWIS: Tom, there are two questions of  
15 completeness that are getting a little mixed up here. One is  
16 the question of whether you can do everything in the world  
17 which, of course, you can't do.

18 MR. MURLEY: Right.

19 MR. LEWIS: The other is, whether having set an  
20 objective you have done all you could do to achieve that  
21 objective; that is, it is possible to set as a PRA the  
22 calculation of a probability and to hell with the consequences.  
23 It is not that that would be a very good guide to decision  
24 making, to regulatory decision making, but it is possible to do  
25 it within the context of a self-consistent PRA. You have to

1 set a limited objective and then do as well as you can within  
2 it, because you can always price yourself out of doing anything  
3 by saying you haven't done enough.

4 You have to start at the beginning, decide what it is  
5 you are going to do, do it as well as you can and then, by  
6 golly, those are the probabilities as well as anybody knows and  
7 to the extent that you calculated the consequences and those  
8 are the consequences. But, you don't need to do everything as  
9 long as you know what you've done.

10 MR. MURLEY: Yes. And that's where I think starting  
11 out on a program like this, it takes a lot of wisdom and  
12 judgment to make sure that we are focusing on the right things.  
13 And that's why I would appreciate your insight when you hear  
14 what the staff is going to lay out for you today. Have we  
15 focused our limited resources on the right approach to this  
16 question?

17 MR. SIESS: Tom, NRR people are now reviewing designs  
18 for a proposed future evolutionary reactors. Are they  
19 addressing this issue?

20 MR. MURLEY: Yes.

21 MR. SIESS: The new?

22 MR. MURLEY: Yes.

23 MR. SIESS: Has ABBR and SP-90 gotten around this to  
24 satisfy you?

25 MR. MURLEY: Yes, absolutely. Now, we don't -- the



1 Commission wants to be involved in any decisions on  
2 requirements that go beyond our regulations. So, this matter  
3 is in a paper which will be sent to the Commission I hope  
4 within a week or so, which you will get a copy of. It lists 15  
5 areas where we are proposing to deviate from the regulations,  
6 various areas. This is one of them, Intersystems LOCA.

7 MR. SIESS: By deviate, which direction?

8 MR. MURLEY: Both.

9 MR. SIESS: Up, down, or sideways?

10 MR. MURLEY: Both. Most of them are increases or go  
11 beyond our regulations, but some like the OBE SSE question are  
12 relaxations. There is one on Intersystems LOCA and, for  
13 example, we are proposing that where you can you make the  
14 piping be able to withstand primary system temperature and  
15 pressure.

16 MR. SIESS: You make the distinction between being  
17 able to withstand and design for?

18 MR. MURLEY: Yes. Some cases you can design for it  
19 and other cases it is not practical but you can probably --

20 MR. SIESS: Some places where it is not designed for  
21 but it could withstand?

22 MR. MURLEY: Yes.

23 MR. MICHELSON: Tom, there is one small nomenclature  
24 problem with this Interfacing Systems LOCA which allows some  
25 kinds of things to fall in a crack. The problem is that I

1 think most people think of Interfacing System LOCA and somehow  
2 the Interfacing System is designed for lower pressure and  
3 temperature conditions and somehow it experiences the higher  
4 pressure in temperature condition.

5 That, of course, is not the case in reactor water  
6 cleanups. So, that kind of -- it's a LOCA, and it's an  
7 Interfacing System but it is not of the kind that people  
8 classically think of. Are you also picking up those kind of  
9 LOCA's?

10 MR. MURLEY: I hope so. Why don't you ask the staff  
11 when we get to it.

12 MR. MICHELSON: It is by your definition then, any  
13 Interfacing System whose failure would lead to a loss of  
14 reactor coolant; is it that kind of definition?

15 MR. BARRETT: Outside of containment.

16 MR. MICHELSON: Yes, outside of containment.

17 MR. BARRETT: Yes.

18 MR. MURLEY: Then you encompass it. Thank you. Of  
19 course, designing the pipe for full reactor pressure isn't the  
20 answer.

21 MR. MURLEY: I know. That's a good point. That's a  
22 good point, yes. Thank you.

23 MR. CATTON: Thanks, Tom.

24 MR. BARRETT: I am Richard Barrett. I am Chief of  
25 the Risk Applications Branch in NRR. Mr. Chairman, the notes

1 and viewgraphs that you have in front of you are an abbreviated  
2 version of the presentation that I gave to the Subcommittee on  
3 December 7th. I think that Dr. Murley in his remarks and,  
4 also, Dr. Catton in his report, have covered many of the  
5 important points that are in that presentation. So, after a  
6 discussion with Dr. Catton before the meeting, what I would  
7 prefer to do, rather than go through that presentation again  
8 would be to give you a presentation which addresses the three  
9 principal questions that were raised by the Subcommittee during  
10 the Subcommittee meeting in December.

11 Those three questions were, broadly stated, first of  
12 all, why do we need an ISLOCA project given the fact that the  
13 ISLOCA is handled in the IPE's, in the PRA's that will be done for  
14 the IPE's? Secondly, how does the ISLOCA core melt frequency  
15 goal -- the 10 to the minus sixth goal that we have stated --  
16 how does that relate to the NRC's safety goal policy? Thirdly,  
17 what actions, if any, are we planning to take as a result of  
18 this study once we have completed it and how do they relate to  
19 the IPE?

20 If you are agreeable to that, I would like to pursue  
21 it.

22 MR. CATTON: I see no disagreement.

23 MR. BARRETT: Thank you.

24 MR. CATTON: On your first question, why an ISLOCA  
25 project, I think in my own case the question was really not why



1 a project but why something other than an IPE when you are done  
2 with it. In other words, the increased sensitization may be  
3 necessary, but that doesn't mean once they are sensitized it  
4 can't be just included in the IPE.

5 MR. BARRETT: I think I understood the question to be  
6 a little broader than that. Why have a project at all --

7 MR. CATTON: There are others here that it is  
8 probably broader.

9 MR. BARRETT: If you would like to narrow the  
10 question, I would certainly prefer to answer a narrower  
11 question than a broader one.

12 MR. CATTON: No, I won't do that.

13 MR. BARRETT: Let me just proceed to answer the  
14 broader question of why, given the fact that we are about to  
15 embark on an IPE project which will involve the conduct of in  
16 excess of 100 PRA's, one for each operating reactor in the  
17 country, and each one of those PRA's will address the ISLOCA  
18 accident using the current state of methodology, why is that we  
19 the staff need to have an additional study to analyze this  
20 accident?

21 I think the answer to that question is quite a simple  
22 one. In general in PRA's that have been done in the past and  
23 that are being done now, including the NUREG 1150 PRA's, the  
24 WASH 1400 PRA's, and the PRA analyses that were done by the  
25 Brookhaven National Laboratory as part of the resolution of

1 generic issue 105, there is a limited scope of the modeling  
2 that is done of the ISLOCA sequence. It is generally treated  
3 as a hardware problem. It is treated as the rupture or failure  
4 of redundant check valves. And, quite often, it is limited to  
5 the discharge lines of the RHR systems in PWR's.

6 MR. CATTON: But that doesn't have to continue, does  
7 it?

8 MR. BARRETT: No, it does not have to continue but  
9 given the current state of --

10 MR. CATTON: If it is not correct or not complete, it  
11 should be made complete, it seems to me.

12 MR. BARRETT: Exactly. As I think Dr. Murley pointed  
13 out, we could give the industry guidance on how to do it more  
14 completely, but at this point we don't know what guidance to  
15 give. The purpose of the study is to understand what kind of  
16 guidance we might give if we are to give it. All we know right  
17 now is that --

18 MR. CARROLL: Why is it a given that the industry  
19 needs that guidance?

20 MR. CATTON: Just look at their PRA's?

21 MR. CARROLL: Well, except if NRR or the NRC says  
22 hey, to have an acceptable IPE you are really going to have to  
23 rigorously deal with Intersystem LOCA issues. Why do you have  
24 to say more than that?

25 MR. BARRETT: It's not a given. It is not a given.

1 All we know right now is that there are operational events  
2 which point to scenarios which are not modeled in PRA's. When  
3 we finish this study, we may find out that in spite of that  
4 fact, they are not very important to risk. It may very well be  
5 that the current PRA's are modeling the most important  
6 contributors in which case, we will just close shop and do no  
7 further work. We will put no further guidance to the industry  
8 of any type.

9 But at the moment, we have the suspicion that these  
10 operational events are pointing to important risk contributors.

11 MR. CARROLL: Don't you think people in the industry  
12 are considering that in their IPE's?

13 MR. BARRETT: I really have no indication that that  
14 is the case.

15 MR. CARROLL: They read Nucleonics Week inside NRC.

16 MR. BARRETT: They certainly do. What I would like  
17 to see is that if this is a bigger risk problem than has been  
18 modeled in past PRA's, I would like to be certain that all of  
19 the PWR's, all are doing it in a systematic way or considering  
20 this. I have no way of being assured of that at this point.

21 MR. KERR: When you talk about risk, I presume you  
22 are talking both about total risk due to all the operating  
23 reactors as well as risk to individual reactors?

24 MR. BARRETT: Yes, sir.

25 MR. KERR: It seems to me that one of the



1 characteristics of this problem is that more than some other  
2 sequences, it is likely to be extremely plant-specific. And  
3 hence, doing an analysis of four or five plants will tell you  
4 something about the risks associated with those plants. If I  
5 accept the premise of the people who have completed 1150 up to  
6 this point, it will tell you very little about those other  
7 plants out there.

8           What sort of conclusion are you going to draw on the  
9 basis of your limited analyses?

10           MR. BARRETT: I suspect that you are right. I  
11 suspect that we will find that if we analyze four plants we  
12 will find four very different situations and, from that, you  
13 might conclude that for all the PWR's each one of them is very  
14 plant-specific. That's, to a certain extent, that's why we  
15 have the IPE. We are looking for plant-specific  
16 vulnerabilities. I think by analyzing three or four plants,  
17 specific plants, we can begin to understand what factors are  
18 important to consider in analyzing this for an individual  
19 plant.

20           The guidance that we might put out to the industry in  
21 terms of the IPE would be guidance as to what factors to  
22 consider and perhaps how to consider it.

23           MR. KERR: I think that may well be true. On the  
24 other hand, suppose on the basis of your analyses you decide  
25 that there isn't sufficient risk to carry on the program. How

1 much confidence are you going to have in that conclusion,  
2 assuming that you have sampled only a limited number of plants?  
3 What I am getting at sort of, and I am not sure it's the right  
4 answer is, it seems to me this almost has to be done on each  
5 individual plant and it has to be done in a context in which  
6 one is looking at the total system, not just the isolated  
7 unisolable LOCA.

8 As Mr. Michelson points out, it can well influence  
9 many things other than just these high and low pressure  
10 systems. Therefore, it seems to me it almost has to be done in  
11 a context which is present only when one is doing something  
12 like an IPE. If it's just done where one is looking at this  
13 one sequence, I think it may be ineffective. But, maybe I am  
14 getting ahead of you so I will --

15 MR. BARRETT: Well, again, as Dr. Lewis pointed out,  
16 we have limited resources and we have to make choices as to  
17 what is the best way for us to deal with the problem as we  
18 perceive it. We have looked at the operational experience and  
19 we have an idea of what the potential problem is and what the  
20 potential sources of problems are, and I will get into a little  
21 bit of detail about that in a minute.

22 I think that within the limited resources that are  
23 always available, the limitations that are always there, I  
24 think we have to study the problem as we see it. And, if we  
25 are neglecting some -- if a lack of a more integrated approach

1 neglects some unperceived problem, of course, that's always a  
2 possibility that we have to live it. I think what we are  
3 trying to do is deal with the operational events as we see them  
4 and as we understand them in a generic sense.

5 MR. CATTON: Can I try to paraphrase what I think you  
6 said?

7 MR. BARRETT: Okay.

8 MR. CATTON: The purpose of the study will be to  
9 determine whether or not today's PRA's properly deal with the  
10 ISLOCA and what properly entails. Is that what you said?

11 MR. BARRETT: I'm not sure. No, I didn't say that,  
12 but I am not sure what that means.

13 [Laughter.]

14 MR. BARRETT: It could very well be that no PRA is  
15 perfect as Dr. Lewis pointed out. The question is, is the  
16 current way of doing PRA's capturing the most important part of  
17 the risk associated with ISLOCA or is there an entirely  
18 different element over here that is being shown by this  
19 operational experience which is actually dominating what we are  
20 modeling.

21 MR. CARROLL: How do the people that worked on 1150  
22 answer that question?

23 MR. BARRETT: Well, the people who worked on 1150 are  
24 here, if you would like to pose it to them.

25 MR. CARROLL: I would like to hear their comments at



1 some point.

2 MR. BARRETT: The people who worked on 1150 or the  
3 people in NRC who ran the 1150 project are involved also in the  
4 planning of this project. I don't believe there's any  
5 disagreement about the need to pursue this new area. Perhaps I  
6 could ask Joe Murphy from the Office of Research to address the  
7 question, if you heard it Joe.

8 MR. MURPHY: Joe Murphy, from the Office of Research.  
9 I agree completely with Rich and what Rich has said. We done  
10 1150 techniques that were rather standard for PRA in looking at  
11 the ISLOCA, which means there was an emphasis on the hardware  
12 failures. I think what the operational events have shown us  
13 recognize that in the analytical work on 1150 started I guess  
14 about six years ago. What's happened in this six year interim,  
15 there have been enough operational occurrences to show us that  
16 there is a potential at least for significant involvement in  
17 the human hardware interaction of effecting the ISLOCA  
18 probabilities that, to my knowledge, hasn't been included in  
19 any PRA that has been done.

20 The PRA's have focused on the hardware contribution  
21 and not really looked adequately at the effect the human can  
22 have in doing things that you may not think will happen as you  
23 look at the hardware layout. For that reason, we have been  
24 intimately involved in the planning of the program. I  
25 completely agree with Rich. We have to go forward and take a

1 look at the influence of the human and how it can effect us.

2 It is going to be a plant-specific problem. And,  
3 more than that, it may be even procedure specific in certain  
4 areas. But this will tell us what to look for, so that as you  
5 do an IPE, as you go forward with future PRA's, I think we will  
6 have a much better capability of giving advice to whoever is  
7 doing them, whether it's an NRC sponsored study or whether it's  
8 an IPE being done by the industry.

9 MR. CATTON: I gather from what you are saying that  
10 this particular problem is just a problem to fine tune your  
11 dealing with the human factors issue in your view? It's a  
12 problem across the board.

13 MR. MURPHY: It's a problem across the board. The  
14 fine tuning may be too kind.

15 MR. CATTON: Well, to improve.

16 MR. MURPHY: In fact, the way the ISLOCA has been  
17 looked at in the past, the human has been essentially left out  
18 of the problem.

19 MR. CATTON: It's been essentially left out of the  
20 problem pretty much everywhere.

21 MR. MURPHY: Yes.

22 MR. WARD: Joe, is that really unique for this  
23 ISLOCA, or does that apply to the 30 other sequences that the  
24 PRA attempts to model?

25 MR. MURPHY: It certainly applies to one degree or

1 another. It's a lot of other sequences. I have said many  
2 times I don't know whether the Human Factors Branch people who  
3 are here would agree with me or not, that we have really  
4 progressed a long way in our ability to handle human factors in  
5 probabilistic risk analysis since the days of WASH 1400. But  
6 we still have a long way to go.

7 MR. WARD: Do you think though Joe, that this is  
8 uniquely a problem for ISLOCA as compared with many other  
9 important risk sequences?

10 MR. MURPHY: We know that the bypass sequences that  
11 bypass the containment have from WASH 1400 on in virtually  
12 every PRA that has been done to the Level III, these have been  
13 important risk contributors. We can look at some of the  
14 operational events that have happened and try to ask ourselves  
15 honestly say, how would we have modeled the situation where the  
16 human was important. And, I think we see in these cases that  
17 we would have come up with a very low probability.

18 There have been instances where I think the average  
19 PRA analyst, even if he tried to factor it in -- a human error  
20 into the situation because of the mindset that he would be  
21 going through, would come out with low numbers. Quite frankly,  
22 we saw some operational occurrences that I think told us that  
23 the modeling we have done in the past was insufficient and  
24 suggested that we needed to go forward with a program now to  
25 come up with guidance as to how to look at these in more detail



1 as opposed to say, sitting back and saying let's let the  
2 industry do IPE's and they are aware of the operational  
3 occurrences as well as we are. We can sit back and we can wait  
4 until these come rolling in and do our review at that point.

5 I think that would sort of be burying our heads in  
6 the sand for the next few years and putting the burden on the  
7 industry to do something without really telling them that we  
8 were putting that burden on them. The purpose here is to get a  
9 leg up on the situation. We have something that we suspect we  
10 haven't modeled adequately in past PRA's.

11 MR. SIESS: What's the burden you are putting on the  
12 industry? I got lost there.

13 MR. MURPHY: We are not putting one on. I say if we  
14 simply sat back and put our hands in our pockets and sat down  
15 and said you are not going to provide any guidance on how to  
16 look at ISLOCA at this point. We will wait until the IPE's  
17 come in and we will review them and see if they did it properly  
18 without -- that's called bring me a rock. We will see if you  
19 do it properly but we will give you no guidance as to what  
20 properly means.

21 MR. SIESS: I mean, what's new about that? You  
22 haven't told them what is a vulnerability yet either. You told  
23 them to bring them in and show us what you think is a  
24 vulnerability and we will tell you whether we agree. And,  
25 simply to identify a potential vulnerability seems to be one

1 step beyond where you are now. It may still be short of where  
2 you would like to be in telling them what to do.

3 MR. MURPHY: Well, I won't claim that we always give  
4 perfect guidance to the industry obviously. I think your point  
5 is well taken. But, what I am trying to say is, I don't want  
6 to make this sound like it's a big deal because I don't think  
7 it is from the standpoint of a burden on industry. I think it  
8 is incumbent on us when we think we have a problem, we see a  
9 potential problem, to go forward and try to look at it in  
10 enough detail so that we can convince ourselves what needs to  
11 be looked at, what kind of modeling we might have to go to,  
12 what are the important problems and then try to structure that  
13 into some sort of guidance that we can provide as to what the  
14 problem is.

15 I may be getting into Rich's --

16 MR. SIESS: The danger in that is that you may define  
17 the problem too narrowly. If you simply tossed it out as a  
18 potential problem and let 80 utilities look at it, they might  
19 come up with more things than you could think of.

20 MR. MICHELSON: Bill?

21 MR. KERR: Joe, in one of your earlier comments you  
22 said that you had neglected human error. I look at the  
23 examples of human error here that presumably have been  
24 neglected -- take that last one for example, which involves  
25 potential failure of check valves. If your operational data is

1 valid and maybe it isn't, that failure will enter through a  
2 consideration of a combination of random failure and common  
3 mode failure independently, whether it was caused by human  
4 error or not.

5 MR. MURPHY: I agree.

6 MR. KERR: If the things that are causing problems of  
7 failures, if your database is okay, it doesn't make any  
8 difference if the failures come from human error or whatever,  
9 they will show up.

10 MR. MURPHY: One example might illustrate what I  
11 mean. There was one case where at one point they had a leaking  
12 check valve. Downstream of that leaking check valve there was  
13 a closed MOV. Those were the two barriers. The operator  
14 decided that he recognized he had a leaking check valve, and to  
15 attempt to seek that check valve he thought he put greater  
16 Delta P across the check valve. So, he opened the MOV  
17 downstream. What this did then was, it connected the reactor  
18 coolant system through refueling water storage tank because he  
19 had a leaking barrier and he opened the second barrier, and he  
20 opened that intentionally.

21 What I am saying is, the PRA would not model opening  
22 that MOV downstream.

23 MR. KERR: No, but it would model failures of valves.

24 MR. MURPHY: It would have modeled the failure of a -  
25 what you would have in the PRA typically would be, you had a



1 normally closed gate valve failing open, a very low  
2 probability. But what actually happened in this case the  
3 operator, because he decided he had a chance of seeding the  
4 check valve, intentionally opened the MOV. I don't know  
5 whether to call this a human error, but certainly with a human  
6 operating in a way we didn't intend.

7 MR. KERR: No, I am not arguing what happened. I am  
8 simply saying if this sort of thing is built into the database  
9 through operating experience, it will show up in a PRA whether  
10 it was caused by intentional or unintentional behavior on the  
11 part of an operator.

12 MR. BARRETT: Dr. Kerr, I think there is a  
13 distinction here between having a sequence that is being  
14 modeled currently and yet, you have underestimated the failure  
15 rates such as Joe's example. What is modeled in NUREG 1150 is  
16 a failure of check valves. If you have new operating  
17 experience with say the check valves might fail more  
18 frequently, then you could change your data.

19 I think the problem here is not so much the frequency  
20 of the occurrences as much as the types of occurrences that are  
21 happening, and that you have scenarios which are entire  
22 scenarios which are not taken into account. In fact, the  
23 entire concept of the operator as the initiator of the event is  
24 not taken into account.

25 MR. KERR: Rich, I think I understand your point, and

1 I think it's a valid point. The point that I am trying to make  
2 is that one ought to look at this very carefully and make  
3 certain that by looking so carefully at the trees, the  
4 individual occurrences, one does not lose sight of the fact  
5 that what really is occurring is that failures are being  
6 interjected, maybe in some cases inadvertently, and they are  
7 being inserted by people but what they are is failures of a  
8 system. Human aided failures but nevertheless, if one has  
9 enough operating experience one will see these as failures.

10 If failures show up in your sequences due to whatever  
11 cause, they ought to show up. Now, there may be other  
12 situations in which you haven't thought of appropriate  
13 sequences and they simply wouldn't show up no matter what your  
14 database are. And you are quite right, those need to be  
15 treated. But I sort of get the impression from the examples  
16 that I am seeing that there may be some situations in which  
17 this is not necessarily the case.

18 I am sure that as you look at it in more detail you  
19 will probably catch these.

20 MR. BARRETT: The analysis we are doing, Dr. Kerr,  
21 will also include -- will not only include the new types of  
22 scenarios which we are postulating as a result of the operating  
23 experience, but side-by-side will also include the type of  
24 scenarios which have traditionally been modeled in PRA's and  
25 will try to take into account where the operating experience

1 may lead to higher or even lower failure rates.

2 So, it is going to be done in an integrated fashion  
3 so that the entire ISLOCA sequences model in this study, all of  
4 the scenarios, all of the types of initiators which we think  
5 are important. So, I think we will pick that up.

6 MR. MICHELSON: Where will you get your data for  
7 failures of valves of the type wherein the operator opened  
8 them when they weren't supposed to be opened? That normally  
9 isn't in a MOV valve failure database because there is nothing  
10 wrong with the valves. But, it could be in some other kind of  
11 database in which you record cases wherein the valves are  
12 opened when they shouldn't have been opened.

13 I don't know that that database exists. Are you  
14 aware of any that compiles that in some kind of a systematic  
15 fashion so that you could get a probability number out of it?

16 MR. BARRETT: That's really the most difficult part  
17 of this study, is to model these kinds of human errors,  
18 especially human errors of commission. I think possibly -

19 MR. MICHELSON: The modeling, I think is going to be  
20 easier than getting some data to put into the model to get a  
21 number out of it. I think the modeling would be relatively  
22 straightforward, but getting the data seems difficult if not  
23 impossible.

24 MR. BARRETT: You are absolutely right. The  
25 difficulty is compounded by the fact that these error rates



1 that you are talking about being human error rates will vary  
2 depending on the types of conditions you will see.

3 MR. MICHELSON: Are you going to tell us how you are  
4 going to do this somehow anyway?

5 MR. BARRETT: Gary Burdick, he talks about the  
6 research program and will give you some -- obviously not too  
7 much detail about how we will get the base figures that we will  
8 use for these error rates. But also, how the model will take  
9 into account varying factors which impact human reliability. I  
10 made a promise that I hope Gary can meet.

11 MR. CATTON: In your search for data, it seems to me  
12 that if that's the kind of information that you are looking for  
13 you are going to have to broaden the database to well beyond  
14 the Interfacing System LOCA.

15 MR. BARRETT: Absolutely.

16 MR. CATTON: I mean, some parts I can imagine how you  
17 are using it to develop a standard for that part of a PRA. But  
18 what I am hearing now is a broader question, and you are going  
19 to have to go beyond the ISLOCA, much beyond it, and it's  
20 really not a study of the Interfacing System LOCA.

21 MR. BARRETT: It's a study of Interfacing System  
22 LOCA, but we are having to bring into account --

23 MR. CATTON: You start out with a study of the  
24 Interfacing System LOCA and you find that where your problem  
25 lies, at least as I hear you, that you can't put good numbers

1 on the probability of the operator doing one thing or another  
2 even initiating it. I don't think you have enough events  
3 within the ISLOCA type to give you that information, so you  
4 need to really back up and put the ISLOCA on a shelf and say  
5 gee, this is the kind of information, we need to evaluate it  
6 and do a different kind of study which is human factors related  
7 by itself.

8 MR. BARRETT: Yes.

9 MR. CATTON: And not all of this other stuff that  
10 just confuses the issue.

11 MR. BARRETT: Well, what we need to do is take  
12 advantage of all the human factors, methods development and  
13 data development that has gone on previously.

14 MR. CATTON: But it hasn't addressed the question.  
15 At least that's what we heard from Joe just a minute ago.

16 MR. BARRETT: Well, the modeling of ISLOCA hasn't  
17 addressed the question.

18 MR. CATTON: But knowing whether or not he's going to  
19 open the valve when he shouldn't is one of the questions, and I  
20 think Carl is right. You are not going to find that within the  
21 ISLOCA database, you are going to have to go well beyond it,  
22 maybe even well beyond the Nuclear industry to find this  
23 information and that is information is relevant to things other  
24 than just the ISLOCA.

25 MR. BARRETT: Yes.

1 MR. CATTON: So, why aren't you proposing a study of  
2 just that if that's the issue?

3 MR. BARRETT: We are proposing to do exactly what you  
4 said, and then use that information to calculate the ISLOCA  
5 probability.

6 MR. CATTON: So, the actual probability of the ISLOCA  
7 is downstream somewhere.

8 MR. KERR: If that's what you are undertaking, it  
9 seems to me that the problem is longer than the five years Mr.  
10 Murley cited as being unacceptable.

11 MR. BARRETT: I think I should probably leave a lot  
12 of this discussion to Gary Burdick. I think maybe too bleak of  
13 a picture has been painted here. I think you are getting the  
14 impression that we are going to start now to understand human  
15 reliability analysis. There are existing methods, there are  
16 existing data, and we are going to use what is available with  
17 some modifications which Gary Burdick describes.

18 But, the methods and the data and the performance  
19 shaping factors, we are not only to have a five year program to  
20 develop these things but we are, in fact within a month or so,  
21 of having an ISLOCA analysis in a preliminary draft form for  
22 one of the plants that we are analyzing.

23 MR. MICHELSON: I hope in all of this discussion we  
24 haven't thought that the remaining problem is the human factor,  
25 because unless you have put to bed some way the other problem



1 of having experienced even a modest ISLOCA what consequences it  
2 would have in terms of continuing cooling of the core.

3 One alternative is to say okay, I don't need to worry  
4 about that, if I have an ISLOCA, I have a core melt. Assume  
5 that. If you do that, you start ending up with probabilities  
6 of about  $10^{-3}$  and  $10^{-4}$  for the  
7 ISLOCA and then you end up with that same probability for the  
8 core melt. Until you chase this thing out and prove that even  
9 if you get it with fairly high probability, that the  
10 consequences are still acceptable.

11 I haven't heard you say anything yet about that,  
12 other than looking at the human factor which again, is dealing  
13 with prevention and not with how well can we mitigate once we  
14 experience it.

15 MR. BARRETT: We will model not only the probability  
16 that the operator can take action to prevent an ISLOCA from  
17 going to core melt, we are also going to take a look at the  
18 question of whether or not the pipe will break in the first  
19 place.

20 MR. MICHELSON: My question was the third part that  
21 you still haven't said and that is, having broken the pipe what  
22 is the consequence, and not just whether the operator can do  
23 something about it. You have to understand what the situation  
24 he's getting into will be so you know whether he can evaluate  
25 whether he could mitigate it or not. I haven't heard you

1 pursue that much yet.

2 MR. BARRETT: You are right, we haven't.

3 MR. MICHELSON: I assume you will today.

4 MF. BARRETT: We haven't discussed that, and I think  
5 we are making a lot of promises about what Gary can do with the  
6 30 minutes that is allotted to him.

7 MR. MICHELSON: Well, if you haven't --

8 MR. BARRETT: I will simply say at this point that  
9 the study will not only deal with the initiators of an ISLOCA,  
10 the probabilities of it being initiated either by a hardware  
11 failure or by human, it will also deal with the question of  
12 what is the likelihood that this type of sequence can be  
13 arrested before it goes to core melt including the impact for  
14 instance of having a break in the secondary buildings, the  
15 impact that would have on equipment, on the availability of  
16 injection equipment.

17 We also are evaluating the procedures and training  
18 that the operators have and the probability that they will be  
19 able to isolate the break or deal with it in some other way  
20 through accident management. We are trying to look at this in  
21 a pretty comprehensive way.

22 MR. MICHELSON: Those are the items I think the  
23 industry might need more guidance on as to how far do they  
24 really need to pursue this.

25 MR. BARRETT: Exactly.

1 MR. MICHELSON: If you haven't pursued it, of course,  
2 then they are at loss as to how far they should go. So, even  
3 though four studies for instance might tell you only about four  
4 plants, the methodology thereby developed might give you an  
5 insight as to how you do one properly for other plants wherein  
6 the situations are different. At least it gives you some  
7 guidance, better than nothing.

8 MR. BARRETT: Yes, sir.

9 MR. MICHELSON: Which is, I think, what we have at  
10 the moment.

11 MR. BARRETT: I just want to point out  
12 parenthetically, we run the possibility here by including the  
13 human initiator, the possibility is there that we might  
14 significantly increase the probability, calculated probability  
15 of an Interfacing Systems LOCA. But we are also improving on  
16 the current method of doing PRA's by doing a more thorough job  
17 of trying to understand whether or not, or what is the  
18 likelihood that an ISLOCA will go to core melt. What is the  
19 likelihood that the operator will be able to mitigate the event  
20 or that the pipe won't break in the first place?

21 So, it may well be that the result of this study is  
22 that the ISLOCA core damage frequency is significantly reduced  
23 in our opinion. It's a possibility.

24 [Slides.]

25 MR. BARRETT: Let me just very quickly tell you why I



1 put this up here. The operational experience that we have seen  
2 shows us that it is possible for the human to bypass some of  
3 the important safeguards that are in the plant to protect us  
4 against this type of an event. The first type of an event, and  
5 one of the ones that Joe mentioned, we have seen events where  
6 operators have deliberately opened valves which should not be  
7 open at full power. The example that Joe gave was one of an  
8 operator who thought he was trying to see -- who was trying to  
9 see a check valve by creating a differential pressure. He  
10 deliberately created an ISLOCA situation.

11 We had another interesting event --

12 MR. CARROLL: Did he, in that case?

13 MR. BARRETT: In that case there was.

14 MR. CARROLL: Was there the potential in that case  
15 for enough flow to cause a LOCA?

16 MR. BARRETT: In that case there was flow through a  
17 four inch line.

18 MR. CARROLL: A wide open line?

19 MR. BARRETT: A wide open line to the RWST.

20 MR. CARROLL: But I thought the check valve was just  
21 leaking?

22 MR. BARRETT: The check valve had gross leak  
23 adjustment. No, it was not a wide open line all the way from  
24 the RWST, but you can see -- what we are trying to key on here  
25 is, what are the modes of failure. This is a mode of failure

1 that was not considered before.

2 MR. CATTON: Is this the Bibliss instance?

3 MR. BARRETT: Yes, it is.

4 MR. CATTON: They didn't take it as seriously as you  
5 are.

6 MR. BARRETT: Well, I believe they are still studying  
7 the event.

8 MR. CATTON: It could be.

9 MR. CARROLL: I just caution that it is very easy to  
10 get hysterical about these kind of things. But you have to  
11 look at the real world, and I can't imagine the operator opened  
12 the valve wide open but maybe he did. I would expect he just  
13 cracked the MOV open, and I can't imagine the check valve was  
14 wide open.

15 MR. CATTON: But then he couldn't get the MOV closed  
16 again.

17 MR. CARROLL: That's okay, if you only cracked it.

18 MR. MICHELSON: That's a case where you have to look  
19 at the plant-specific situation. A lot of times as soon as you  
20 turn the hand switch, it goes full open automatically. You  
21 can't stop it, it doesn't have intermediate --

22 MR. CARROLL: That's true also.

23 MR. MICHELSON: The only way you can stop it is to  
24 let it go full open and then turn it around.

25 MR. CARROLL: That's true also.

1 MR. MICHELSON: But it depends on the plant. You  
2 have to start getting into that degree of detail if you want to  
3 understand this problem.

4 MR. CATTON: It was a human factors issue from the  
5 point of view of a shift change or something, wasn't it?  
6 Didn't they have a shift change right in the middle of it?

7 MR. BARRETT: That's possible, but I don't recall.

8 MR. CATTON: And then it led to more difficulties?

9 MR. BARRETT: They have all come together in my mind  
10 by now.

11 MR. DIAB: This is just a comment on this event that  
12 you were discussing. We had a similar event here in the  
13 States, and there was also a complication that the intent was  
14 to crack open an MOV. But, by the time the communication went  
15 from one to another, the valve was wide -- mid-wide open.  
16 That's another human error, that's a communication deficiency.

17 Again, you had a check valve and the intent was to  
18 seal it by creating a Delta P. And, the order was crack open  
19 the valve. By the time that went from one to one, the valve  
20 was eventually open.

21 MR. CARROLL: But in that ~~case~~ was the check valve  
22 open very much?

23 MR. DIAB: It was also -- I think there was a foreign  
24 object in there so you couldn't really see it.

25 MR. CARROLL: But was there the potential for a core



1       uncovery? Could enough flow have escaped?

2                   MR. DIAB: Yes, I think what Rich is trying to say is  
3       that this is a symptom of things that can occur. You could  
4       have had a slightly different situation with a much larger  
5       flow.

6                   MR. BARRETT: I think that's the important point. We  
7       are looking for types of errors which in themselves are not  
8       ISLOCA's, but in combination could be ISLOCA's.

9                   MR. CARROLL: With a much lower probability.

10                  MR. BARRETT: Much lower in probability. The  
11       question is, is it 10 to the minus six. That is a very low  
12       probability.

13                  MR. DIAB: I think once you start -- you begin to  
14       introduce these kinds of variations, human errors on things  
15       like that, then the problem doesn't really become very much  
16       plant-specific like was suggested earlier. The plant  
17       specificity comes from the fact that you have hardware oriented  
18       modeling. If you have a certain hardware combination in one  
19       plant and you don't have it in another plant, that's why you  
20       have the plant-specific idea that is floating around now.

21                  But once you begin to introduce these other  
22       parameters, the plant specificity sort of fades away to some  
23       degree.

24                  MR. KERR: But, the plant specificity is the thing  
25       that you will know most about. The human error is of the type

1 that you are talking now, you simply aren't going to be able to  
2 predict those probabilities with any level of confidence. You  
3 can do the consequence analysis perhaps, but the probability of  
4 that combination of human errors is going to be subject to  
5 tremendous uncertainty.

6 MR. BARRETT: Dr. Kerr, let me suggest that that type  
7 of question, maybe Dr. Burdick when he is up here can try to  
8 deal with the quality of the methods.

9 MR. KERR: That's a good suggestion.

10 MR. BARRETT: I am not an expert in this area. I  
11 just ask the questions and he answers them. Let me just  
12 quickly tell you some of the other types of events that we  
13 think are important.

14 [Slides.]

15 MR. BARRETT: What is it that we depend on to protect  
16 this pressure isolation? We depend in many cases on  
17 interlocks. We depend on, for instance, pressure differential  
18 interlocks as one of the barriers against opening of the motor  
19 operator valves in the RHR drop lines. We have seen at least  
20 one case where that interlock was defeated. We depend in many  
21 cases, to prevent the operation of a motor operated valve, we  
22 depend on someone removing power from that valve.

23 We have seen cases where there has been a failure to  
24 remove power from a motor operator valve when it should have  
25 been removed. We depend on good procedures, we depend on good

1 administrative controls to prevent the opening of these valves.  
2 We have seen numerous cases where, again, inadequate procedures  
3 have led to the opening of valves that should never be opened  
4 at power. Finally, here, we generally depend on the assumption  
5 that once we have closed the check valve and we have tested  
6 that check valve, we can depend on that check valve to be  
7 closed.

8 But we have seen events in which check valves have  
9 been stroked during operation, either during a test or for some  
10 other reason. And, in one case, 18 check valves were found to  
11 be stuck open, 18 of them for the same reason, because someone  
12 had installed them incorrectly using a procedure which left out  
13 a step. So what we are seeing here is possible initiators,  
14 possible contributors which are just not modeled in the PRA's.  
15 As a consequence, we have this project and the project is  
16 nothing more than a study, nothing more than an analysis to see  
17 if this new information changes our perception of the ISLOCA  
18 risk, the ISLOCA problem.

19 [Slides.]

20 MR. BARRETT: If there are no further questions, let  
21 me move on to the second question which I wanted to discuss  
22 with you and that is, a question was raised in various  
23 different forms at the Subcommittee meeting regarding what is  
24 the relationship between the goals that we have set for ISLOCA  
25 and the safety goals of the NRC. Let me just try to discuss



1 that. It is difficult to make a clear comparison between  
2 these, because the compliance of a particular plant with the  
3 safety goals is very plant-specific. So, in a generic sense,  
4 it is difficult to discuss it. I think it's instructive to at  
5 least talk about it.

6 The safety goal policy has essentially three types of  
7 goals in it. The first goals are the quantitative risk  
8 objectives. These are risk objectives for the latent fatality  
9 risk to an individual living within one mile of the plant or  
10 within 10 miles of the plant, and there's a prompt fatality  
11 goal for an individual living within one mile of the plant.

12 As I pointed out, the compliance of any particular  
13 plant, PWR or BWR with these goals is highly plant-specific and  
14 site specific. But let me just give you some insight into it.  
15 Back in 1984 when the draft policy was published, I did a brief  
16 survey of some of the available PRA's at that time to see how  
17 they stacked up against these quantitative risk goals. What I  
18 generally found for PWR's, even PWR's in high population zones  
19 was that, they fell well within the latent fatality goals. At  
20 that time, the latent fatality goal was less strict than it is  
21 today. But I believe it's fair to say even today, the existing  
22 plants, the existing PRA's will not challenge the latent  
23 fatality goals.

24 Furthermore in general, the ISLOCA sequence at the 10  
25 to the minus six level, which is where it generally is, is not

1 the most important contributor to the latent fatality goals.  
2 On the other hand, when I looked at the prompt fatality goals,  
3 what I found was that for the higher population sites, that the  
4 PRA risk estimates were a factor or two to ten below that goal  
5 in compliance with that goal again, depending on a lot of  
6 factors. In general, the ISLOCA sequence which again was in a  
7 numerical region of our 10 to the minus six frequency goal, was  
8 a major contributor to that.

9 So, if we achieve a 10 to the minus six frequency  
10 goal for ISLOCA, I think we can say that we will be within the  
11 prompt fatality goal for these PWR's as a general statement.  
12 On the other hand, if we were to accept a 10 to the minus five  
13 or a 10 to the minus four goal for ISLOCA, I don't think I  
14 could confidently make that statement for all plants. Again,  
15 these goals are generally not as limiting as the final goal,  
16 which I will discuss in a minute.

17 The second type of goal that appears on the safety  
18 goal policy is the performance objective for preventive  
19 systems. This has been interpreted differently by a number of  
20 people. The ACRS in a letter in April of 1988, suggested that  
21 this be interpreted as a 10 to the minus four core damage  
22 frequency. The staff has proposed a somewhat -- a very similar  
23 but slightly different interpretation of this goal. The ISLOCA  
24 sequence is generally a very small fraction of the total core  
25 damage frequency from internal events. If we meet the goal of

1 10 to the minus six for the frequency of ISLOCA, it will not in  
2 any appreciable way affect our judgment on a plant with regard  
3 to the performance objective for prevention.

4 Let me move onto the third type of goal. That is the  
5 proposed general performance guideline which was proposed to  
6 the staff for study as a possible goal for the nuclear  
7 industry. The way it was stated was that there should be a 10  
8 to the minus six probability of a large release, large release  
9 undefined. There have been a number of attempts to define what  
10 a large release is. I think that the ACRS definition was that  
11 a large release should somehow entail the release to the  
12 outside of the containment of a sizeable fraction of the  
13 radioactive inventory of the core.

14 I think that's a sensible definition. I think it's  
15 also a definition which a high consequence ISLOCA certainly  
16 fits. It's the type of an accident that would certainly fit  
17 that definition of large release. The goal, the proposed goal  
18 is that that have a 10 to the minus six frequency per reactor  
19 year. The goal that we are talking about for the ISLOCA  
20 sequence is a 10 to the minus six frequency per reactor year.  
21 We didn't derive the ISLOCA frequency goal from that general  
22 performance guideline or from anyone of these safety goals. At  
23 least in an order of magnitude sense, it is fair to say that  
24 the goal we are stating is compatible with the general  
25 performance guideline, particularly in light of the fact for



1 PRA's, for PWR's in general, the ISLOCA sequence is one of the  
2 major if not the dominant contributors to offsite risk to large  
3 releases.

4 MR. SHEWMON: When you calculate the probability of a  
5 ISLOCA as you define it, is that the probability of it  
6 proceeding to a large release or just -- we have had a fair  
7 amount of discussion here of when is a precursor significant  
8 and when is it minor. What do you take as the end point whose  
9 probability you wish to calculate?

10 MR. BARRETT: We are calling it high consequence  
11 ISLOCA. By that what I mean is, an Interfacing Systems LOCA in  
12 a sizeable pipe in which the core melts early within one or two  
13 hours, in which there is relatively little mitigation of the  
14 source term, and in which there is a sizeable release to the  
15 public within two or three hours of the beginning of the event.

16 MR. SHEWMON: So, you carry the probability  
17 calculation or would propose to carry it onto that degree?

18 MR. BARRETT: Yes, sir.

19 MR. SHEWMON: Thank you.

20 MR. MICHELSON: Then you do have to do a consequence  
21 determination to decide whether you are within the 10 to the  
22 minus six?

23 MR. BARRETT: Yes, sir. That's part of the program.

24 MR. MICHELSON: I misunderstood I guess too. I  
25 thought that was the probability of experiencing a loss of

1 coolant and not the consequence of it. If you are including  
2 consequence, then you have quite an analytical problem.

3 MR. BARRETT: The consequence is being included.  
4 Again, simply from a qualitative point of view though, we want  
5 to make the distinction between the type of event that can get  
6 you into an early core melt, an early release, a release that  
7 will be so fast that perhaps your emergency preparedness will  
8 not be effective as opposed to an entire spectrum of less  
9 significant type of ISLOCA's.

10 MR. MICHELSON: But this is clearly plant-specific.

11 MR. BARRETT: Yes, sir, clearly plant-specific.

12 MR. WARD: I didn't quite follow what you said, maybe  
13 I misunderstood. You seem to be saying that with the goals you  
14 have for the ISLOCA you would be well within each of the safety  
15 goal guidelines from top to bottom.

16 MR. BARRETT: Except this one.

17 MR. WARD: Is that what you said?

18 MR. BARRETT: We would be compatible with this one.

19 MR. WARD: That's where you said that may be a major  
20 contributor to risk expressed in that way.







21 MR. BARRETT: Yes.

22 MR. WARD: Okay.

23 MR. BARRETT: In many past PWR, PRA's, the ISLOCA has  
24 been a major if not dominant contributor to this category of  
25 events.

# 2

## IMAGE EVALUATION TEST TARGET (MT-3)









PHOTOGRAPHIC SCIENCES CORPORATION  
770 BASKET ROAD  
P.O. BOX 338  
WEBSTER, NEW YORK 14580  
(716) 265-1600



# 2







## IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION  
770 BASKET ROAD  
P.O. BOX 338  
WEBSTER, NEW YORK 14580  
(716) 265-1600

# 2







## IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION  
770 BASKET ROAD  
P.O. BOX 338  
WEBSTER, NEW YORK 14580  
(716) 265-1600

# 2

## IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION  
770 BASKET ROAD  
P.O. BOX 338  
WEBSTER, NEW YORK 14580  
(716) 265-1600



1 MR. WARD: I understand now, thank you.

2 MR. BARRETT: It depends on your definition of a  
3 large release, of course.

4 MR. WARD: Yes.

5 MR. BARRETT: Perhaps there are no further questions  
6 about the issue of safety goals.

7 [Slides.]

8 MR. BARRETT: Let me go on and discuss the third  
9 question which I postulated earlier, namely what is it that we  
10 plan to do as a result of this study. As Dr. Murley pointed  
11 out and as I have tried to point out, at this point the ISLOCA  
12 project is nothing more than a study. We are simply trying to  
13 find out if we have a bigger problem than we previously had.  
14 If we find out that we don't have a bigger problem, then we  
15 will definitely walk away from it with no further action.

16 Let me just discuss some hypothetical cases. Along  
17 the bottom scale here, I have a wide range of possibilities  
18 here for the probability of a high consequence Interfacing  
19 Systems LOCA. At this point, I might say that I don't know  
20 where the results of this study will fall. Let's just play a  
21 what if game. The first possibility, if I look at the range  
22 from the very best, our estimate of where the very best plant  
23 might be to our estimate of perhaps the very worst plant might  
24 be, if it looks like this; that is to say, if the median plant  
25 is at 10 to the minus six which is our goal, and if the

1 variation that we would expect from plant to plant due to the  
2 issues that we are raising is small, perhaps a factor of two in  
3 this particular case -- again, we are talking hypotheticals  
4 here -- then we would take no action. We would walk away from  
5 the problem, declare victory. We would say this looked like a  
6 problem but it wasn't.

7 Let's take a slightly different case. Suppose in  
8 this case the median value is still 10 to the minus six of a  
9 ISLOCA but based on the analysis that we see, the factors that  
10 are important here, we find several factors that we know are  
11 important in nuclear power plants based on our experience which  
12 could cause this to vary quite widely --

13 MR. KERR: Is that variation uncertainty in your  
14 analysis of one or two plants, or variation among plants?

15 MR. BARRETT: Among plants.

16 MR. KERR: How many plants do you anticipate  
17 analyzing?

18 MR. BARRETT: We plan to analyze three or four  
19 plants. But each one of those plants will be analyzed from the  
20 perspective of looking at the sensitivity to various human  
21 factor issues. So, based on those three or four plants, we can  
22 learn a lot about what the variation might be from the very  
23 best plant to the very worst plant.

24 MR. MICHELSON: Is your sample big enough to decide  
25 that no action is needed based on three or four plants? You

1 might have picked all of the goods one from a particular  
2 viewpoint and therefore -- for those, no action was needed.  
3 But maybe there's a dozen out there, that if you looked at you  
4 would have been way off on 10 to the minus five or four range.

5 How are you going to kind of assure yourself that  
6 your sample is a good sample?

7 MR. BARRETT: We have three criteria for sampling the  
8 plants. The first criterion is that we want to look at a  
9 variety of configurations, system configurations. Within each  
10 plant we are looking at four or five systems that are low  
11 pressure systems. We think we can see by looking at three or  
12 four plants we will see a wide variety of these types of valve  
13 configurations. And, that will give us a wide variety of  
14 scenarios to look at.

15 The second criterion is, we want to look at each of  
16 the three vendor types, I think primarily because the different  
17 vendors have different types of procedures. We want to see the  
18 effect that the procedures that they have for recovery actions  
19 have on this system -- on this accident. The third criterion  
20 is, we would like to -- we are trying to sample -- get a sense  
21 of how important licensee performance is. So, we are not as  
22 you pointed out, going to three or four very good plants. We  
23 are trying to look at some plants that have been singled out  
24 for the NRC watch list.

25 MR. MICHELSON: There are four vendors I should say,



1 and if you are only going to pick three or four plants, you are  
2 not going to pick more than one boiling water reactor for  
3 instance.

4 MR. BARRETT: Let me point out here, what we are  
5 talking about right is just the PWR's.

6 MR. MICHELSON: Why is it just PWR's?

7 MR. BARRETT: Well, we decided to do the PWR's first  
8 and then after we got started on the PWR's study, we would then  
9 begin to determine whether a BWR follow on is necessary.

10 MR. MICHELSON: Okay. So, we are looking at three  
11 vendors and if you pick three plants, you are only going to  
12 pick one Westinghouse?

13 MR. BARRETT: That's right.

14 MR. MICHELSON: Now, if you like to look at some of  
15 the other factors going into it, are you going to search around  
16 and figure out what was the worst things that we might run into  
17 and look for the plant that has all that combination of worst  
18 things; are you going to do it randomly, or what?

19 MR. BARRETT: There are certain limitations, of  
20 course, on which plants we can analyze.

21 MR. MICHELSON: You are only going to look at one  
22 Westinghouse, for instance. How are you going to decide which  
23 one is going to lead you to the no action decision?

24 MR. BARRETT: First of all, we have the two other  
25 criteria. One of them for instance is, we would like at plants

1 that have had performance problems, that have been singled out  
2 as having perhaps been put on the watch list either in the  
3 current one or else in recent years.

4 MR. MICHELSON: You would use that as --

5 MR. BARRETT: Yes. We also have constraints, because  
6 part of this program involves an audit of that plant where we  
7 will actually send the analysis team to the plant to interview  
8 people, to walk the plant down for -- it's a very intensive  
9 audit process, and one of the constraints we have is the  
10 scheduling of the audit.

11 MR. MICHELSON: If you are lead to no action  
12 decision, does that mean then that the IPE won't have to  
13 include this scenario in the same depth that you did it when  
14 you decided no action was needed?

15 MR. BARRETT: Exactly. The IPE will include it the  
16 way that PRA's have always included it.

17 MR. MICHELSON: Have been traditionally including it.  
18 So, it's a really very important decision that decides whether  
19 or not people look at it on their plant in this kind of depth?

20 MR. BARRETT: In this kind of depth, yes.

21 MR. MICHELSON: And, a no action decision is a very  
22 important one, and only three plants I kind of -- we will see.

23 MR. BARRETT: We will see. If I had to -- maybe when  
24 I am finished I will give you a guess as to which one of these  
25 scenarios is going to pan out.

1           MR. KERR: I think the likelihood of no action is a  
2 very low probability, Carl.

3           MR. MICHELSON: Yes.

4           MR. BARRETT: In general, that has very low  
5 probability, yes, sir.

6           MR. MICHELSON: I would like to see it in the IPE by  
7 the utility themselves to see if it's a problem.

8           MR. BARRETT: Well, if we find -- if we come to  
9 perhaps the more likely conclusion that we still believe the  
10 core damage frequency for the median plant is 10 to the minus  
11 six but that the variations can be quite wide on a plant-  
12 specific basis, then I think what we will try to do is take the  
13 most important insights from this research result and give  
14 those out as guidance for the IPE process. I don't think we  
15 are going to ask anybody to do an IPE analysis for ISLOCA that  
16 is as detailed and intensive and expensive as the one we are  
17 doing.

18           I think what we will try to do is take the most  
19 important insights from it and ask them to look at their plant  
20 from these perspectives. IPE guidance would be the choice at  
21 that point.

22           MR. CARROLL: When would all this happen, at what  
23 point in time?

24           MR. BARRETT: We are going to -- our goal is to have  
25 technical resolution for the PWR's by October of this year.



1 MR. CARROLL: So, there's still plenty of time to  
2 factor this into the IPE's that need to be submitted?

3 MR. BARRETT: Yes. It will impact some of the plants  
4 that will have gone beyond the point. Some of the plants would  
5 have to go back and redo that analysis. I believe for the  
6 majority of the plants, I think this would be timely.

7 MR. MICHELSON: What is your schedule for BWR's?

8 MR. BARRETT: We don't have a schedule yet for BWR's.

9 MR. MICHELSON: Do you think that's because it is a  
10 lesser concern or just want to do one at a time?

11 MR. BARRETT: Well, we wanted to do one at a time.  
12 We chose the PWR's for a number of reasons. Yes, we just felt  
13 that it was a lesser concern. The primary reasons for that is  
14 the lower primary pressure, primary system pressure, the wider  
15 variety of injection sources for a BWR. We just felt that it  
16 was a lower level of risk.

17 MR. MICHELSON: Outside of containment on boilers you  
18 have much larger pipes that are seeing reactor pressure  
19 routinely?

20 MR. BARRETT: Yes, sir.

21 MR. MICHELSON: And, whose failure demand that the  
22 valves isolate properly or clearly the plant is in deep  
23 trouble. Yet, that seems to be more compelling than on the --  
24 less compelling than on the PWR.

25 MR. CATTON: But they don't have the right valve date

1 in their, Carl.

2 MR. MICHELSON: I know. Well, that just makes it  
3 worse.

4 MR. CATTON: If they put the right valve date in  
5 there, maybe they would study the PWR's first.

6 MR. SHEWMON: The failure of those pipes is part of  
7 the design basis now, isn't it?

8 MR. MICHELSON: No. Not in terms of non-isolation.

9 MR. CATTON: That's right.

10 MR. MICHELSON: The design basis includes getting  
11 them isolated again in 20 seconds, 30 seconds, whatever the  
12 basis might be. If you don't isolate, you are in deep trouble.

13 MR. KERR: But the failure probability of those pipes  
14 is comparatively low.

15 MR. MICHELSON: And, the failure probability of the  
16 valves is relatively high.

17 MR. KERR: Yes, but you don't need the valves unless  
18 the pipe fails.

19 MR. MICHELSON: That's true. That's true.

20 MR. KERR: This is not low pressure piping, it is  
21 piping that is designed for the pressures and the temperatures  
22 I think, isn't it?

23 MR. MICHELSON: That's right. In some cases, it's  
24 non-sizemic piping though, non-QA piping. That's at full  
25 reactor pressure with full force.

1           MR. SHEWMON: That doesn't change the probability of  
2 pipe failure though, actually.

3           MR. MICHELSON: Well, it depends on what your  
4 viewpoint is.

5           MR. SHEWMON: It doesn't matter. If you go back and  
6 look at the seismic studies, either experience in fossil plants  
7 or the research program, whether or not it is designed on that  
8 way doesn't have a lot of effect on the failure probability.

9           MR. MICHELSON: The failure, Paul, they talk about  
10 six inches and up. We are talking about -- you know, you can  
11 get in deep trouble with a four inch pipe break outside of  
12 containment if you don't isolate it.

13           MR. SHEWMON: We were talking about thick pipes a  
14 moment ago. You want to talk about something else, we can talk  
15 about that.

16           MR. CATTON: It just seems to me that if you do a PRA  
17 and you have the data, you ought to put the right data in or  
18 the answer is nonsense. I think that is what Carl is saying  
19 politely.

20           MR. WARD: Haven't the isolation valves in the big  
21 steam lines in BWR's been given a lot more attention all along?  
22 I mean, to lump them in with this MOV problem, I think is  
23 misleading.

24           MR. MICHELSON: We are not thinking necessarily main  
25 steam and feed water. We are thinking reactor water cleanup,



1 HPCI steam lines, things of that sort and auxiliary feed water  
2 steam lines. But the main feed water and steam have gotten a  
3 lot of attention.

4 MR. BARRETT: You are absolutely right. There has  
5 been in fact, more experience on BWR's with the loss of  
6 pressure isolation.

7 MR. MICHELSON: That's right.

8 MR. BARRETT: We are not minimizing the importance of  
9 the PWR problem. We simply had to make priorities.

10 MR. WARD: The selection criteria for the plants, you  
11 are going to look at one of each PWR vendor and then problem  
12 plants; is that the only two criteria?

13 MR. BARRETT: The other one is to try to select a  
14 wide enough variety of plants that we see, a wide variety of  
15 valve configurations. You can two check valves and an MOV, one  
16 check valve one MOV.

17 MR. MICHELSON: We are near the end of your scheduled  
18 time, so you need to finish up.

19 MR. BARRETT: I am almost finished, Mr. Chairman.  
20 Let me just talk about one other possibility, and that  
21 possibility is that we could go through and find out that in  
22 fact the median risk is considerably higher than we previously  
23 thought. Under that circumstance it is possible that some sort  
24 of generic action would be necessary. When I say generic  
25 action, that could be anything.

1           It could be something similar to what Dr. Murley said  
2 earlier about a bulletin for Midloop operation. It could be  
3 something more drastic, depending on how bad that median risk  
4 is. If I had to make a guess of which of these potential  
5 scenarios is the one we might find, I think we might find this  
6 one, but we will see. I don't want to prejudice it.

7           MR. CATTON: Could the generic action be hey, you, a  
8 particular plant had better get your IPE in soon and it better  
9 include the following?

10           MR. BARRETT: I don't think we will know which are  
11 the worst plants even in this case. We may suspect that some  
12 plants are far worse than the median, but we probably won't  
13 know which ones they are.

14           MR. CATTON: But if you are going to do this human  
15 factors work, aren't you going to -- part of it, I thought, was  
16 methods development which was going to tell you how to make  
17 that judgment?

18           MR. BARRETT: Yes, sir. But then, each plant will  
19 have to be looked at individually. In this particular case,  
20 each plant will have to be looked at individually before we  
21 know which ones are the bad ones. Maybe we can tell them how  
22 to do a better job of their IPE, but we won't know of priority  
23 which one should be done first because we won't know until the  
24 analysis is done which ones are, if any, are the outliers.

25           MR. CATTON: It sounds kind of mushy to me.

1 MR. MICHELSON: Why don't we finish up.

2 MR. WARD: Could I ask a question?

3 MR. MICHELSON: Go ahead.

4 MR. WARD: Rich, I am not sure you quite got at least  
5 what some of us were driving at for your third -- what you  
6 characterized as the third question from the Subcommittee. As  
7 some of us see it, one of the benefits of the IPE process is  
8 that it's going to permit licensees to take some sort of common  
9 integrated, coherent set of implementation corrective actions  
10 against the whole suite of things they find in the IPE process.  
11 Whether the IPE process simply entails doing a PRA and  
12 responding to what falls out of that -- I don't think it does.  
13 I don't think anyone has ever said it does.

14 It includes doing a PRA, but it might include other  
15 ways of looking for things. For example, if you have gathered  
16 up some insights on how the ISLOCA might be looked at in  
17 specific plants outside of a PRA framework, that could be part  
18 of what I would call the IPE process. So, an essential part of  
19 it is whether you are going to have a schedule and permit  
20 licensees to take actions that are integrated or whether they  
21 have to take action on ISLOCA out here in some sort of parallel  
22 program ahead of or at least not coordinated with what they are  
23 doing from the other IPE or from the IPE work. I think that's  
24 the concern.

25 Do you understand what I said?



1 MR. BARRETT: Yes.

2 MR. WARD: I don't know if I made it clear.

3 MR. BARRETT: I think I heard two concerns. One is  
4 the question of whether we would put out guidance that would  
5 somehow take the ISLOCA and take it out of context. Is that  
6 part of your concern, that we would be asking them to analyze  
7 ISLOCA out of the context of the entire IPE process?

8 MR. WARD: Yes.

9 MR. BARRETT: I understand.

10 MR. WARD: And demand some fixes for ISLOCA  
11 independent of what fixes are going to come out of whatever the  
12 IPE reveals.

13 MR. BARRETT: No, that would not be -- that would not  
14 be the case unless we found some really bad problem. Unless we  
15 found, for instance, this other scenario where we just found  
16 that things are much worse than we previously thought and then  
17 at that point, there might be some sort of generic action that  
18 would be required. What that action would be, I don't believe  
19 even at that point, even if we were in the 10 to the minus five  
20 region, if we were to decide that we wanted to take some sort  
21 of generic action it could not be a drastic action. For one  
22 thing, cost benefit associated with this level of risk would  
23 not allow us to impose a very drastic action.

24 I think in the area of human factors you gain a lot  
25 with awareness of an event, with a little bit of training. One

1 of the issues we find is that some plants, the simulators can  
2 simulate an ISLOCA.

3 MR. MICHELSON: I think with that, we will have to  
4 complete your presentation. We are eating into the next  
5 presenter's time. Mr. Burdick is going to present the material  
6 for research. There is another handout coming.

7 MR. BURDICK: Thank you, Mr. Chairman and members of  
8 the Committee. My task now is to pay off all these I.O.U's. I  
9 think I will be able to deal adequately with a number of your  
10 questions and concerns.

11 [Slides.]

12 MR. BURDICK: That is who I am, Gary Burdick. This  
13 research activity was initiated as a result of a user request  
14 from Tom Murley to Eric Beckjord. You have heard a lot of  
15 discussion of these concerns. I won't dwell on these, but  
16 there are some important key elements of the request. You  
17 have to get farther into the low pressure systems than has been  
18 done, in past PRA's that has been discussed. More analysis of  
19 the human actions, human contributors. We have to determine  
20 sequence timings. NRR's concern is with the ISLOCA that has a  
21 possibility for the large release in a short period of time.

22 This, we were asked to do in a PRA framework and, in  
23 fact, are doing that. In the event that there is some  
24 regulatory action required we will, of course, have to go  
25 through probably backfit analyses. We were asked to estimate

1 the ISLOCA consequences in terms of risk and identify important  
2 factors for consequence reduction.

3 Right up front, we did take a look at past ISLOCA  
4 analyses. Again, there has been discussion of this and I will  
5 rapidly go through this. These analyses did little or no  
6 modeling beyond the PIV's.

7 MR. CATTON: What are PIV's?

8 MR. BURDICK: Pressure Isolation Valves. They make  
9 risk important hardware assumptions as to break likelihoods,  
10 locations, sizes. They did not account for types of human  
11 errors seen in recent events, of course, because they did not  
12 go into the low pressure systems. But we are not saying that  
13 these past analyses are inadequate. If indeed our more in  
14 depth study does not show that there is a risk increase, that  
15 these past studies do in fact bound the problem, and that is a  
16 distinct possibility -- we are not ruling that out -- then,  
17 those past analyses can be considered adequate.

18 There was some programmatic requirements then  
19 identified. We had to do this more in depth modeling of the  
20 low pressure systems to include the engineering analyses and  
21 human activities. There was a small methods development effort  
22 recognized, required to produce a low pressure system rupture  
23 model. This, of course, we did not have in past analyses. We  
24 want to know as best we can, what are the effects of the  
25 introduction of the high pressure. Do we have the single hole



1 in the dike, do we have multiple breaks occurring. We had to  
2 have a --

3 MR. KERR: Do you think you could model accurately  
4 whether or not the low pressure system would fail?

5 MR. BURDICK: I think the engineering analysis being  
6 done in this area is going to be top notch and will indicate  
7 probabilities of breaks at various locations. I think very --  
8 they will do that job very well, yes. There is preliminary  
9 indication of that.

10 MR. KERR: That's unusual, because engineers are not  
11 generally adept at predicting when things will fail. They  
12 design things that won't fail by introducing enough margin that  
13 they have relatively high confidence. But predicting failure  
14 is a different kettle of fish.

15 MR. BURDICK: We have, I think, one of the top  
16 engineering firms in the country looking at this problem, INEL  
17 Corporation. They are on subcontract.

18 MR. SHEWMON: He's not questioning either the moral  
19 probity or the capability of the engineers, he's making an  
20 observation on the difficulty of the problem. I don't think  
21 you are addressing it.

22 MR. BURDICK: Well, I will acknowledge that the  
23 problem is difficult, and I still say we are looking at it with  
24 the best people that we can find. We have under contract or  
25 the Division of Engineering does, probably the top individual

1 in the country to act as a consultant to review Impel's work in  
2 this area, Mr. Rodabow. I don't know if you have heard of him.  
3 Otherwise, I think he's known as Mr. Pipe.

4 MR. WARD: Gary, you say you have to develop this.  
5 What was used all the way back to WASH 1400 for Event V, I  
6 guess it is. What was assumed there about rupture of low  
7 pressure piping?

8 MR. BURDICK: What specifically was assumed?

9 MR. WARD: Yes.

10 MR. BURDICK: Well, I believe it was assumed to  
11 rupture not too far beyond the PIV's. Correct me if I am  
12 wrong, Joe, but I think at the first knuckle or thereabouts.  
13 So, you had leaks coming out of fairly large pipes. What we  
14 may in fact find through this more in depth engineering  
15 analysis is that you get leaks farther downstream, you have  
16 lower volume. This causes lower consequences for, not alone  
17 because of the low volume, but because this lower flow rate  
18 buys you additional time for recovery actions.

19 So, I think that the frequency that we may go up a  
20 little, but because of these other factors, the consequences  
21 may come down. And, because of this in depth modeling of the  
22 low pressure systems, we may begin to understand why we are  
23 seeing some of these events that have been discussed previously  
24 today. These events, again, they may not as was pointed out,  
25 be all that serious but they are occurring and they may be

1 expected to occur.

2 MR. MICHELSON: Which bullet on that slide is the one  
3 that deals with the environmental effects of the breaks, so  
4 that we are sure that we have everything in the model that  
5 needs to be there such as fire protection and so forth being  
6 actuated by steam which is not an incredible event. It happens  
7 very often when you break a hot water line even. Is that  
8 somewhere in one of those bullets?

9 MR. BURDICK: That is not addressed by any particular  
10 bullet here.

11 MR. MICHELSON: Is it addressed somewhere else then?

12 MR. WARD: Wasn't that on an earlier slide?

13 MR. BURDICK: These are not all the programmatic  
14 requirements. I recall these are the major ones. I will  
15 discuss how --

16 MR. SHEWMON: Are you postulating that the halogen  
17 influences the fracture probability of the pipe?

18 MR. MICHELSON: No. When a hot water line ruptures  
19 portion flashes of steam, water droplets are near and the fire  
20 detectors look at it just like smoke and start spraying the  
21 area.

22 MR. SHEWMON: Fine.

23 MR. MICHELSON: If it propagates further, they spray  
24 other areas.

25 MR. SHEWMON: My question was, you are postulating



1 that that spray influences the fracture probability; is that  
2 right?

3 MR. MICHELSON: No. That spray now influences the  
4 ability to mitigate the fracture you already have. You have to  
5 get the fracture first. That's the Interfacing Systems LOCA.  
6 I am just asking where we chase the consequence to determine  
7 how it affects core melt, because that I think is your goal, 10  
8 to the minus six for a large consequence. How do you know you  
9 got a large consequence if an instrument line breaks off?

10 MR. BURDICK: We are looking at common cause failures  
11 in the program.

12 MR. MICHELSON: That's not common cause, that's  
13 consequential effects. Common cause are when several things go  
14 crazy at the same time for unrelated reasons possibly. It also  
15 could be your common causes the hot water release.

16 MR. BURDICK: We realize that the affluent coming out  
17 of the system has a possibility to cause other problems and, in  
18 particular, it could --

19 MR. MICHELSON: Where is that treated in your  
20 program?

21 MR. BURDICK: I will treat it later.

22 MR. MICHELSON: Okay. Thank you.

23 MR. CATTON: It seems to me you have to treat it  
24 under your first bullet in engineering analysis. If you have a  
25 low pressure system and you are pressurizing it, in order to

1 address Carl's question, you have to know where the leaks are  
2 going to be throughout the low pressure system. And then you  
3 have to look to see what's around those leaks to find out if  
4 they are going to be impacted.

5 MR. BURDICK: Right on.

6 MR. MICHELSON: Where is that on your slide; that was  
7 the only question.

8 MR. CATTON: But you said later.

9 MR. BURDICK: I can't put everything on one slide,  
10 okay? Let me just move on here. The program is being done on  
11 a phased approach because we want to be a little prudent here.  
12 These more in depth analyses cost money and we want to, as we  
13 go along, assess what we are getting out of what we are doing,  
14 vis-a-vis, what has been done in the past. Maybe what was done  
15 is adequate. We don't know at this point.

16 So, there is going to be an HRA comparative analysis  
17 done on the first plant. We are doing the human reliability  
18 analyses two different ways. I will get into that a little  
19 more later. There is, in fact, a decision after the first  
20 plant to decide on which way to go. There is an entire program  
21 decision after the second plant. Rich didn't mention this, but  
22 this has been imposed upon me by my management to take a look  
23 at this entire approach to the problem to see how much we are  
24 getting from other aspects and to make some decision as to how  
25 many more plants, if any, we have to do to reach some

1 intelligent conclusions here.

2 MR. CATTON: In which part of this are you going to  
3 search for the human factors data that we heard was needed?

4 MR. BURDICK: Right in this box here, and that will  
5 be aided by this box, operational experience and plant audits.

6 MR. KERR: Where does one enter the process, at that  
7 first box on the upper left?

8 MR. BURDICK: What's the end of the process?

9 MR. KERR: No, where does one enter, e-n-t-e-r,  
10 begin?

11 MR. BURDICK: One does not enter this program in any  
12 particular part.

13 MR. CATTON: Once you are in you don't get out.

14 MR. BURDICK: There are a lot of activities that are  
15 being worked by different individuals, different disciplines.  
16 I mentioned some methods development --

17 MR. KERR: So, all those things start simultaneously?

18 MR. BURDICK: These started first, the configuration  
19 review.

20 MR. KERR: Okay. That's where the --

21 MR. BURDICK: The data analyses, these started  
22 simultaneously. There was some human factors analyses that  
23 started shortly after that. Instead of going through which  
24 started when, I think it's more fruitful if I explain how this  
25 all fits together and what these activities comprise.



1 MR. KERR: I would urge you to be fruitful.

2 MR. BURDICK: Be what?

3 MR. KERR: Be fruitful. Your word.

4 MR. BURDICK: We are looking at operating experience.  
5 The human factors people are using that information to develop  
6 an initial set of performance shaping factors. As they go  
7 through the --

8 MR. KERR: I apologize for this question, but could  
9 you just tell me briefly what a performance shaping factor is?

10 MR. BURDICK: These are items that the human factors  
11 analyst believes have important bearing on human actions in  
12 certain situations.

13 MR. KERR: Okay. One needs to develop them for this  
14 particular sequence; is that what you mean?

15 MR. BURDICK: One of the approaches to the human  
16 reliability analysis does use that approach, right.

17 MR. KERR: Okay. Thank you.

18 MR. BURDICK: An attempt to identify important items  
19 that affect a human's actions as he performs certain tasks.  
20 The quantification on the first plant is also going to use the  
21 same approach that has been done in past PRA's, generic data,  
22 some use of the THARP approach to quantifying human  
23 reliability.

24 [Slides.]

25 MR. BURDICK: A configuration review was done to

1 identify, as Rich mentioned, a set of systems which we hope  
2 would be as representative as possible of what exists out there  
3 in the operating plants. This, of course, cannot be perfect  
4 but it has to be the best we can do with the constraints we  
5 have to live with. The configuration review was -- the systems  
6 information was passed to the human factors people so they  
7 could get an idea of what it was they were going to have to be  
8 dealing with, get some idea of the nature of the beast before  
9 they went to the plants for the plant audits and the walk  
10 through.

11 The systems configurations were also passed to the  
12 engineering analysis task so it could begin to look at the  
13 fragilities, the effects of the high pressure encroachment on  
14 the low pressure system, and all of this information -- also, a  
15 thermal hydraulic analyses to get timing for the core recovery,  
16 of RWST drainage. We were anticipating some physics analysis.  
17 There may be some criticality questions, if it came to the  
18 point where we were reinjecting unboreated water for example.  
19 All of this information was fed into a PRA review. We did look  
20 at past PRA's, past analyses, to see what was usable out of  
21 those.

22 And, we had to develop a little new analysis  
23 technique to put all of this together. Accident management  
24 analysis was singled out here, but this is currently planned to  
25 be done in the recovery analysis stage of the normal PRA

1 process. If there is anything that leaps out here, some  
2 perceived high risk situation, that information will be passed  
3 to another branch in DSR for further analysis.

4 MR. MICHELSON: Excuse me. In looking at your  
5 various scenarios or situations, are you also going to look at  
6 for instance, fairly high probability transients that a plant  
7 could get into during which, because of whatever is going on,  
8 the probability of certain kind of operator errors occurring  
9 would be much higher and that might get you into an Interfacing  
10 Systems LOCA during the transient.

11 Do you look at that, or do you just kind of discard  
12 that as a low probability situation? Do you look for it, or  
13 are you just looking at Interfacing System LOCA as an  
14 initiator?

15 MR. BURDICK: We are simply looking at Interfacing  
16 Systems LOCA initiators.

17 MR. MICHELSON: Is there any reason to be concerned  
18 that what is otherwise a low probability Interfacing System  
19 LOCA might become a much higher probability if it was in  
20 conjunction with a transient during which operators weren't  
21 paying attention to that aspect or weren't -- their probability  
22 of making errors becomes greater when they already have another  
23 problem on their hands.

24 MR. BURDICK: Are you talking about the coincidence  
25 of an Atlas situation?



1 MR. MICHELSON: No, not Atlas. Just a much less  
2 transient than that, a higher probability transience, reactor  
3 trips and so forth even.

4 MR. BURDICK: I will check with the contractor during  
5 the next --

6 MR. MICHELSON: I just kind of wondered if what  
7 otherwise might be a low probability ISLOCA might be a high  
8 probability ISLOCA because of the situation of the plant at the  
9 moment.

10 MR. BURDICK: I will talk that over with the  
11 contractor at the next program review meeting.

12 MR. MICHELSON: Okay. I don't say it's a problem, I  
13 just wondered.

14 MR. BURDICK: All of these activities are intended to  
15 provide support to NRR's near term concerns, as well as  
16 contribute to the ultimate resolution of generic issue 105.

17 MR. MICHELSON: I guess my wonderment, by the way,  
18 might -- you might ask the contractor what happens if a plant  
19 has a fire and during the fire is there a possibility of an  
20 Interfacing System LOCA, not necessarily because of the fire  
21 but because of the confusion and the things your operator has  
22 to do during a fire.

23 MR. BURDICK: I think that kind of thing might be  
24 beyond the scope. We have funding limitations. We have to  
25 bound the problem somewhere.

1 MR. MICHELSON: We will just leave it as an  
2 uncertainty and the first consequence.

3 MR. BURDICK: We can't deal with everything.

4 MR. MICHELSON: Right.

5 MR. BURDICK: Let's see if there is anything that I  
6 have left out here.

7 [Slides.]

8 MR. BURDICK: We have covered that. Let's move  
9 along. I think I've covered just about all of this. As we go  
10 through these audits, we are attempting to make them as  
11 efficient as we can. As we identify things that can be  
12 improved or modifying the procedures --

13 MR. KERR: What is meant by a plant audit in this  
14 context?

15 MR. BURDICK: What is a plant audit?

16 MR. KERR: In this context?

17 MR. BURDICK: Well, we identify beforehand what we  
18 think is important to look at with respect to the Interfacing  
19 Systems LOCA situation, put together audit procedures, put  
20 together a team under a team leader, go to a cooperating plant  
21 and look for information with respect to relevant areas.

22 MR. KERR: Okay, so it's a visit to the plant and  
23 examination of the records of the plant?

24 MR. BURDICK: Yes, indeed.

25 MR. KERR: Interviewing people?

1           MR. BURDICK: Yes. Again, the human factors area is  
2 having a trial application on one plant, and we do have this  
3 methods development activity. I think there was some question  
4 raised there. We couldn't ask the contractor to go out and do  
5 something on this scale of a nature that has never been done  
6 before without giving some thought to how he was going to do  
7 it. Furthermore, down the line, there is a possibility that  
8 there may be some guidance going out to the licensees.

9           We have to have some, I think, thought put into that  
10 kind of guidance. Right up front, this development effort,  
11 everyone concerned thought was necessary.

12           MR. MICHELSON: Do you have more than one contractor,  
13 or are there just one doing the whole package?

14           MR. BURDICK: We have one contractor, and that's the  
15 Idaho National Engineering Laboratory. They have on  
16 subcontract, Impel Corporation to do the engineering analyses.  
17 Idaho was chosen not off the top of our heads, but after a look  
18 at the constituent areas involved in dealing with this problem.  
19 They already had ongoing strong teams in each area. They  
20 seemed to provide the ability to respond therefore, more  
21 rapidly to the needs of this program than other laboratories.

22           Nothing then is going to be applied in this phased  
23 approach to the systems identified in Task 1 in the context of  
24 the specific plants. The analysis, we have planned to go  
25 forward, at least on two plants before we go through this



1 decision process on how much more of it we have to do and is  
2 there any modifications in the method that has to be made.  
3 Again, there is a comparative human reliability analysis being  
4 done on the first plant.

5 The decisions, I want to emphasize, these are going  
6 to deal with the adequacy of the methods and the decisions are  
7 not going to be with respect to the adequacy of the plants with  
8 respect to the ISLOCA issue.

9 MR. CATTON: Maybe I don't understand some of the  
10 words you are using. When you talk about method, isn't the PRA  
11 method pretty well established; it's the level of detail that  
12 you need for a given problem where a little uncertain. Second,  
13 the depth of the deterministic analysis that supports the PRA  
14 is a little bit iffy.

15 MR. BURDICK: By method we are not just talking about  
16 PRA, although there has been a specific PRA approach selected  
17 for that portion of the analysis, and that is a multi-nodal  
18 event approach. But, there are other methods that we have had  
19 to develop also. One of these is a rupture model development  
20 to deal with the --

21 MR. CATTON: A rupture model is not PRA, it's  
22 something that yields --

23 MR. BURDICK: Well, methods are developed in other  
24 areas than PRA.

25 MR. CATTON: Somehow I am still confused. You have

1 up here depth of analysis. It seems to me determining whether  
2 or not something will rupture under a given set of  
3 circumstances is done by analysis.

4 MR. BURDICK: Yes. But, there are different kinds of  
5 analysis going on, particularly the engineering analysis.

6 MR. CATTON: But doesn't this yield you the  
7 information that you stick into the PRA?

8 MR. BURDICK: Well, it's a little more complex than  
9 that. We have coming out of the Impel work, a spectrum of data  
10 points, associated distributions. We have to have an overall  
11 approach to do uncertainty analyses, using those distributions  
12 to ultimately come out with the probabilities of failures at  
13 certain locations. We have to have a cohesive way of putting  
14 all this together so we can do sensitivity analyses, to help  
15 identify important constituents if the need exists to go beyond  
16 and do cost benefit analyses for PNOSA backfit Rule maybe.

17 MR. CATTON: I'm still lost. You might as well just  
18 continue.

19 MR. MICHELSON: We are running short of time, so we  
20 might as well continue.

21 MR. BURDICK: This is not a simple problem. I think  
22 this will become clear to you after we share the results of  
23 this first plant analysis to you. There will be a discussion  
24 in that document of the methods.

25 MR. MICHELSON: Roughly, when do you think you would

1 be prepared to give us the results of this first plant  
2 analysis?

3 MR. CATTON: We heard a draft was in preparation?

4 MR. MICHELSON: Yes, but I was trying to find out  
5 when do you think you would be ready so we can kind of plan  
6 accordingly?

7 MR. BURDICK: Well, I think we are looking toward  
8 April.

9 MR. BARRETT: Yes, we would like to have the  
10 opportunity to take a real hard look at the analysis in-house  
11 before we bring it down for you.

12 MR. BURDICK: It all depends on our internal review  
13 and how satisfied we are.

14 MR. MICHELSON: You are talking May then, I guess; is  
15 that right?

16 MR. BARRETT: That's correct.

17 MR. BURDICK: Correct, that's good.

18 MR. CATTON: Would it be possible for maybe some of  
19 us who are interested to get some of the written material  
20 before then?

21 MR. BURDICK: Before your meeting?

22 MR. CATTON: Yes.

23 MR. BURDICK: Certainly, absolutely.

24 MR. CATTON: Like soon, if possible.

25 MR. BURDICK: In fact, I am in a position to



1 guarantee it, I guess, if you will cooperate with your  
2 scheduling of your -- you can't very much do --

3 MR. MICHELSON: I think he's referring to not the  
4 briefing documents for the meeting but documents even ahead of  
5 that. We would like to get an early on view of what you are  
6 doing before the Committee considers it as a Committee.

7 MR. CATTON: Sometimes it's very difficult to absorb  
8 six months to a year's of your work while sitting here  
9 listening to you talk.

10 MR. BURDICK: Believe me, I realize that.

11 MR. CATTON: I would like to kind of keep up, and the  
12 way to keep up is preliminary documentation. If you don't give  
13 us the preliminary documentation, at least in my own case, we  
14 wind up asking awful, sometimes silly questions.

15 MR. BARRETT: We will certainly try to get you the  
16 information as soon as possible. The main concern we have is  
17 that we don't want to just take the contractor work and then  
18 begin to give it out to people before we have had a chance to  
19 evaluate it. But, I think as soon as we get a chance to  
20 evaluate it and feel comfortable with it in-house, we certainly  
21 could share it with you.

22 MR. BURDICK: There is a program management task  
23 here, of course, the glue that holds all of this together and  
24 documentation task.

25 MR. MICHELSON: Before you leave that, I waited to

1 see -- I understood you were going to show me what task was  
2 going to deal with evaluating the environmental consequences of  
3 an ISLOCA so that you could do a determination of a possible  
4 core melt probability changes. Which one of these tasks is it,  
5 I didn't catch it going through?

6 MR. BURDICK: I couldn't sneak that by you, huh?

7 MR. MICHELSON: No, I just didn't recognize it, I  
8 guess. I thought it would be in your task list, but I guess  
9 not.

10 MR. BURDICK: Well, the list pretty much follows  
11 this. It enters in a couple of ways. It is in the PRA  
12 analysis portion. Before we go on one of these audits, there  
13 is a preliminary PRA analysis done. There is a sequence  
14 analysis done to guide the members who actually go to the  
15 plants and, as they are doing their walk through, they are  
16 mindful of possible break locations and they actually examine  
17 those locations for hardware that could be impinged by  
18 effluents. They go a little beyond that.

19 There is also some look during the recovery action  
20 phase of the analysis, questions are asked can people really  
21 get from here to there to take some action to recover from a  
22 situation. It may be some steam or --

23 MR. CATTON: Can I try, Carl? I don't think he  
24 understands your question. If you have a pipe break in a given  
25 volume, you have to worry about everything in it. In the past

1 this was not done. It's a lot more than jet impingement. It  
2 seems to me that under that box down in the corner there where  
3 it says "TH", you ought to be taking a look at what various  
4 kinds of leaks can do in a given location. That has not been  
5 done in the past.

6 MR. BURDICK: We are not looking at --

7 MR. CATTON: All that has been done in the past is  
8 jet impingement. I think jet --

9 MR. BURDICK: We are not only doing --

10 MR. CATTON: Wait a minute. I think jet impingement  
11 is a small part of your problem, that you have to go beyond  
12 direct jet impingement or you are going to miss a major part of  
13 the impact above this kind of a leak. What are you doing about  
14 that?

15 MR. BURDICK: Well, we are looking at flow rates in  
16 relation to compartment sizes, how rapidly the compartments can  
17 fill to damage other equipments. We are not only looking at  
18 impingement, but steam. I see Dr. John O'Brien has his hand  
19 raised.

20 MR. CATTON: One of the reasons I asked about the  
21 availability of early documentation is, I would like to see how  
22 you are addressing this particular question in some detail. It  
23 is not a trivial problem.

24 MR. BURDICK: I understand that.

25 MR. WARD: Isn't that included in your Task number 3



1 under -- with the systems identified in Task 1, you do all  
2 these things and you get your flow rates. The next item should  
3 be, I guess, the consequential effects on other equipment.

4 MR. BURDICK: We do, in the thermal hydraulic  
5 analysis, come up with probabilities of break locations, flow  
6 rates, and those flow rates are from equipments in particular  
7 locations. That information is used in a common cause kind of  
8 analysis, as I mentioned.

9 MR. MICHELSON: Does that include temperature  
10 pressure and other entrained water or whatever in the  
11 atmosphere? In other words, the environment that the equipment  
12 sees, are you going to predict that from the thermal hydraulic  
13 analysis? That's what you have to start with to predict how  
14 equipment might respond.

15 MR. BURDICK: To a limited extent we cannot cover  
16 everything.

17 MR. MICHELSON: Well, if you don't do it -- if you do  
18 what we have been doing all the time, I wonder why the  
19 exercise? Because we have been talking about pipe breaks and  
20 the amount of water coming out for a long time, and I think  
21 everybody has decided that drains are big enough where the  
22 rooms won't come apart. But, nobody has looked at the  
23 equipment in the room in terms of what the environment will now  
24 do to producing unwanted actions elsewhere in the plant.

25 MR. CATTON: There has actually been experimental --

1 MR. MICHELSON: There's plenty of experience to show  
2 what happens.

3 MR. CATTON: Experience at the German reactor  
4 containment that shows what these things can do. But, somehow,  
5 that never seems to get folded back into this kind of analysis  
6 where it is relevant.

7 MR. MICHELSON: We had a Surry pipe break, for  
8 instance, which we set off 63 sprinkler, we set off the fire  
9 protection in a remote part of the building relative to where  
10 the break was, and activated the security interlocks, things  
11 like this, from a pipe break. Now, that's the kind of analysis  
12 I thought we were talking about here, if we are going to  
13 determine whether the core might melt as a consequence.

14 MR. BURDICK: This analysis goes beyond past analyses  
15 in a number of ways. In the common cause failure analysis  
16 area, there was I don't think, anything done at all in past  
17 PRA's with respect to the ISLOCA situation. Again, we are  
18 doing that in a limited way, and we have constraints on this  
19 problem. With common cause failure analysis, you could go on  
20 practically forever, I think.

21 John, you had your hand up?

22 MR. O'BRIEN: I believe the answer to the question  
23 that is being asked by Mr. Catton and Mr. Michelson is that  
24 these low pressure lines that we are evaluating are classified  
25 by the NRC as high pressure lines and in their normal design

1 are partial to rupture and leak. All equipment in the vicinity  
2 of these lines are qualified to withstand the environment  
3 associated with leaks and ruptures in these piping.

4 MR. CATTON: That usually just means time at  
5 temperature, humidity and pressure.

6 MR. O'BRIEN: It doesn't even mean that.

7 MR. BURDICK: Chemical environment.

8 MR. CATTON: And, chemical environment. That's not  
9 enough.

10 MR. MICHELSON: Inside a containment, that statement  
11 is quite true. Outside of containment, which is where we are  
12 dealing with I think on ISLOCA only, this is not true.

13 MR. CATTON: Well, he says he --

14 MR. MICHELSON: This is very few specific locations.

15 MR. CATTON: But he says he is going to do it. But  
16 even if he does it, that's not enough. You have to include the  
17 effect of the flow as well as just the time at temperature,  
18 pressure and humidity or chemistry or whatever. There is a lot  
19 more to the problem than just filling the room up with steam.

20 MR. O'BRIEN: I cannot imagine --

21 MR. CATTON: If you don't address it, you won't get  
22 at the issues that Carl is raising.

23 MR. O'BRIEN: I cannot imagine that the ISLOCA will  
24 present itself with a more harsh environment than the NRC has  
25 been postulating for two decades.



1 MR. CATTON: Well, I felt for two decades that that's  
2 probably not harsh enough for what will probably exist.

3 MR. MICHELSON: I would invite you just to go back  
4 and look at the pipe break studies that were done two decades  
5 ago, which is in many cases the last ones that were done, and  
6 see what they really considered.

7 MR. CATTON: Or just to visit HDR in Germany. It's  
8 really an eye opener. Things are torn off the walls. All  
9 kinds of things happened in that place.

10 MR. MICHELSON: I think we will have to complete the  
11 discussion. Chet, would you like to have a closing remark?

12 MR. SIESS: You are talking about mechanical effects  
13 that --

14 MR. CATTON: Actually it's both, the flow vibration  
15 sort of loosens up the seals or something in the seal.

16 MR. SIESS: That's mechanical.

17 MR. CATTON: Yes. The mechanical part of it has been  
18 ignored.

19 MR. SIESS: Not just simply the atmospheric  
20 environment?

21 MR. CATTON: That's correct. But I think Carl is  
22 right, we are over now, about 10 minutes.

23 MR. MICHELSON: Did you have anything more. You have  
24 one more slide?

25 MR. BURDICK: Well, I just had a program status thing

1 here.

2 [Slides.]

3 MR. BURDICK: I guess you already understand that we  
4 are expecting a document, draft document, perhaps the 16th of  
5 February it might be in my hands or very shortly thereafter.

6 MR. MICHELSON: That's from the contractor?

7 MR. BURDICK: That's from INEL, yes, EG&G, Idaho. We  
8 will review that document internally and then have the  
9 contractor back for a formal program review. Do I understand  
10 your request? You want to see the draft document?

11 MR. CATTON: For my own needs, I would like to see  
12 that little box in the corner that said "TH", the thermal  
13 hydraulics part of it, in particular how you treat what is  
14 going on in the vicinity of the break.

15 MR. MICHELSON: The Committee would like to see the  
16 draft document. INEL generally turns out pretty clean draft  
17 documents, and I think it would be worthy of our just looking  
18 at it. We won't call you in for any discussion of it unless it  
19 appears to be that we have some extremely serious problems.  
20 But, we would like to see the early on information, but we  
21 won't comment on it further until you are ready.

22 MR. BURDICK: I will take a look at that document.  
23 If it has too many warts, I may not want to do that.

24 MR. MICHELSON: We will look forward to that. Would  
25 you let us know if you are not going to send it; would that be

1       okay?

2               MR. BURDICK: Certainly. In case I don't, you will  
3 certainly get the completed document as soon as possible.

4               MR. MICHELSON: We would like to know when the  
5 completed document will come if you reject or do not send us  
6 the INEL preliminary draft, okay?

7               MR. BURDICK: Certainly.

8               MR. MICHELSON: Thank you.

9               MR. CATTON: I would like to thank you for the  
10 presentation.

11               MR. MICHELSON: I believe there is one more, Ivan.  
12 Mr. Barrett had asked for a minute to sum it up, and then you  
13 can thank them.

14               MR. CATTON: Okay, sorry.

15               MR. BARRETT: As a matter of fact, Gary said a number  
16 of the things that I had hoped to say in summing it up. Let me  
17 simply say that we have heard a lot of very important comments  
18 and questions, both in the Subcommittee meeting and here today,  
19 and I know that we haven't addressed all of them fully. But,  
20 we intend to take them into account in further planning of the  
21 program.

22               We hope that at the very least, we have convinced you  
23 of the importance of conducting this study and of the soundness  
24 of our approach to this study. As Gary pointed out, we will --  
25 we intend to keep you fully informed of the technical results



1 as they become available, starting as soon as we get the first  
2 analysis for the Davis-Besse event. Thank you very much.

3 MR. CATTON: Thank you. Carl?

4 MR. MICHELSON: The Committee will take a break now  
5 until 10 after, at which time we will pick up the agenda for  
6 the discussion with the Commissioner's this afternoon.

7 [Whereupon, at 10:57 a.m., the general meeting  
8 recessed, to reconvene the following day, Friday, January 12,  
9 1990.]

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: ACRS 357th General Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

*Mary C. Rosenberg*

Mary Rosenberg  
Official Reporter  
Ann Riley & Associates, Ltd.

# NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: ISLOCA PROGRAM OVERVIEW

DATE: JANUARY 11, 1990

PRESENTER: RICHARD J. BARRETT

PRESENTER'S TITLE/BRANCH/DIV: CHIEF, RISK APPLICATIONS BRANCH  
DIVISION OF RADIATION PROTECTION  
AND EMERGENCY PREPAREDNESS

PRESENTER'S NRC TEL. NO.: 492-1089

SUBCOMMITTEE: FULL COMMITTEE



## CONSEQUENCES OF AN ISLOCA

- o LOSS OF REACTOR PRESSURE BOUNDARY AND CONTAINMENT  
(Two out of three fission product barriers)
  
- o POTENTIAL FOR EARLY CORE DAMAGE
  
- o POTENTIAL FOR HIGH OFFSITE DOSES
  
- o LIMITED TIME FOR OFFSITE PROTECTIVE ACTIONS

## CURRENT PRA RESULTS

- o ISLOCA ANALYZED AS A HARDWARE PROBLEM  
(TWO VALVES IN SERIES)
  - WASH 1400
  - NUREG 1150
  - NUREG/CB 5102 (BNL Study)
- o RELATIVELY LITTLE ANALYSIS OF HUMAN ELEMENT
- o LITTLE OR NO CREDIT FOR ACCIDENT MANAGEMENT
- o CORE DAMAGE FREQUENCY  $\sim 1E-6$
- o ISLOCA A MAJOR CONTRIBUTOR TO EARLY FATALITIES

## EXAMPLES OF HUMAN ERROR

- o OPERATOR ACTION TO OPEN PIV
  - WRONG UNIT ERROR
  - OPENING OF MOV TO RESET CHECK VALVE
  
- o FAILURE TO REMOVE POWER TO MOV PRIOR TO LOGIC TEST
  
- o DEFEAT OF PRESSURE INTERLOCKS
  
- o INADEQUATE PROCEDURE FOR MOV STROKE TESTS
  
- o INADEQUATE INSTALLATION PROCEDURE LEADING TO SIMULTANEOUS FAILURE OF 18 CHECK VALVES



## ACRS BRIEFINGS ON ISLOCA

o APRIL 1989

Tom Murley informed Full Committee of existence of ISLOCA Project

o DECEMBER 1989 / JANUARY 1990

Staff briefing regarding goals, structure and elements of project

o SPRING 1990


Subcommittee briefing on preliminary technical results

o FUTURE BRIEFINGS


At appropriate intervals

# ISLOCA RESOLUTION OPTIONS


**NO ACTION**




**ISSUE IPE GUIDANCE**



**GENERIC ACTION**



**GENERIC ACTION AND IPE GUIDANCE**




$10^{-7}$

$10^{-6}$

$10^{-5}$

$10^{-4}$

**Probability of a high consequence ISLOCA**





**RES STAFF PRESENTATION TO THE  
ACRS**

**SUBJECT: ISLOCA RESEARCH PROGRAM (NEAR-TERM)**

**DATE: JANUARY 11, 1990**

**PRESENTER: GARY BURDICK**

**PRESENTER'S TITLE/BRANCH/DIV.:**

**SPECIAL ASSISTANT**

**DIVISION OF SYSTEMS RESEARCH**

**OFFICE OF NUCLEAR REGULATORY RESEARCH**

**PRESENTER'S NRC TEL. NO.: 49-23509**

## ISLOCA RESEARCH PROGRAM NEAR-TERM OBJECTIVES

- 0 EVALUATE LOW PRESSURE SYSTEMS FRAGILITIES UNDER HIGH PRESSURES/TEMPERATURES TO IDENTIFY LIKELY FAILURE LOCATIONS.
- 0 IDENTIFY SPECIFIC HUMAN ACTIONS AND ROOT CAUSES IMPORTANT TO ISLOCA FOR RECOMMENDING RISK REDUCTION ACTIONS.
- 0 DETERMINE ISLOCA SEQUENCE TIMING, FLOW RATES, ACCIDENT MANAGEMENT STRATEGIES, AND ISLOCA EFFECTS ON OTHER EQUIPMENT.
- 0 DEVELOP A PRA FRAMEWORK TO EVALUATE HUMAN AND HARDWARE CONTRIBUTIONS TO ISLOCA.
- 0 ESTIMATE ISLOCA CONSEQUENCES AND IMPORTANT FACTORS FOR CONSEQUENCE REDUCTION.


### PAST ISLOCA ANALYSES

- o DID LITTLE OR NO MODELING BEYOND PIVs
- o MADE RISK-IMPORTANT HARDWARE ASSUMPTIONS:
  - BREAK LIKELIHOODS
  - BREAK LOCATIONS
  - BREAK SIZES
- o DID NOT ACCOUNT FOR TYPES OF HUMAN ERRORS SEEN IN RECENT EVENTS
- o MAY BE ADEQUATE IF THEY:
  - CAN BE SHOWN TO BOUND THE PROBLEM
  - ESTIMATED RISK IS SMALL



## PROGRAMMATIC REQUIREMENTS

- o MODELING OF LOW PRESSURE SYSTEMS BEYOND PAST STUDIES:
  - ENGINEERING ANALYSES
  - HUMAN ACTIVITIES
- o SMALL METHODS DEVELOPMENT EFFORT REQUIRED TO PRODUCE:
  - LOW-PRESSURE SYSTEM RUPTURE MODEL
  - APPROACH TO INTEGRATE ANALYSES FROM VARIOUS DISCIPLINES
- o PHASED PROGRAM TO ASSESS ANALYSIS DEPTH VIS-A-VIS PAST APPROACHES
  - HRA COMPARATIVE ANALYSIS BEING DONE ON 1ST PLANT
  - HRA DECISION AFTER 1ST PLANT
  - ENTIRE PROGRAM DECISION AFTER 2ND PLANT



RES ISLOCA PROGRAM FLOW CHART

## BRIEF TASK DESCRIPTIONS

### 1. CONFIGURATION REVIEW

- IDENTIFY "REPRESENTATIVE" SYSTEMS

### 2. DATA ANALYSIS

- REVIEW OPERATING HISTORY FOR ISLOCA EVENTS
- ESTIMATE PRA PARAMETERS
- IDENTIFY POTENTIALLY IMPORTANT HUMAN ACTIONS

### 3. ENGINEERING ANALYSIS

FOR THE SYSTEMS IDENTIFIED IN TASK 1:

- CALCULATE COMPONENT FRAGILITIES W.R.T. PRESSURE AND TEMPERATURE
- ESTIMATE LIKELIHOODS OF FAILURES AT SPECIFIC SYSTEM LOCATIONS
- ESTIMATE FLOW RATES AND TIMINGS



## BRIEF TASK DESCRIPTIONS (CONT'D)

### 4. HUMAN FACTORS

- ANALYZE HUMAN ACTIONS FROM TASK 2 FOR PERFORMANCE SHAPING FACTORS
- COLLECT ADDITIONAL DATA FROM PLANT AUDITS
- RETROSPECTIVELY REVIEW AUDIT PROCEDURES IN LIGHT OF CURRENT PROGRAM RESULTS
- RECOMMEND AUDIT PROCEDURE REVISIONS
- DEVELOP FINAL PERFORMANCE SHAPING FACTORS FOR ESTIMATION OF HUMAN ERROR CONTRIBUTION TO ISLOCA
- TRIAL APPLICATION ON ONE PLANT

### 5. ANALYSIS METHOD DEV.

- DEVELOP PROCEDURES TO INTEGRATE ANALYSES AND RESULTS (TASKS 1-4) INTO ISLOCA PLANT EVALUATION METHOD

## BRIEF TASK DESCRIPTIONS (CONT'D)

### 6. EVALUATION METHOD APPLICATION

- APPLY PROCEDURES OF TASK 5 TO SYSTEMS IDENTIFIED IN TASK 1.
- ANALYSES TO GO FORWARD ON TWO PLANTS
- COMPARATIVE HUMAN RELIABILITY ANALYSES TO BE DONE ON 1ST PLANT
- DECISION ON FURTHER APPLICATIONS FOLLOWING 2ND PLANT
- DECISIONS WILL DEAL WITH ADEQUACY OF METHODS AND DEPTH OF ANALYSES
- PAST EFFORTS BEING UTILIZED WHERE APPROPRIATE (BNL REPORTS FOR HARDWARE DRIVEN SCENARIOS)

### 7. PROGRAM MANAGEMENT

- IDENTIFY CRITICAL PATH ITEMS
- ENSURE COORDINATION AMONG TASKS

### 9. DOCUMENTATION

- SYSTEM MODELS AND ANALYSES
- RESULTS AND CONCLUSIONS

## PROGRAM STATUS

### TASK

1. CONFIGURATION REVIEW (COMPLETED)
2. DATA ANALYSIS (COMPLETED)
3. ENGINEERING ANALYSIS  
(DAVIS-BESSE UNDERWAY)
4. HUMAN FACTORS (UNDERWAY)
5. ANALYSIS METHOD DEV.  
(UNDERWAY)
6. METHOD APPLICATION (DAVIS-BESSE)
7. PROGRAM MANAGEMENT (UNDERWAY)
8. DOCUMENTATION  
(DELIVERY POSSIBLE IN LATE FY1990)