

January 18, 1990

Docket Nos. 50-313
and 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: RESPONSE TO BULLETIN 88-10 FOR ARKANSAS NUCLEAR ONE, UNITS 1 AND 2

On November 22, 1988, the NRC staff issued Bulletin 88-10, "Nonconforming Molded-Case Circuit Breakers, requesting certain actions to be taken in regard to molded-case circuit breakers (MCCB) used in safety-related applications. The bulletin requested that licensees provide a written response confirming that actions requested by the bulletin had been taken, summarizing the results of those actions and if not completed, a schedule for completion.

By letters dated March 31, October 31, and December 28, 1989, you responded to Bulletin 88-10. The NRC staff has completed the review of your responses and finds that your actions are in conformance with the bulletin. No further action is required at this time. The NRC staff considers that you have met the response requirements of Bulletin 88-10.

As discussed in Bulletin 88-10, you should maintain the documentation associated with this bulletin for at least five years. These records may be subject to inspection in the future.

Sincerely,

/s/
Chester Poslusny, Jr., Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PD4 Reading	G. Holahan
ADR4	F. Hebdon	P. Noonan	CPoslusny	OGC-Rockville
E. Jordan	ACRS (10)	PD4 Plant File		

OFC	: PD4/LA	: PD4/PM	: PD4/D	:	:	:	:
NAME	: PNoonan	: CPoslusny:cs:	FHebdon	:	:	:	:
DATE	: 01/17/90	: 01/17/90	: 01/17/90	:	:	:	:

OFFICIAL RECORD COPY
Document Name: B 8810

9001290222 900118
PDR ADDOCK 05000313
Q PIC

QF1
1/10



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
January 18, 1990

Docket Nos. 50-313
and 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: RESPONSE TO BULLETIN 88-10 FOR ARKANSAS NUCLEAR ONE, UNITS 1 AND 2

On November 22, 1988, the NRC staff issued Bulletin 88-10, "Nonconforming Molded-Case Circuit Breakers, requesting certain actions to be taken in regard to molded-case circuit breakers (MCCB) used in safety-related applications. The bulletin requested that licensees provide a written response confirming that actions requested by the bulletin had been taken, summarizing the results of those actions and if not completed, a schedule for completion.

By letters dated March 31, October 31, and December 28, 1989, you responded to Bulletin 88-10. The NRC staff has completed the review of your responses and finds that your actions are in conformance with the bulletin. No further action is required at this time. The NRC staff considers that you have met the response requirements of Bulletin 88-10.

As discussed in Bulletin 88-10, you should maintain the documentation associated with this bulletin for at least five years. These records may be subject to inspection in the future.

Sincerely,

Douglas V. Pichett

for Chester Poslusny, Jr., Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

cc: See next page

Mr. T. Gene Campbell
Arkansas Power & Light Company

Arkansas Nuclear One
Unit Nos. 1 and 2

cc:

Mr. Early Ewing, General Manager
Technical Support and Assessment
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Neil Carns, Director
Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Honorable Joe W. Phillips
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Nicholas S. Reynolds, Esq.
Bishop, Cook, Purcell
& Reynolds
1400 L Street, N.W.
Washington, D.C. 20005-3502

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
1 Nuclear Plant Road
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Environmental Health
Protection
Arkansas Department of Health
4815 West Markam Street
Little Rock, Arkansas 72201

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852