



Portland General Electric Company

David W. Cockfield Vice President, Nuclear

January 22, 1990

Trojan Nuclear Plant
Docket 50-344
License NPF-1

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington DC 20555

Dear Sirs:

Nuclear Regulatory Commission (NRC)
Bulletin 89-02 - Stress Corrosion Cracking of
High-Hardness Type 410 Stainless Steel Internal Preloaded
Bolting in Anchor Darling
Model S350W Swing Check Valves or Valves of Similar Design

The purpose of this letter is to report to the NRC that Portland General Electric Company (PGE) has completed an evaluation of all safety-related check valves as required per Bulletin 89-02. The results of our evaluation conclude that the Trojan Nuclear Plant has no swing check valves with internal preloaded bolting material of American Society for Testing Materials (ASTM) Specification A193 Grade B6 Type 410 stainless steel. No further action will be taken by PGE on Bulletin 89-02.

Sincerely,

c: Mr. John B. Martin
Regional Administrator, Region V
U.S. Nuclear Regulatory Commission

Mr. David Stewart-Smith
State of Oregon
Department of Energy

Mr. R. C. Barr
NRC Resident Inspector
Trojan Nuclear Plant

Subscribed and sworn to before me this 22nd day of January, 1990.

9001300087 900122
PDR ADOCK 05000344
Q PDC

Notary Public of Oregon

My Commission Expires:

August 9, 1991

