### Southern California Edison Company

23 PARKER STREET

IRVINE. CALIFORNIA 92718

F. R. NANDY MANAGER OF NUCLEAR LICENSING

January 16, 1990

TELEPHONE (714) 587-5400

U. S. Nuclear Regulatory Commission Office of Inspection and Enforcement Region V 1450 Maria Lane, Suite 210 Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Subject: Docket Nos. 50-206, 50-361 and 50-362

Followup Report, Inoperable Fire Doors - December 1989 San Onofre Nuclear Generating Station, Units 1, 2 and 3

The purpose of this letter is to provide a follow-up report for Technical Specification (TS) fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in December 1989. This monthly report and previous monthly reports provide updated information associated with the initial 1983 report for Units 2 and 3. Unit 1 fire doors found inoperable during routine surveillances are now included in this report following implementation, in December 1989, of Amendment 131 to Provisional Operating License No. DPR-13.

The enclosed report identifies: a) 2 latching mechanism failures and 1 closure mechanism failure for Unit 1 and, b) 19 latching mechanism failures and 14 closure mechanism failures for Units 2 and 3. As each of these deficiencies was identified, compensatory fire watches were established pursuant to TS 3.14.7, Action "A" for Unit 1 and TS 3.7.9, Action "a" for Units 2 and 3. No doors were found to be blocked open in December.

If you require any additional information, please let me know.

Very truly yours,

Enclosure

cc: C. W. Caldwell (NRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)

## ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF DECEMBER 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNIT 1, DOCKET NO. 50-206

## I. Latching Mechanism Failures:

Number of doors inoperable - 2, as follows:

Door Number	Inoperable	Operable
S1-FBD-148	11/29/89	12/09/89
S1-FBD-130	12/13/89	

## II. Closure Mechanism Failures:

Number of doors inoperable - 1, as follows:

Door Number	Inoperable	<u>Operable</u>
S1-FBD-148	11/29/89	12/08/89

### III. Doors Blocked Open:

Number of doors blocked open - None

# ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF DECEMBER 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNITS 2 AND 3, DOCKET NOS. 50-361 AND 50-362

## I. Latching Mechanism Failures:

Number of doors inoperable - 19, as follows:

Door Number	Inoperable	Operable
AC-108	08/16/89	12/06/89
AC-428	09/21/89	
FH2-101	10/10/89	
AC-325	10/24/89	12/21/89
C3-406	11/15/89	12/08/89
FH2-404	11/28/89	
AC-349	12/06/89	12/15/89
AC-107	12/07/89	
S2-016	12/07/89	
S3-016	12/07/89	
AC-223	12/13/89	
AR-504	12/14/89	
AC-239	12/18/89	12/26/89
FH2-404	12/28/89	
AC-349	12/29/89	
FH3-303	12/29/89	
FH3-403	12/29/89	
S2-018	12/29/89	
AC-101	12/31/89	

# ATTACHMENT SOUTHERN CALIFORNIA EDISON COMPANY INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1989 SAN ONOFRE NUCLEAR GENERATING STATION UNITS 2 AND 3, DOCKET NOS. 50-361 AND 50-362

### II. Closure Mechanism Failures:

Number of doors inoperable - 14, as follows:

Door Number	Inoperable	<u>Operable</u>
AC-119	04/30/89	12/01/89
AC-108	08/16/89	12/06/89
AC-428	10/10/89	
AC-242	11/02/89	
S2-018	11/19/89	12/08/89
C3-406	11/25/89	12/08/89
FH2-404	11/28/89	
AC-108	11/29/89	12/06/89
S2-016	12/07/89	
S3-016	12/07/89	
AC-402	12/12/89	12/15/89
AC-458	12/12/89	12/15/89
AC-218	12/14/89	
AC-119	12/27/89	

## III. Doors Blocked Open:

Number of doors blocked open - None