

JAN 22 1990

Docket No. 99901145/89-01

Mr. Richard Rush, President
Capital Westward Systems, Incorporated
1290 Santa Fe
San Jacinto, California 92380

Dear Mr. Rush:

This letter addresses the inspection of your facility at San Jacinto, California led by Mr. J. J. Petrosino, of this office on September 11-12, 1989, and the discussions of his findings with you at the conclusion of the inspection.

The inspection was conducted as a result of an October 21, 1988 10 CFR Part 21 report filed by Consumers Power Company regarding non-genuine Masoneilan-Dresser Industries (MD) valve parts supplied by S-W Controls for use at the Palisades nuclear power plant. Areas examined during the NRC inspection and our findings are discussed in the enclosed report. This inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector. Release of this report was delayed during NRC's ongoing review of nonconforming and substandard vendor products.

Within the scope of this inspection, we found no instance where you failed to meet NRC requirements.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room.

Sincerely,

E. William Brach, Chief
Vendor Inspection Branch
Division of Reactor Inspection
and Safeguards
Office of Nuclear Reactor Regulation

Enclosure:
Appendix A-Inspection Report 99901145/89-01

DISTRIBUTION
RIDS CODE IE:09
VIB Reading
DRIS Reading
BKGrimes
EWBrach
GCwalina
JPetrosino (2)

9001310329 900122
PDR QA999 EMV CAPS
99901145 PIC

*ID#R-13
99901145/
89-01*

IE09

OFC	: RIS-1:VIB	: AC:RIS-1:VIB	: C:VIB:DRIS	:	:	:
NAME	: JPetrosino:nrp	: GCwalina	: EWBrach	:	:	:
DATE	: 01/19/90	: 01/19/90	: 01/22/90	:	:	:

OFFICIAL RECORD COPY
Document Name: CAPITAL LETTER

NRC FILE CENTER COPY

JAN 22 1990

Docket No. 99901145/89-01

Mr. Richard Rush, President
Capital Westward Systems, Incorporated
1290 Santa Fe
San Jacinto, California 92380

Dear Mr. Rush:

This letter addresses the inspection of your facility at San Jacinto, California led by Mr. J. J. Petrosino, of this office on September 11-12, 1989, and the discussions of his findings with you at the conclusion of the inspection.

The inspection was conducted as a result of an October 21, 1988 10 CFR Part 21 report filed by Consumers Power Company regarding non-genuine Masoneilan-Dresser Industries (MD) valve parts supplied by S-W Controls for use at the Palisades nuclear power plant. Areas examined during the NRC inspection and our findings are discussed in the enclosed report. This inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector. Release of this report was delayed during NRC's ongoing review of nonconforming and substandard vendor products.

Within the scope of this inspection, we found no instance where you failed to meet NRC requirements.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room.

Sincerely,

E. William Brach, Chief
Vendor Inspection Branch
Division of Reactor Inspection
and Safeguards
Office of Nuclear Reactor Regulation

Enclosure:
Appendix A-Inspection Report 99901145/89-01

DISTRIBUTION
RIDS CODE IE:09
VIB Reading
DRIS Reading
BKGrimes
EWBrach
GCwalina
JPetrosino (2)

OFC	:RIS-1:VIB	:AC:RIS-1:VIB	:C:VIB:DRIS	:	:	:
NAME	:JPetrosino:nrp	:GCwalina	:EWBrach	:	:	:
DATE	:01/19/90	:01/19/90	:01/22/90	:	:	:

OFFICIAL RECORD COPY
Document Name: CAPITAL LETTER