

6400 North Dixie Highway Newport, Michigan 48166 (313) 586-4150

> January 26, 1990 NRC-90-0013

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

References:

- 1) Fermi 2 NRC Docket No. 50-341 NRC License No. NPF-43
- 2) NRC Bulletin 89-02, "Stress Corrosion Cracking of High-Hardness Type 410 Stainless Steel Internal Preloaded Bolting in Anchor Darling Model S350W Swing Check Valves or Valves of Similar Design," dated July 19, 1989

Subject: Detroit Edison Response to NRC Bulletin 89-02

Detroit Edison has reviewed the NRC Bulletin 89-02 (Reference 2) which was received on August 3, 1989. This bulletin requested us to identify and take actions on certain types of swing check valves which may contain Type 410 Stainless Steel bolting material.

In response to this bulletin, Detroit Edison has performed a review of the plant equipment at Fermi 2 to identify whether any swing check valves of concern are installed in the plant. This review has confirmed that Anchor Darling Model S350W swing check valves are not installed at Fermi 2. This review also included valves of similar design with preloaded Type 410 Stainless Steel bolting material, and indicated that no such valves are installed at Fermi 2.

In addition, manufacturers of other safety related check valves were consulted and their documents were reviewed. None of these other manufacturers used preloaded Type 410 Stainless steel bolting material in their check valves supplied to Fermi 2.

As Detroit Edison does not have Anchor Darling Model S350W swing check valves or valves of similar design with preloaded Type 410SS bolting material at Fermi 2, no further actions are required.

USNRC January 26, 1990 NRC-90-0013

If you have any questions, please contact Mr. Girija Shukla at (313) 586-4270.

Sincerely,
BRalph Syl

cc: A. B. Davis

R. W. Defayette

W. G. Rogers

J. F. Stang

USNRC January 26, 1990 NRC-90-0013

I, B. RALPH SYLVIA, do hereby affirm that the foregoing statements are based on facts and circumstances which are true and accurate to the best of my knowledge and belief.

Senior Vice President

On this 26th says that he executed the foregoing as his free act and deed.

> Keren M Leed Notary Public

KAREN M. REED Notary Public, Monroe County, Mich My Commission Expires May 14, 1998