

## 3.2 BASES (cont'd)

High radiation monitors in the main steam line tunnel have been provided to detect gross fuel failure as in the control rod drop accident. With the established setting of 3 times normal background, and main steam line isolation valve closure, fission product release is limited so that 10 CFR 100 guidelines are not exceeded for this accident. Reference Section 14.6.1.2 FSAR. During the Hydrogen Addition Test, the normal background Main Steam Line Radiation Level is expected to increase by approximately a factor of 5 at the peak hydrogen concentration as indicated in note 16, Table 3.1-1. With the hydrogen addition, the fission product release would still be well within the 10 CFR 100 guidelines in the event of a control rod drop accident.

Pressure instrumentation is provided to close the main steam isolation valves in the run mode when the main steam line pressure drops below 825 psig. The reactor pressure vessel thermal transient due to an inadvertent opening of the turbine bypass valves when not in the run mode is less severe than the loss of feedwater analyzed in Section 14.5 of the FSAR, therefore, closure of the main steam isolation valves for thermal transient protection when not in the run mode is not required.

The HPCI high flow and temperature instrumentation are provided to detect a break in the HPCI steam piping. Tripping of this instrumentation results in actuation of HPCI isolation valves. Tripping logic for the high flow is a 1 out of 2 logic.

The trip settings of approximately 300 percent of design flow for this high flow or 40°F above maximum ambient for high temperature are such that uncovering the core is prevented and fission product release is within limits.

The RCIC high flow and temperature instrumentation are arranged the same as that for the HPCI. The trip settings of approximately 300 percent for high flow or 40°F above maximum ambient for temperature are based on the same criteria as the HPCI.

The reactor water cleanup system high temperature instrumentation are arranged similar to that for the HPCI. The trip settings are such that uncovering the core is prevented and fission product release is within limits.

The instrumentation which initiates ECCS action is arranged in a dual bus system. As for other vital instrumentation arranged in this fashion, the specification preserves the effectiveness of the system even during periods when maintenance or testing is being performed. An exception to this is when logic functional testing is being performed.

The control rod block functions are provided to prevent excessive control rod withdrawal so that MCPR does not decrease to the Safety Limit. The trip

9002050353 900124  
 PDR ADDCK 05000333  
 PDC