

February 1, 1990

Docket No. 50-741

Mr. B. Ralph Sylvia  
Senior Vice President - Nuclear  
Operations  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, Michigan 48166

DISTRIBUTION

~~DOCKET FILE~~

NRC & LOCAL PDRs  
PD31 GRAY FILE  
TMURLEY/JSNIEZEK  
JPARTLOW  
CROSSI  
JZWOLINSKI  
PSHUTTLEWORTH

EJORDAN  
GHILL(4)  
ACRS(10)  
GPA/PA  
OC/LFMB  
PSHEA  
JSTANG  
OGC

Dear Mr. Sylvia:

SUBJECT: RELIEF REQUEST FROM THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES (TAC NO. 75027)

By letter dated September 26, 1989, Detroit Edison Company (DECo) requested relief from ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, Winter Addendum 1981. The request specifically requested relief from the exercising frequency requirements of Section XI, Paragraph IWV-3522, for check valves E11-F408 and E11-F409.

The NRC staff has reviewed the DECo request for relief and finds it acceptable as set forth in the enclosed Safety Evaluation.

In accordance with Technical Specification 4.0.5, written relief must be obtained from the Commission pursuant to 10 CFR 50.55a(g)(6)(i), for deviations from Section XI of the ASME Code. The staff's evaluation has determined that the code requirements for the specified testing are impractical, and the granting of the relief is authorized by law, will not endanger life or property or the common defense and security, and is otherwise in the public interest; giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, relief is granted from the requirements of ASME Code, Section XI, 1990 Edition, Winter 1981 Addendum, Subsection IWV, Article IWV-3522 Paragraph 3522 for check valves E11-F408 and E11-F409.

Sincerely,

original signed by

John F. Stang, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

LA/PD31:DRSP  
PSHUTTLEWORTH  
1/18/90

PM/PD31:DRSP  
JSTANG  
1/18/90

(A) PD31:DRSP  
JTHOMA  
1/31/90

OGC  
Mifoung  
1/26/90

EMEB/NRR  
TMARSH  
1/18/90

*Am w/ corrections noted*

*DFG  
1/1*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
February 1, 1990

Docket No. 50-341

Mr. B. Ralph Sylvia  
Senior Vice President - Nuclear  
Operations  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, Michigan 48166

Dear Mr. Sylvia:

SUBJECT: RELIEF REQUEST FROM THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES (TAC NO. 75027)

By letter dated September 26, 1989, Detroit Edison Company (DECo) requested relief from ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, Winter Addendum 1981. The request specifically requested relief from the exercising frequency requirements of Section XI, Paragraph IWV-3522, for check valves E11-F408 and E11-F409.

The NRC staff has reviewed the DECo request for relief and finds it acceptable as set forth in the enclosed Safety Evaluation.

In accordance with Technical Specification 4.0.5, written relief must be obtained from the Commission pursuant to 10 CFR 50.55a(g)(6)(i), for deviations from Section XI of the ASME Code. The staff's evaluation has determined that the code requirements for the specified testing are impractical, and the granting of the relief is authorized by law, will not endanger life or property or the common defense and security, and is otherwise in the public interest; giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, relief is granted from the requirements of ASME Code, Section XI, 1990 Edition, Winter 1981 Addendum, Subsection IWV, Article IWV-3522, Paragraph 3522 for check valves E11-F408 and E11-F409.

Sincerely,

A handwritten signature in cursive script, appearing to read "John F. Stang".

John F. Stang, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. B. Ralph Sylvia  
Detroit Edison Company

Fermi-2 Facility

Ronald C. Callen  
Adv. Planning Review Section  
Michigan Public Service Commission  
6545 Mercantile Way  
P. O. Box 30221  
Lansing, Michigan 48909

Ms. Lynn Goodman  
Supervisor - Licensing  
Detroit Edison Company  
Fermi Unit 2  
6400 North Dixie Highway  
Newport, Michigan 48166

John Flynn, Esq.  
Senior Attorney  
Detroit Edison Company  
2000 Second Avenue  
Detroit, Michigan 48226

Nuclear Facilities and Environmental  
Monitoring Section Office  
Division of Radiological Health  
P. O. Box 30035  
Lansing, Michigan 48909

Mr. Thomas Randazzo  
Director, Regulatory Affairs  
Detroit Edison Company  
Fermi Unit 2  
6400 North Dixie Highway  
Newport, Michigan 48166

Mr. Walt Rogers  
U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
6450 W. Dixie Highway  
Newport, Michigan 48166

Monroe County Office of Civil  
Preparedness  
963 South Raisinville  
Monroe, Michigan 48161

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137