

APPENDIX B

NOTICE OF DEVIATION

Omaha Public Power District
Fort Calhoun Station

Docket: 50-285
Operating License: DPR-40

A deviation from your commitments to the NRC was identified during the NRC inspection conducted October 23 through November 9, 1989. The deviation involved a failure to validate new and revised emergency operating procedures (EOPs) in accordance with the requirements of the Fort Calhoun Station procedure generation package. In accordance with the "General Statement of Policy for NRC Enforcement Actions," Title 10 of the Code of Federal Regulations (10 CFR) Part 2, Appendix C (1989) (Enforcement Policy), the deviation is listed below:

In a letter dated March 1, 1985, the licensee committed to upgrade existing and revised EOPs in accordance with a procedure generation package (PGP). Part 5 of this PGP requires that EOPs be initially validated in the control room mockup facility.

Contrary to the above, the EOP validation process did not include use of the control room mockup facility. (285/8940-02)

Omaha Public Power District is hereby requested to submit a written statement to this office, within 30 days of the date of the letter transmitting this notice, including for each deviation (1) the reason for the deviation, if admitted; (2) the corrective steps that have been taken and the results achieved; (3) the corrective steps that will be taken to avoid further deviations; and (4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this 30th day of January 1990

9002070170 900130
PDR ADOCK 05000285
Q PIC