

Docket No. 50-285

Mr. Kenneth J. Morris
Division Manager - Nuclear Operations
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Norris:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 124 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC NO. 75376)

The Commission has issued the enclosed Amendment No. 124 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated December 1, 1989.

The amendment adds an operating mode number for each operating mode in Table 3-4 of the Technical Specifications. In addition in the Refueling Shutdown mode, when fuel is in the core, a water sampling and analysis is required. However, when the total core has been off-loaded, this amendment incorporates that water testing and analysis is not required since there is no fuel in the core.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

original signed by:

Anthony Bournia, Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 124 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

~~Docket File~~

G. Holahan
A. Bournia (2)
G. Hill (4)
ACRS (10)

NRC PDR
ADR4
OGC-Rockville
Wanda Jones
GPA/PA

Local PDR
F. Hebdon
D. Hagan
J. Calvo
ARM/LFMB

PD4 Reading
P. Noonan
E. Jordan
PD4 Plant File

*See previous concurrence
DOCUMENT NAME: FT. CALHOUN 75376

*PD4/LA
PNoonan
01/11/90

*PD4/PM
ABournia:
01/11/90

*OGC-Rockville
01/23/90

PD4/DJ
FHebdon
01/31/90

DF01
11

9002080277 900131
PDR ADDCK 05000285
PDC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 31, 1990

Docket No. 50-285

Mr. Kenneth J. Morris
Division Manager - Nuclear Operations
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Morris:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO.124 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC NO. 75376)

The Commission has issued the enclosed Amendment No. 124 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated December 1, 1989.

The amendment adds an operating mode number for each operating mode in Table 3.4 of the Technical Specifications. In addition, in the Refueling Shutdown mode, when fuel is in the core, a water sampling and analysis is required. However, when the total core has been off-loaded, this amendment incorporates that this water testing and analysis is not required since there is no fuel in the core.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Anthony Bournia

Anthony Bournia, Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.124 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Kenneth J. Morris
Omaha Public Power District

Fort Calhoun Station
Unit No. 1

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, D.C. 20036

Mr. Jack Cansen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68008

Mr. Phillip Harrell, Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Harold Borchert, Director
Division of Radiological Health
Department of Health
301 Centennial Mall, South
P.O. Box 95007
Lincoln, Nebraska 68509

Mr. G. R. Peterson, Manager
Fort Calhoun Station
P. O. Box 399
Fort Calhoun, Nebraska 68023