



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OMAHA PUBLIC POWER DISTRICT

DOCKET NO. 50-285

FORT CALHOUN STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 124
License No. DPR-40

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Omaha Public Power District (the licensee) dated December 1, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9002080292 900131
PDR ADOCK 050-0285
P FDC


2. Accordingly, Facility Operating License No. DPR-40 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR-40 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.124, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Frederick J. Heddon, Director
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Charges to the Technical
Specifications

Date of Issuance: January 31, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 124

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

3-18
3-19

Insert Pages

3-18
3-19

TABLE 3-4

MINIMUM FREQUENCIES FOR SAMPLING TESTS

	<u>Type of Measurement and Analysis</u>	<u>Sample and Analysis Frequency</u>
1. Reactor Coolant		
(a) Power Operation (Operating Mode 1)	(1) Gross Radioactivity (Gamma emitters)	1 per 3 days
	(2) Isotopic Analysis for DOSE EQUIVALENT I-131	(i) 1 per 14 days
		(ii) 1 per 8 hours ⁽¹⁾ whenever the radio- activity exceeds 1.0 Ci/gm DOSE EQUIVALENT I-131.
		(iii) 1 sample between 2-8 hours following a thermal power change exceeding 15% of the rated thermal power change exceeding 15% of the rated thermal power within a 1-hour period.
	(3) \bar{E} Determination	1 per 6 months ⁽²⁾
	(4) Dissolved oxygen and chloride	1 per 3 days
(b) Hot Standby (Operating Mode 2)	(1) Gross Radioactivity (Gamma emitters)	1 per 3 days
	(2) Isotopic Analysis for DOSE EQUIVALENT I-131	(i) 1 per 8 hours ⁽¹⁾ whenever the radio- activity exceeds 1.0 Ci/gm DOSE EQUIVALENT I-131.
		(ii) 1 sample between 2-8 hours following a thermal power change exceeding 15% of the rated thermal power within a 1-hour period.
Hot Shutdown (Operating Mode 3)	(3) Dissolved oxygen and chloride	1 per 3 days

TABLE 3-4 (Continued)

MINIMUM FREQUENCIES FOR SAMPLING TESTS

	<u>Type of Measurement and Analysis</u>	<u>Sample and Analysis Frequency</u>
1. Reactor Coolant (Continued)		
(c) Cold Shutdown (Operating Mode 4)	(1) Chloride	1 per 3 days
(d) Refueling Shutdown (Operating Mode 5)	(1) Chloride	1 per 3 days ⁽³⁾
	(2) Boron Concentration	1 per 3 days ⁽³⁾
2. SIRW Tank	Boron Concentration	1 per 31 days
3. Concentrated Boric Acid Tanks	Boron Concentration	1 per 31 days
4. SI Tanks	Boron Concentration	1 per 31 days
5. Spent Fuel Pool	Boron Concentration	1 per 31 days

(1) Until the radioactivity of the reactor coolant is restored to $\leq 1 \mu\text{Ci/gm}$ DOSE EQUIVALENT I-131.

(2) Sample to be taken after a minimum of 2 EFPD and 20 days of power operation have elapsed since reactor was subcritical for 48 hours or longer.

(3) Boron and chloride sampling/analyses are not required when the core has been off-loaded.