

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company  
Vogtle Units 1 and 2

Docket Nos. 50-424 and 50-425  
License Nos. NPF-68 and NPF-81

During the Nuclear Regulatory Commission (NRC) inspection conducted on December 2, 1989 - January 5, 1990 a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1989), the violation is listed below.

10 CFR Part 50, Appendix B, Criterion X, the licensee's accepted Quality Assurance Program, and the Final Safety Analysis Report (FSAR), Section 17.2.10, require that a program for the inspection of activities affecting quality be established and executed by, or for, the organization performing the activity to verify conformance with the documented instructions, procedures, and drawings for accomplishing the activity.

ANSI N45.2.4, 1972 (also designated as IEEE Standard 336-1971), committed to in FSAR Chapter 1.9.30, states that checks and inspections shall be performed to verify the operational readiness and completeness of components and systems.

Plant procedure 85024-C, Electrical Inspection, implements inspection activities by providing for the establishment and control of Quality Control hold points in work activities. Procedure step 4.5.3 requires hold points for verifying that battery terminations are tightened or torqued to the values listed in procedure 27915-C.

Contrary to the above, on December 29, 1989, the inspector identified that checks and inspections were not performed to verify the operational readiness and completeness of a safety-related system while conducting repairs on the class 1E 125V DC power system. Plant procedure 85024-C was not followed in that Quality Control hold points were not established for Maintenance Work Order 18905060, which was implementing a temporary modification involving cell jumping. Further review determined that hold points were not being established for any work orders which implemented temporary modifications.

This is a severity level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Georgia Power Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, Vogtle, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of


9002150022 900201  
PDR ADDOCK 03000424  
Q PIC

Georgia Power Company  
Vogtle Units 1 and 2

2 Docket Nos. 50-424 and 50-425  
License Nos. NPF-68 and NPF-81

Violation" and should include: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION



Alan R. Herdt, Chief  
Reactor Projects Branch 3  
Division of Reactor Projects

Dated at Atlanta, Georgia  
this 01 day of Feb. 1990