

47

Ms. Ida M. Ustad
Office of General Services
Administration Acquisition
Policy and Regulation
18th & F Street N.W.
Room 4026
Washington, D.C. 20405

Dear Ms. Ustad:

SUBJECT: POTENTIALLY DEFECTIVE REFURBISHED ELECTRICAL EQUIPMENT

In our continuing investigation to identify the circumstances under which defective refurbished electrical equipment may have been supplied to nuclear power plants, we have discovered additional invoices and orders that specify your agency as the customer. Copies of these invoices and orders are attached for your information and use. These documents result from our review of a selection of records spanning the last three or four years from companies supplying molded case circuit breakers listed in NRC Information Notice 88-46, a copy of which is enclosed for your information. As other records come to light, we will provide copies to your office as appropriate.

If there is any additional information you require, please call me or Mr. Walter Haass at (301) 492-3219.

Sincerely,

Original signed by
Brian K. Grimes

Brian K. Grimes, Director
Division of Reactor Inspection and Safeguards
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Invoices/Orders
- 2. NRC Information Notice 88-46 and Supplements 1 and 2

DISTRIBUTION: (w/o enclosures)

Central Files KEccelston
 VIB Reading (w/enclosures) WHutchinson, OI
 DRIS Reading (w/enclosures) WMcNulty, OI-RV (w/enclosures)
 JSniezek PDR
 FMiraglia
 BGrimes
 EBrach
 GCwalina
 WHaass (w/enclosures)
 JStone

*SEE PREVIOUS CONCURRENCE PAGE.

2/46

OFC	:VIB:DRIS	:SC:VIB:DRIS	:BC:VIB:DRIS	:D:DRIS	:	:	:
NAME	:WPHaass:jh*	:GCWalina*	:EBrach*	:BKGrimes*	:	:	:
DATE	:04/03/89	:04/05/89	:04/05/89	:04/05/89	:	:	: