Docket No. 50-416

Mr. W. T. Cottle Vice President, Nuclear Operations System Energy Resources, Inc. Post Office Box 469 Port Gibson, Mississippi 39150

DISTRIBUTION Docket File LKintner NRC & Local PDRs OGC PD21 R/F EJordan SVarga CWHeh! ACRS(10) ETourigny

Dear Mr. Cottle:

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 (GGNS-1), DRYWELL PRESSURE NARROW RANGE INSTRUMENT TO MEET REGULATORY GUIDE 1.97 REQUIREMENTS (TAC NO. 69057)

By letter dated July 22, 1988, System Energy Resources, Inc. (the licensee) requested the NRC to review its position statement regarding a deviation from the guidelines of Regulatory Guide 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident" (RG 1.97). The deviation is use of a containment-todrywell differential pressure instrument with a range of +2 psid to -2 psid and a wide range drywell pressure instrument with a range of -10 to 40 psig instead of the RG 1.97 recommended drywell pressure instrument with a range of -5 psig to 3 psig.

The NRC staff has reviewed this requested deviation. The staff's Safety Evaluation is enclosed. We conclude that the licensee has adequately justified this deviation from the RG 1.97 recommendation.

The licensee has committed to make changes in the Updated Final Safety Analysis Report (UFSAR) to reflect use of the differential pressure instrument for post-accident monitoring. The implementation date for UFSAR changes and any emergency operating procedure changes is December 31, 1990.

Sincerely,

Original Signed By:

Lester L. Kintner, Senior Project Manager Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

9002220161 900213 PDR ADDCK 05000416

Enclosure: Safety Evaluation

cc w/enclosure: See next page

| | | | | ST: (A)D: PD11- | | |
|------|-----------|-----------|-----------|-----------------|------|--|
| | | | . / // | EGTourigny | | |
| DATE | :024/2490 | :02/12/90 | 81/12/190 | :01//3/90 | | |