



Consumers  
Power

**POWERING  
MICHIGAN'S PROGRESS**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 786-0550

February 13, 1990

Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 - BIG ROCK POINT PLANT -  
REQUEST FOR ADDITIONAL INFORMATION CONCERNING GENERIC LETTER 89-04

NRC letter dated December 21, 1989, requested Consumers Power Company to provide written confirmation of completion dates for commitments made in response to Generic Letter 89-04. Specifically completion dates were requested for Items 3 and 6 outlined in Consumers Power Company's response dated September 29, 1989. Items 3 and 6, as outlined below, will be completed by March 1, 1990.

Item 3

A procedure shall be written to test the demineralized water supply check valve VMU-300 with full accident flow.

Item 6

The limiting stroke time values for CV-4094, CV-4095, CV-4096, CV-NC11, CV-NC11A, CV-NC12, CV-NC12A, MO-7053, and MO-7063 shall be changed in accordance with Position 5 of Attachment 1 to Generic Letter 89-04.

J Daniel Eddy  
Plant Licensing Engineer

CC Administrator, Region III, USNRC  
NRC Resident Inspector - Big Rock Point

OC0290-0253-NL04

9002230134 900213  
PDR ADOCK 05000155  
P PNU

A CMS ENERGY COMPANY

A046  
1/0