



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 151  
License No. DPR-59

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Power Authority of the State of New York (the licensee) dated May 31, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:


9002270077 900215  
PIR ADOCK 05000333  
P PDC

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 151, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - 1/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: February 15, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 151

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Pages

115a

116

127

Insert Pages

115a

116

127

JAFNPP

3.5 (cont'd)

5. All recirculation pump discharge valves shall be operable prior to reactor startup (or closed if permitted elsewhere in these specifications).
6. If the requirements of 3.5.A cannot be met, the reactor shall be placed in the cold condition within 24 hrs.

B. Containment Cooling Mode (of the RHR System)

1. Both subsystems of the containment cooling mode, each including two RHR and two RHRSW pumps, shall be operable whenever there is irradiated fuel in the reactor vessel, prior to startup from a cold condition, and reactor coolant temperature  $>212^{\circ}\text{F}$  except as specified below:

4.5 (cont'd)

5. All recirculation pump discharge valves shall be tested for operability any time the reactor is in the cold condition exceeding 48 hours, if operability tests have not been performed during the preceding 31 days.

B. Containment Cooling Mode (of the RHR System)

1. Subsystems of the containment cooling mode shall be demonstrated operable by performing:
  - a. a pump operability and flow rate test on the RHR pumps per Surveillance Requirement 4.5.A.3.
  - b. a monthly operability test of the RHR containment cooling mode motor operated valves.
  - c.1 a monthly operability test on the RHRSW pumps and associated motor operated valves.
  - c.2 a flow rate test at least once every 3 months and verifying a flow rate of 4000 gpm for each RHRSW pump and a total flow rate of 8000 gpm for two RHRSW pumps operating in parallel.
  - d. During each five-year period, an air test shall be performed on the containment spray headers and nozzles.

JAFNPP

3.5 (cont'd)

2. Should one RHR pump of the components required in 3.5.B.1 above be made or found inoperable, continued reactor operation is permissible only during the succeeding 30 days provided that during such 30 days all remaining components of the containment cooling mode are operable.
3. Should one of the containment cooling subsystems become inoperable or should two of the RHRSW pumps become inoperable, continued reactor operation is permissible for a period not to exceed 7 days.
4. If the requirements of 3.5.B.2 or 3.5.B.3 cannot be met, the reactor shall be placed in a cold condition within 24 hr.
5. Low power physics testing and reactor operator training shall be permitted with reactor coolant temperature <212°F with an inoperable component(s) as specified in 3.5.B above.

4.5 (cont'd)

2. When it is determined that one RHRSW pump of the components required in 3.5.B.1 above is inoperable, the remaining components of the containment cooling mode subsystems shall be verified to be operable immediately and daily thereafter.
3. When one containment cooling subsystem loop becomes inoperable, the redundant containment cooling subsystem loop shall be verified to be operable immediately and daily thereafter. When two of the RHRSW pumps become inoperable, the remaining components of the containment cooling subsystem(s) shall be demonstrated to be operable immediately and daily thereafter.

## 3.5 BASES (cont'd)

B. Containment Cooling Mode (of the RHR System)

The containment heat removal portion of the LPCI/containment spray mode is provided to remove heat energy from the containment in the event of a loss-of-coolant accident. For the flow specified, the containment long-term pressure is limited to less than 8 psig and, therefore, is more than ample to provide the required heat removal capability.

Each subsystem of the containment cooling mode (of the RHR System) consists of two RHR Pumps, two RHR service water pumps, one heat exchanger and a flowpath capable of recirculating water from the suppression pool through the heat exchanger and back to primary containment. Either subsystem is capable of performing the containment cooling function. Loss of one RHR service water pump does not seriously jeopardize the containment cooling capability as any two of the remaining three pumps can satisfy the cooling requirements. Since there is some redundancy left, a thirty-day repair period is adequate. Loss of one subsystem of the containment cooling mode leaves one remaining system to perform the containment cooling function. The operable system is verified to be operable each day when the above condition occurs. Based on the fact that when one containment cooling subsystem becomes inoperable only

one system remains, a seven day repair period was specified.

Low power physics testing and reactor operator training with inoperable components will be conducted only when the containment cooling mode of RHR is not required for the safety of the plant.

Calculations have been made to determine the effects of the design basis LOCA while conducting low power physics testing or operator training at or below 212°F. The results of these conservative calculations show that the suppression pool water temperature will not exceed 170°F. Therefore LPCI and Core Spray Systems will not be adversely affected by the postulated LOCA.