

Docket No. 50-341

DISTRIBUTION

Docket file

Mr. B. Ralph Sylvia
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

NRC & Local PDRs
PD31 R/F
JZwolinski
PShuttleworth
Wanda Jones
DHagan

JStang
OGC
EJordan
ACRS (10)
GHill(4)
GPA/PA
ARM/LFMB

Dear Mr. Sylvia:

SUBJECT: RELIEF REQUEST TO THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES (TAC NO. 73624)

By letter dated June 21, 1989, Detroit Edison Company (DECo) requested relief from ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, Winter Addendum 1981. The request specifically requested relief for all pumps in the program and the Drywell-Torus vacuum relief valves. By letter dated September 8, 1989, the licensee withdrew all the relief requests concerning pumps in the June 21, 1989, relief request.

The NRC staff has reviewed the DECo request for relief for the Drywell-Torus vacuum relief valves and find it acceptable as set forth in the enclosed Safety Evaluation.

In accordance with Technical Specification 4.0.5, written relief must be obtained from the Commission pursuant to 10 CFR 50.55a(g)(6)(i), for deviations from Section XI of the ASME code. The staff has determined that the code requirements for the specified testing of valves are impractical, and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest, giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, relief is granted from the requirements of ASME Code, Section XI, 1980 Edition, Winter 1981 Addendum, Subsection IWV, Article IWV-3000, Paragraphs 3426 and 3427, for the Drywell-Torus vacuum relief valves.

Sincerely,

John C. Thoma for
John F. Stang, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page
[FERMI TAC 73624]

*See previous concurrence

*LA/PD31:DRSP *PM/PD31:DRSP
PShuttleworth JStang:cr
12/15/89 12/18/89

02/16/90 307
*D/PD31:DRSP
JThoma
12/20/89

*NRR/EMEB *OGC
TMarsh
1/18/90 1/30/90

DF01
1/1

December 21, 1989

Docket No. 50-341

Mr. B. Ralph Sylvia
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION

Docket file	JStang
NRC & Local PDRs	OGC
PD31 Plant Gray	EJordan
JZwolinski	ACRS (10)
PShuttleworth	GHill(4)
Wanda Jones	GPA/PA
DHagan	ARM/LFMB

Dear Mr. Sylvia:

SUBJECT: RELIEF REQUEST TO THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES (TAC NO. 73624)

By letter dated June 21, 1989, Detroit Edison Company (DECo) requested relief from ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, Winter Addendum 1981. The request specifically requested relief for all pumps in the program and the Drywell-Torus vacuum relief valves. By letter dated September 8, 1989, the licensee withdrew all the relief requests concerning pumps in the June 21, 1989, relief request.

The NRC staff has reviewed the DECo request for relief for the Drywell-Torus vacuum relief valves and find it acceptable as set forth in the enclosed Safety Evaluation.

In accordance with Technical Specification 4.0.5, written relief must be obtained from the Commission pursuant to 10 CFR 50.55a(g)(6)(i), for deviations from Section XI of the ASME code. The staff has determined that the code requirements for the specified testing of valves are impractical, and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest, giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, relief is granted from the requirements of ASME Code, Section XI, 1980 Edition, Winter 1981 Addendum, Subsection IWV, Article IWV-3000, Paragraphs 3426 and 3427, for the Drywell-Torus vacuum relief valves.

Sincerely,

original signed by

John F. Stang, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

[FERMI TAC 73624]

LA/PD31:DRSP *med*
PShuttleworth
12/15/89

PM/PD31:DRSP
JStang:cr
12/16/89

D/PD31:DRSP
JThomas
12/20/89

NRR/EMEB
TMarsh
~~12/18/89~~
1/18/90

OGC *llh*
mlj
~~12/18/89~~
1/30/90



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
February 16, 1990

Docket No. 50-341

Mr. B. Ralph Sylvia
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Sylvia:

SUBJECT: RELIEF REQUEST TO THE INSERVICE TESTING PROGRAM FOR PUMPS AND
VALVES (TAC NO. 73624)

By letter dated June 21, 1989, Detroit Edison Company (DECo) requested relief from ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, Winter Addendum 1981. The request specifically requested relief for all pumps in the program and the Drywell-Torus vacuum relief valves. By letter dated September 8, 1989, the licensee withdrew all the relief requests concerning pumps in the June 21, 1989, relief request.

The NRC staff has reviewed the DECo request for relief for the Drywell-Torus vacuum relief valves and find it acceptable as set forth in the enclosed Safety Evaluation.

In accordance with Technical Specification 4.0.5, written relief must be obtained from the Commission pursuant to 10 CFR 50.55a(g)(6)(i), for deviations from Section XI of the ASME code. The staff has determined that the code requirements for the specified testing of valves are impractical, and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest, giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, relief is granted from the requirements of ASME Code, Section XI, 1980 Edition, Winter 1981 Addendum, Subsection IWV, Article IWV-3000, Paragraphs 3426 and 3427, for the Drywell-Torus vacuum relief valves.

Sincerely,

John O. Thoma for

John F. Stang, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Mr. B. Ralph Sylvia
Detroit Edison Company

Ferri-2 Facility

cc:

Mr. Ronald C. Callen
Adv. Planning Review Section
Michigan Public Service Commission
6545 Mercantile Way
P. O. Box 30221
Lansing, Michigan 48909

Ms. Lynn Goodman
Supervisor - Licensing
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

John Flynn, Esq.
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

Mr. Thomas Randazzo
Director, Regulatory Affairs
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

Mr. Walt Rogers
U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137