

FEB 15 1990

Docket No. 50-334
50-412

Duquesne Light Company
ATTN: Mr. J. D. Sieber
Vice President, Nuclear Group
Post Office Box 4
Shippingport, Pennsylvania 15077

Gentlemen:

SUBJECT: Combined Inspection Report Nos. 50-334/89-23 and 50-412/89-22

This refers to the routine resident safety inspection by Mr. P. Wilson at the Beaver Valley Power Station in Shippingport, Pennsylvania. The reporting period covers the time from November 18 - December 31, 1989. The inspection consisted of document reviews, interviews and observation of activities. The findings were summarized and discussed with you and members of your staff after of the inspection.

Based on the results of this inspection, it appears that in one instance, your activities were not conducted in full compliance with NRC requirements. Failure to follow your written procedures apparently led to a Unit 1 Safety Injection actuation while that unit was shut down. Please respond to this matter in accordance with the enclosed Appendix A.

This letter also acknowledges receipt of your letter dated December 15, 1989 in response to our letter dated November 15, 1989 addressing your corrective action associated with excessive overtime by plant staff. Thank you for informing us of your corrective and preventive actions. These items will be examined during a future inspection of your licensed program.

I appreciate your cooperation in these matters.

Sincerely,

Edward C. Wenzinger, Chief
Projects Branch No. 4
Division of Reactor Projects

Enclosures:

1. Appendix A, Notice of Violation
2. NRC Region I Combined Inspection Report Nos. 50-334/89-23 and 50-412/89-22

OFFICIAL RECORD COPY

CIR BV 89-23/22 - 0001.0.0
02/13/90

9002270379 900215
PDR ADUCK 05000334
Q PDC

1E01
1/11

FEB 15 1990

cc w/encls:

J. J. Carey, Executive Vice President, Operations
J. O. Crockett, General Manager, Corporate Nuclear Services
W. S. Lacey, General Manager, Nuclear Operations Services
T. P. Noonan, General Manager, Nuclear Operations
N. R. Tonet, Manager, Nuclear Engineering
S. C. Fenner, Manager, Quality Assurance
K. D. Grada, Manager, Nuclear Safety
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o enclosures)
E. E. Collins, DRP
N. F. Dudley, DRP
P. S. Tam, LPM, NRR
R. J. Bores, DRSS

DRP:RI
PWilson/pj
1/12/90

DRP:RI
ECollins
2/15/90

DRP:RI
EWenzinger
2/15/90