

APPENDIX A

NOTICE OF VIOLATION

Connecticut Yankee Atomic Power Company

Docket No. 50-213

Based on the results of an NRC inspection conducted on April 28 and 29 and May 5-June 7, 1980, it appears that one of your activities was not conducted in full compliance with conditions of your NRC Facility License No. DPR-61 as indicated below. This item is an infraction.

Environmental Technical Specification (ETS) 2.4.3.1(1) limits the release rate of noble gases from the site based upon the beta and gamma energies of the isotopic mix being released.

Contrary to the above, on May 28, 1980, a noble gas mixture was released which exceeded the ETS 2.4.3.1(1) limit by a factor of 1.26 for a period of approximately five minutes.