

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

BEST ESTIMATE POST TEST PREDICTION

FOR LOFT NUCLEAR EXPERIMENT L3-6

by

LILIANE SCHOR

JAMES LOOMIS

AUSAF HUSAIN

8103090330

## Table of Contents

	Page
List of Figures	2
List of Tables	4
1.0 Introduction	5
2.0 Model Description for RELAP4/Mod3	6
2.1 Calculation Overview	6
2.2 Blowdown Model	6
3.0 Comparison of Experimental Results in the RELAP4/Mod3 Post Test Calculation	8
3.1 Pressure	9
3.2 Differential Pressure	9
3.3 Fluid Temperature	9
3.4 Density	10
3.5 Mass Flow Rate	10
3.6 Liquid Mass in the System	10
3.7 Liquid Levels	10
4.0 Reference	12
5.0 Appendix A	55

## List of Figures

	Page
Figure 1.	RELAP 4 LOFT Nodalization 16
Figure 2.	Intact Loop Hot Leg Pressure (0 - 200 sec) 17
Figure 3.	Pressurizer Pressure (0 - 200 sec) 18
Figure 4.	Pressure in Downcomer (0 - 200 sec) 19
Figure 5.	Pressure in Broken Loop Cold Leg (0 - 200 sec) 20
Figure 6.	Pressure in Broken Loop Hot Leg (0 - 200 sec) 21
Figure 7.	Pressure in Steam Generator Dome (0 - 200 sec) 22
Figure 8.	Density in Broken Loop Cold Leg (0 - 200 sec) 23
Figure 9.	Density in Broken Loop Hot Leg (0 - 200 sec) 24
Figure 10.	Density in Intact Loop Hot Leg (0 - 200 sec) 25
Figure 11.	Density in Intact Loop Cold Leg (0 - 200 sec) 26
Figure 12.	Density at Steam Generator Exit Intact Loop (0 - 200 sec) 27
Figure 13.	Differential Pressure Across Pumps (0 - 200 sec) 28
Figure 14.	Differential Pressure Across Steam Generator (0 - 200 sec) 29
Figure 15.	Differential Pressure Across Reactor Vessel (0 - 200 sec) 30
Figure 16.	Temperature in Intact Loop Hot Leg (0 - 200 sec) 31
Figure 17.	Temperature at Inlet and Outlet Plenums in Steam Generator, Intact Loop (0 - 200 sec) 32
Figure 18.	Level in Pressurizer (0 - 200 sec) 33
Figure 19.	Intact Loop Hot Leg Pressure (0 - 2400 sec) 34
Figure 20.	Pressurizer Pressure (0 - 2400 sec) 35
Figure 21.	Pressure in Downcomer (0 - 2400 sec) 36
Figure 22.	Pressure in Broken Loop Cold Leg (0 - 2400 sec) 37
Figure 23.	Pressure in Broken Loop Hot Leg (0 - 2400 sec) 38
Figure 24.	Pressure in Steam Generator Dome (0 - 2400 sec) 39
Figure 25.	Density in Broken Loop Cold Leg (0 - 2400 sec) 40
Figure 26.	Density in Broken Loop Hot Leg (0 - 2400 sec) 41
Figure 27.	Density in Intact Loop Hot Leg (0 - 2400 sec) 42
Figure 28.	Density in Intact Loop Cold Leg (0 - 2400 sec) 43

## List of Figures

		Page
Figure 29.	Differential Pressure Across Steam Generator (0 - 2400 sec)	44
Figure 30.	Differential Pressure Across Reactor Vessel (0 - 2400 sec)	45
Figure 31.	Differential Pressure Across Pumps (0 -2400 sec)	46
Figure 32.	Liquid Level in Core (0 - 2400 sec)	47
Figure 33.	Liquid Mass in Reactor Vessel (0 - 2400 sec)	48
Figure 34.	Liquid Mass in Steam Generator, Primary Side (0 - 2400 sec)	49
Figure 35.	Liquid Mass in Hot and Cold Leg, Intact Loop (0 - 2400 sec)	50
Figure 36.	Liquid Mass in Broken Loop (0 - 2400 sec)	51
Figure 37.	Temperature in Intact Loop Hot Leg (0 - 2400 sec)	52
Figure 38.	Temperature at Inlet and Outlet Plenums in Steam Generator (0 - 2400 sec)	53
Figure 39.	Break Flow (0 - 2400 sec)	54



## List of Tables

		Page
Table 1	RELAP4 Blowdown System Model Description	13
Table 2	Initial Conditions for LOCE L3-6	14
Table 3	Chronology of Events Experimental Data Versus Test Prediction	15

BEST ESTIMATE POST TEST PREDICTION  
FOR LOFT NUCLEAR EXPERIMENT L3-6

1.0 Introduction

This document contains the Yankee Atomic Electric Company post test prediction of the coupled system thermal-hydraulic response for the Loss of Fluid Test (LOFT) System during Loss of Coolant Experiment (LOCE) L3-6.

The RELAP4/Mod3[1] and RELAP5/Mod[2] computer codes were used to calculate the thermal-hydraulic behavior in the LOFT system during LOCE L3-6.

The analytical models used to perform this prediction should be recognized as "best estimate" predictive mechanisms.

## 2.0 Model Description for RELAP4/Mod3

### 2.1 Calculational Overview

The code used for the post test analysis presented in this section of the report is RELAP4/Mod3 version YAEC-05B.

Two update changes were made to the code; one to represent the behavior of the LOFT steam flow control valve in the secondary side of the steam generator, another to allow the use of different contraction coefficients for subcooled and two-phase critical flow.

A listing of the input description and update diagrams is given in Appendix A.

### 2.2 Blowdown Model

The RELAP4/Mod3 LOFT system model used to calculate blowdown during LOCE L3-6 is described in this section.

A schematic of the LOFT system is given in Figure 1.

The model used for LOCE L3-6 is a modification of the EG&G LOFT L3-1 model (Reference 3). The following changes were made to the base nodalization (Reference 3) for this analysis:

1. The break location was moved from the broken loop cold leg to the intact loop cold leg and the new break spool piece was modeled.
2. The accumulator was removed.
3. Primary coolant injection flows were added to properly account for the system mass inventory.

4. For modeling two-phase degradation behavior, data that describe the pump two-phase head and torque characteristics are needed. The new LOFT head and torque multipliers based on experimental data, presented by EG&G in Reference 4 has been used.
5. A new volume (33) representing the pipe which connects the steam generator secondary steam dome to the steam relief valve was added to the nodalization of the steam generator secondary. Complete phase separation was used in this volume.
6. Two junctions (45 and 43) instead of one were used to represent the feedwater inlet and the auxiliary feedwater inlet, respectively.
7. Six junctions were used to model the leak through the steam flow relief valve; one before the valve cycled (junction 41) and a combination of 5 valves and 5 trips throughout the remainder of the transient.
8. High pressure injection system (HPSI) location was moved from the intact cold leg into the downcomer.
9. Only one volume was used to represent the core. A bypass volume representing 5% of the total core flow was added to the reactor vessel.
10. Phase separation was removed from all volumes except reactor vessel volumes, pressurizer and steam generator secondary.
11. The critical flow models specified for the junctions were the Henry Fauske model for the subcooled region and Moody model for the two phase region. Multipliers of 1.0 and 0.6 were applied for subcooled and saturated break flow, respectively.

A brief description of each control volume is given in Table 1. In specifying the system initial conditions, i.e., pressure, temperature, flow and power, the actual initial conditions of the LOFT facility at the test initiation were input to RELAP4 model within the bounds of measurement error and heat balance consistency (5).

A list of measured versus RELAP4 initial conditions are given in Table 2.

### 3.0 Comparison of Experimental Results in the RELAP4/Mode 3 Post Test Calculations.

This section presents comparisons between the experimental data provided by EG&G (Reference 6) and the post test predictions calculated by RELAP4. Short term (0 to 200 sec) and long term (0 to 2400 sec) results are presented. The selection of the parameters provided in this report was based on the availability and quality of the data, the correspondence between modeled volumes and physical locations of measurements, and the overall importance of the parameter in assessing the capability of the RELAP4 code.

Some results are presented without comparison with experimental data when those data were unavailable.

Table 3 presents measured versus predicted (RELAP4) sequence of events for experiment L3-6.

#### 3.1 Pressure

Comparison between calculated versus measured LOFT pressures are presented in Figures 2 through 7 for short-term plots (0 - 200 sec) and in Figures 19 through 24 for long term plots (0-2400 sec).

Good agreement is achieved between the calculated pressure in the primary system and the measured one up to 945 seconds. After 945 seconds, RELAP4 under predicts the data. At 1300 seconds, RELAP 4 predicts a 30 psia repressurization of the system. This is due to a change in break flow and break quality. Following the repressurization, the pressure in the primary system drops again until it reaches 330 psia at 2031.5 seconds.

In the secondary side of the steam generator, by carefully monitoring the leak through the steam relief valve, good agreement is achieved until 945 seconds. At 945 seconds, the pressure in the secondary side of the steam generator exceeds the primary system pressure. In the LOFT experiment, the two systems become decoupled at this point while in the RELAP4 calculation, the secondary pressure follows the primary pressure.

### 3.2 Differential Pressure

Differential pressures across core, pump, and steam generator intact loop are presented in Figures 13 through 15 for short (0 - 200 sec) and in Figures 29 through 31 for long term (0 - 2400 sec) results.

### 3.3 Fluid Temperature

Temperatures in intact loop hot leg and temperatures in the steam generator inlet and outlet plenums are presented in Figures 16 and 17.

The LOFT system reached saturation at the cold leg at 40 seconds while RELAP4 predicted saturation in the cold leg at 90 seconds in the transient. After reaching saturation, RELAP4 predicted the LOFT data well until 945 seconds. The temperatures are underpredicted (Figures 37 and 38) after 945 seconds and seem to follow the pressure prediction response.

### 3.4 Density

Densities in broken loop cold and hot legs and intact loop cold and hot legs are presented in Figures 9 through 12 for short term (0 - 200 sec) and in Figures 25 through 28 for long term (0 - 2400 sec) response. Good agreement with data is achieved.

### 3.5 Mass Flow Rate

The comparison between calculated versus measured break flow is presented in Figure 39. The RELAP4 results are within the measurement error band.

### 3.6 Liquid Mass in the System

Four plots for liquid mass in the reactor vessel (Figure 33), liquid mass in steam generator primary side (Figure 34), liquid mass in hot and cold leg, intact loop (Figure 35), and liquid mass in broken loop (Figure 36) are presented. Since data on LOFT liquid mass inventory are not available, no comparisons to the data have been made.

### 3.7 Liquid Levels

Level in the pressurizer is presented in Figure 18. RELAP4 calculated a delay of 3 seconds in emptying the pressurizer. This may have been caused by an initial lower level in the LOFT pressurizer as compared to the value used in the RELAP4 calculations.

The level in the core is presented in Figure 32. Again, data are not available but the LOFT instruments did not measure core uncover. RELAP4 calculates uncover of the core at 1300 seconds, recovery at 1500 seconds and finally uncovers again at 1550 seconds.

We are using Wilson bubble rise in the core. It seems that a homogeneous model in the core may have been more appropriate for the case where main coolant pumps are still available. This assumption would not have shown core uncover, instead would show high voiding of the core.



#### 4.0 References

1. Yankee Atomic Electric Company WREM based PWR-ECCS Evaluation Model (version YAEC-05B), YAEC 1160, July 1978.
2. Victor H. Ramsom et al, RELAP5/MOD 1 Code Manual (DRAFT)
3. W. H. Grush and M. S. Shiuko, Best Estimate Prediction for LOFT Nuclear Experiments L3-1, EGG-LOFT-5033, November 1979
4. EG&G presentation to NRC on January 15, 1981 (RELAP 5 Calculations of L3-5 and L3-6)
5. Glenn E. McCreery, Quick-Look Report on LOFT Nuclear Experiments L3-6/L8-1, EGG-LOFT-5318, December 1980
6. LOFT L3-6 Data Tapes

Table 1. RELAP4 Blowdown System Model Description

Control Volume	Description
1	Nuclear Core
2	Core Bypass
3	Steam generator secondary steam dome
4 & 5	Upper Plenum
6 & 7	Intact loop hot leg
8 & 13	Steam generator inlet plenum and outlet plenum
9 & 12	Straight section of steam generator tubes
10 & 11	Curved sections of steam generator tubes
14	Steam generator outlet piping
15	Piping leading to the tee preceding the coolant pumps.
16	Piping from tee to primary coolant pumps
17	Primary coolant pumps
18 & 19	Intact loop cold leg
20	Upper annulus at the vessel inlet
21	Downcomer
22	Lower plenum
23 & 24	Broken loop cold leg
25, 26, 27 & 28	Broken loop hot leg
29 & 30	Reflood assist bypass piping
31	Pressurizer surge line
32	Pressurizer
33	Piping connecting the steam generator secondary steam dome to the steam relief valve
34	ECC injection line
35	Steam generator secondary downcomer
36	Steam generator secondary shroud region
37	Containment

Table 2. Initial Conditions for LOCE L3-6

<u>Parameter</u>	<u>Measured Value</u>	<u>Input Value for RELAP 4</u>
<u>Primary Coolant System</u>		
Mass flow rate ( $\times 10^6$ lbm/hr)	3.8 $\pm$ 0.05	3.8
Hot leg pressure (psia)	215.67 $\pm$ 20.3	2156.62
Cold leg temperature ( $^{\circ}$ F)	544.5 $\pm$ 2.0	544.5
Hot leg temperature ( $^{\circ}$ F)	579.1 $\pm$ 3.2	579.5
Primary coolant pump injection flow (gpm)	1.55 $\pm$ 0.25	1.55
<u>Reactor Vessel</u>		
Power level (MW)	50 $\pm$ 1	50
<u>Steam Generator Secondary Side</u>		
Water level (in)	8.7 $\pm$ 1.2	8.7
Water temperature ( $^{\circ}$ F)	517.4 $\pm$ 1.4	507.0
Pressure (psia)	807.86 $\pm$ 8.7	809.27
Mass Flow Rate (lbm/sec)	61.3 $\pm$ 0.2	61.3
<u>Pressurizer</u>		
Pressure (psia)	2161.07 $\pm$ 36.26	2155.11
Liquid level (in)	46.5 $\pm$ 4.3	46.5
<u>ECCS</u>		
Initiation pressure (psia)	1778.17 $\pm$ 20.31	1778.7

Table 3. Chronology of Events - Experimental  
Data Versus Test Predictions

Sequence of Events for LOCE L3-6

EVENT	TIME AFTER LOCE INITIATION	
	MEASURED DATA (seconds)	PREDICTION DATA
Reactor scrammed	-5.8+0.2	-5.8
LOCE initiated	0.0	0.0
HPSI "A" tripped on	3.6-0.2	2.2
Pressurizer emptied	20.2-0.2	23.9
Upper Plenum fluid saturated	28.5+0.2	30.0
Intact loop hot leg voiding initiated	29.4+5.0	30.0
Intact loop cold leg voiding initiated	31.4+5.0	90.0
End of subcooled break flow	44.2+0.2	90.0
Steam generator secondary auxiliary feed pump started	73.4+0.2	73.4
Steam generator secondary steam control valve opened	88.8+0.2	88.7
Steam generator secondary steam control valve closed	99.6+0.2	101.2
Primary system pressure became less than secondary system pressure	930.0+30.0	940.0
Steam generator secondary auxiliary feed pump shut down	1856.0+5.0	1856.0
Primary coolant pumps tripped off	2371.4	2031.5




Figure 1  
RELAP 4 LOFT Nodalization




Figure 2  
Intact Loop Hot Leg Pressure  
(0 - 200 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-6 D  
RELAP4 121




Figure 3  
Pressurizer Pressure  
(0 : 200 sec)

# L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6-0  
RELAP4 10F

RECEIVED 8/10/70 13 41 55

PLOT 451




Figure 4  
Pressure in Downcomer  
(0 : 200 sec)



L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP 4




Figure 5  
Pressure in Broken Loop Cold  
Leg (0  $\pm$  200 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-5  
RELAP4 L3-5

#137451




Figure 6  
Pressure in Broken Loop Hot Leg  
(0 to 200 sec)

L3-5 RELAP4 COMPARISON TO DATA

APR 1981 03:00 13 41.55

LOFT L3-6 0  
RELAP4 107




Figure 7  
Pressure In Steam Generator Dome  
(0  $\frac{1}{2}$  200 sec)

L3-6 RELAP4 COMPARISON TO DATA

APR 1988 01/02/88 15 43 30

LOFT L3-6 D  
RELAP4 LOF




Figure 8  
Density in Broken Loop Cold Leg  
(0  $\frac{1}{2}$  200 sec)

L3-5 RELAP4 COMPARISON TO DATA

RTTUUR 31/01/72 12 20 11

LOFT L3 5 2  
RELAP4 1 01




Figure 9  
Density in Broken Loop Hot Leg  
(0 ÷ 200 sec)

# L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-6 0  
RELAP4 1.01

PLOT#81

SCHEM 81/07/00 7:20 AM




Figure 10  
Density in Intact Loop Hot Leg  
(0 ÷ 200 sec)

L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP4 101




Figure 11  
Density in Intact Loop Cold Leg  
(0 - 200 sec)

L3-5 RELAP4 COMPARISON TO DATA

DATE: 08/07/07 12:20:19

LOFT L3-6 D

RELAP4 1 OF




Figure 12  
Density at Steam Generator Exit Intact Loop  
(0  $\frac{r}{r}$  200 sec)



L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6 DP  
RELAP4 DP




Figure 13  
Differential Pressure Across Pumps  
(0  $\frac{1}{2}$  200 sec)

# L3-6 RELAP4 COMPARISON TO DATA

REVISION 31700123 15 JUL 75

LOFT L3-6 3A  
RELAP4 1.01




Figure 14  
Differential Pressure Across Steam Generator  
(0  $\frac{1}{2}$  200 sec)

L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6 DR  
RELAP4 10V





Figure 15  
Differential Pressure Across Reactor Vessel  
(0  $\frac{1}{2}$  200 sec)

L3-5 RELAP4 COMPARISON TO DATA

PROGRAM: RELAP4/25-11-73-93

LOFT L3-6  
RELAP4 LOI



31

Figure 16  
Temperature in Intact Loop Hot Leg  
( 0  $\frac{2}{7}$  200 sec)




Figure 17  
 Temperature at Inlet and Outlet  
 Plenums in Steam Generator, Intact Loop  
 (0  $\frac{1}{2}$  200 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP4 LOFT

PLD7451

LEVEL IN PRESSURIZER (FT) ML 32




Figure 18  
Level in Pressurizer  
(0, 200 sec)

L3-5 RELAP4 COMPARISON DATA

LOT 13 8 0  
RELAP4 10P





Figure 19  
Intact Loop Hot Leg Pressure  
( 0 ± 2400 sec )

# L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6 D  
RELAP4 LOF

PLOT451

2250



TIME (SEC) TI 9

Figure 20  
Pressurizer Pressure  
(0 ÷ 2400 sec)



13-5 RELAP4 COMPARISON TO DATA





Figure 21  
Pressure in Downcomer  
(0 - 2400 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP4

EXPERIMENTAL DATA  
20-11-74

PLOT434



TIME (SECS) T10

Figure 22

Pressure in Broken Loop Cold Leg  
(0 ; 2400 sec)

L3-6 RELAP4 COMPARISON TO DATA




Figure 23  
Pressure in Broken Loop Hot Leg  
(0 ; 2400 sec)




Figure 24  
 Pressure in Steam Generator Dome  
 (0 - 2400 sec)

13-6 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP4 101




Figure 25  
Density in Broken Loop Cold Leg  
(0 ÷ 2400 sec)

L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6  
RELAP4

01/02/77 12 31 '2

01/04/77




Figure 26  
Density in Broken Loop Hot Leg  
(0 - 2400 sec)

L3-5 RELAP4 COMPARISON TO DATA

REF ID: A71707427, 10-18-22

LOFT L3-6  
RELAP4 1.01




Figure 27  
Density in Intact Loop Hot Leg  
(0 - 2400 sec)

L3-5 RELAP4 COMPARISON TO DATA

REF ID: A61702 (27. 10. 15. 00)

LOFT L3-6 ON  
RELAP4 1 OF




Figure 28  
Density in Intact Loop Cold Leg  
(0 - 2400 sec)



# L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6 DM  
RELAP4 LOT

FILE: E2 31/07/79 14 37.06

PLOT45A




Figure 29  
Differential Pressure Across  
Steam Generator  
(0 - 2/600 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-5 78  
RELAP4 107




Figure 30  
Differential Pressure Across  
Reactor Vessel  
(0 - 2400 sec)

L3-6 RELAP4 COMPARISON TO DATA

LOFT L3-6 DR  
RELAP4 ICI




Figure 31  
Differential Pressure Across Pumps  
(0 - 2400 sec)

RELAP4 LOFT L3-5 MEASURED VALUES

RELAP4 127

RELAP4 127




Figure 32  
Liquid Level in Core  
(0 - 2400 sec)

RELAP4 LOFT 13.6 MEASURED VALUES




Figure 33  
Liquid Mass in Reactor Vessel  
(0 - 2400 sec)

RELAP4 LOFT L3-6 MEASURED VALUES

JANUARY 31/00/77. 13-04-20.




Figure 34  
Liquid Mass in Steam Generator,  
Primary Side  
(0 - 2400 sec)

RELAP4 LOFT L3-6 MEASURED VALUES

JANUARY 91/02/27, 10:39:20.




Figure 35  
Liquid Mass in Hot and Cold Leg,  
Intact Loop  
(0 - 2400 sec)

RELAP4 LOFT 1.3-5 MEASURED VALUES

REF ID: A61000




Figure 36  
Liquid Mass in Broken Loop  
(0 - 2400 sec)



L3-6 RELAP4 COMPARISON TO DATA

REPORT NO. 31707739-11-11-50

LOFT L3-6 3  
RELAP4 101




Figure 37  
Temperature in Intact Loop Hot Leg  
(0 - 2400 sec)




Figure 38  
Temperature at Inlet and  
Outlet Plenums in Steam Generator  
(0 - 2400 sec)

L3-5 RELAP4 COMPARISON TO DATA

LOFT L3-5 DR  
RELAP4 121




Figure 39  
Break Flow  
(0 - 2400 sec)

5.0 APPENDIX A

\*C CUMZ  
\*ID LS7227  
\*I CUCI.31

3 ,DADT,VAVPOS

\*C CUML  
\*ID LS7228

\*D CUML.175

LENGTH(J)=(5\*MAXJUN+3)\*NLFLT+B\*MAXJUN\*NLINT

\*C FLUS

\*ID BHL5

\*I FLOS.339

IF(I.NE.88) GO TO 85

DADT = 0.05

C  
C  
C  
C

IN THE FOLLOWING CARDS THE LOGIC TO TRIP THE SPECIAL STEAM  
VALVE IS IMPLEMENTED

IF(TRIP(5,XXXX)) GO TO 999

GO TO 886

999 IF(DADT.LT.0.0.AND.P(K).GE.930.) DADT = 0.0

IF(P(K).LE.920.0) DADT = -DADT

IF(P(K).GE.1030.0) DADT = DADT

IF(P(K).LE.1020.0.AND.DADT.GT.0.0) DADT = 0.0

VAVPOS = VAVPOS+DADT\*DT

IF(VAVPOS.LT.0.0) VAVPOS = 0.0

IF(VAVPOS.GT.1.0) VAVPOS = 1.0

886 VALCOF = .366455\*VAVPOS\*\*3-.240043\*VAVPOS\*\*2+.151757\*VAVPOS-  
.00047633

IF(VAVPOS.LT.0.1) VALCOF = .00043\*VAVPOS+.01157

IF(VAVPOS.LT.0.016) VALCOF = .7293R\*VAVPOS

IF(VAVPOS.LE.0.0) VALCOF = 0.0

IF(P(K).GE.400.) WP(I) = VALCOF\*P(K)

IF(P(K).LT.400.) WP(I) = 1.149\*VALCOF\*SQRT(P(K)\*\*2-(200.)\*\*2)

ESUBK(I) = ZERO

FSUBK(I) = -UNEEXT

GO TO 270

85 CONTINUE

\*I HJW1.237

3 ,DADT,VAVPOS

\*I INJU.257

DADT=0.0

VAVPOS=0.646934

\*I CUCI.31

3 ,DADT,VAVPOS

\*D CUML.175

LENGTH(J)=(5\*MAXJUN+3)\*NLFLT+B\*MAXJUN\*NLINT

\*C FLUS

\*IDENT HCH

\*I FLOS.434

AA1 = 1.0

\*B FLOS.440

AA1 = A1

\*D FLOS.441,FLOS.442

WHMIN = -AA1\*AJ\*LEAK(H,PLL,I,DER,TCHUK,ITPLS)

WHMAX = AA1\*AJ\*LEAK(H,PLK,I,DER,TCHUK,ITPKS)

YANKEE ATOMIC ELECTRIC COMPANY

\*\*\*\*\*  
\*\* SOFTWARE CONTROL LIBRARY \*\*  
\*\*\*\*\*  
\*\* PERM. FILE NAME YP15V05 \*\*  
\*\* MODIFICATION LEVEL V05.00 \*\*  
\*\* DESCRIPTION Y-STEAM TABLE(TABLE15) \*\*  
\*\* INSTALLED DATE Y 02726/80 \*\*  
\*\* TODAY'S DATE Y 02/27/81 \*\*  
\*\* TIME OF RUN Y 17.53.06. \*\*  
\*\*\*\*\*



LISTING OF INPUT DATA FROM CASE 1

LINE	MEASUREMENT	VALUES	STEAM LEAKS	CUMULATIVE ON	NO. OF	COUNT	LEAK
1	MEASUREMENT LIST	VALUES	STEAM LEAKS	CUMULATIVE ON	NO. OF	COUNT	LEAK
2	010001	2 9 9 37	4 2 52 1	10 1 5 16	8 5 3 0	0	
3	010002	50.0 1.0					
4	010003	1 0 1 1					
5	020000	AP 0 AP 3	JM 00 JM 30 JM 41	JC 30 JM 47	JX 39 AP 10		
6		TIME STEP DATA					
7	030010	2 10	2 0	0.1 0.001	8.0		
8	030020	2 10	2 0	0.05 0.0002	8.0		
9	030030	2 10	2 0	0.10 0.001	27.0		
10	030040	5 100	100 0	0.050 0.0001	28.9		
11	030050	2 100	250 0	0.001 0.00008	30.9		
12	030060	5 10	1 0	0.1 0.001	58.9		
13	030070	2 10	2 0	0.10 0.001	82.0		
14	030080	40 100	50 0	0.001 0.00008	83.0		
15	030090	2 10	2 0	0.100 0.0008	3000.0		
16		TIME DATA					
17	040010	1 1 0 0	0.0 0.0				*END
18	040020	2 1 0 0	79.2 0.0				*START AUX FEEDWATER
19	040030	11 1 0 0	5.8 0.0				*BREAK
20	040040	4 1 0 0	0.0 0.0				*START FEEDWATER
21	040050	5 1 0 0	0.0 0.0				*STEAM FLOW
22	040060	1 0 0 0	0.338 0.0				*STOP LEVEL
23	040070	7 0 0 0	1778.17 0.0				*HPIS
24	040080	12 1 0 0	0.0 0.1				*SCHM
25	040090	10 1 0 0	1.9 0.0				*OPTIONAL BREAK
26	040100	0 0 0 0	330.0 0.0				*TRIP PUMPS
27	040110	3 4 33 0	1010.5 0.0				*CLOSE STEAM CONTROL VALVE LEAK
28	040120	4 4 3 0	900.0 0.0				*OPEN LEAK
29	040130	9 1 0 0	48.0 0.0				*START COOLANT INJECTION TO PRIMARY PUMPS
30	040140	13 4 33 0	1010.5 1.9				* START SECOND LEAK 301
31	040150	14 4 33 0	1010.5 1.9				* START SECOND LEAK 401
32	040160	15 4 33 0	1010.5 1.9				* START SECOND LEAK 301
33	040170	16 4 33 0	1010.5 13.0				* START SECOND LEAK 201
34	040180	17 4 33 0	1010.5 1.9				* START SECOND LEAK 101
35							
36		VOLUME DATA					
37							
38		BUBBLE INDEX, TRIP INDICATOR	DEVOLUME DATA RETRIEVAL				
39	*VOLUME	8 0	PRESSURE TEMP QUAL	*REPRESENTS			
40	050011	2 0	2173.026971 543.2349	=1			* CORE
41	050021	2 0	2175.048550 544.50	=1			* CORE BYPASS
42	050031	4 0	807.57153 -1.0	0			* SG SEC STEAM DOME
43	050041	2 0	2109.76737798 579.50	=1			* PLENUM ABOVE FUEL
44	050051	2 0	2167.66449 579.50	=1			* OUT LEG UPPER PLENUM
45	050061	0 0	2156.62140 579.50	=1			* I L H L
46	050071	0 0	2152.814975 579.50	=1			* I L H L VENTURI
47	050081	0 0	2143.61722 579.50	=1			* SG INLET PLENUM
48	050091	0 0	2140.32458 563.8700	=1			* SG TUBES INLET
49	050101	0 0	2137.20345 555.8045	=1			* SG TUBES
50	050111	0 0	2135.71602 549.1800	=1			* SG TUBES
51	050121	0 0	2135.52742 545.310000	=1			* SG TUBES OUTLET
52	050131	0 0	2136.17831 544.50	=1			* SG OUTLET PLENUM
53	050141	0 0	2124.20449 544.50	=1			* T L C L
54	050151	0 0	2121.93712 544.50	=1			* T L C L
55	050161	0 0	2116.790092 544.50	=1			* PUMP INLET
56	050171	0 0	2152.17859 544.50	=1			* REACTOR COOLANT PUMP
57	050181	0 0	2184.76275 544.50	=1			* PUMP OUTLET
58	050191	0 0	2181.634650 544.50	=1			* I L C L
59	050201	2 0	2177.446686 544.50	=1			* MV INLET ANNULUS
60	050211	2 0	2174.414704 44.90	=1			* MV DISCONNECT





129  
130  
131  
132

JUNCTION DATA

JUNCT.	IN	OUT	PUMP	VLV	TH. FL. RATE	
133	01	04	0	0	1002.923	*INLET PLANE BOTTOM OF FUEL
134	01	04	0	0	1002.923	*EXIT TO UPPER PLENUM
135	01	04	0	0	1002.923	*CORE BYPASS INLET
136	01	04	0	0	1002.923	*SG SEC. STEAM DOME TO DNCHM
137	01	04	0	0	1002.923	*INLET PLENUM TO UPPER PLENUM
138	01	04	0	0	1002.923	*INTACT LOOP OUTLET NOZZLE
139	01	04	0	0	1002.923	*IHL=DOWNSTREAM OF SURGE LINE
140	01	04	0	0	1002.923	*SG PLENUM INLET
141	01	04	0	0	1002.923	*SG TUBF SHEET INLET
142	01	04	0	0	1002.923	*SG TUBES
143	01	04	0	0	1002.923	*SG TUBES
144	01	04	0	0	1002.923	*SG TUBES
145	01	04	0	0	1002.923	*SG TUBF SHEET EXIT
146	01	04	0	0	1002.923	*SG OUTLET NOZZLE
147	01	04	0	0	1002.923	*PIPING SG TO PUMPS
148	01	04	0	0	1002.923	*BRANCH PIPING TO PUMPS
149	01	04	0	0	1002.923	*PUMP SUCTION
150	01	04	0	0	1002.923	*PUMP DISCHARGE
151	01	04	0	0	1002.923	*INT. COLD LEG
152	01	04	0	0	1002.923	*INT. CI INLET NOZZLE
153	01	04	0	0	1002.923	*ANNULUS TO DNCHM
154	01	04	0	0	1002.923	*DOWNCOMER TO LOWER PLENUM
155	01	04	0	0	1002.923	*RECL=NOZZLE
156	01	04	0	0	1002.923	*RECL=MEASUREMENT LOCATION
157	01	04	0	0	1002.923	*CORE BYPASS OUTLET
158	01	04	0	0	1002.923	*RECL=TEE TO RABV
159	01	04	0	0	1002.923	*RECL=NOZZLE
160	01	04	0	0	1002.923	*RECL=CONTRACTION
161	01	04	0	0	1002.923	*RECL=SG SIMULATOR
162	01	04	0	0	1002.923	*RECL=PUMP SIMULATOR
163	01	04	0	0	1002.923	*SG SEC. SHROUD TO STEAM DOME
164	01	04	0	0	1002.923	*RECL=TEE TO RABV
165	01	04	0	0	1002.923	*SHRGE LINE CONNECTION TO HL
166	01	04	0	0	1002.923	*PZR INLET
167	01	04	0	0	1002.923	*SG SEC. DOWNCMR TO SHROUD
168	01	04	0	0	1002.923	*ACCUMULATOR INJECTION PIPE
169	01	04	0	0	1002.923	*BREAK IN COLD LEG
170	01	04	0	0	1002.923	*BREAK ORIFICE
171	01	04	0	0	1002.923	*STEAM PIPE INLET
172	01	04	0	0	1002.923	*STEAM CONTROL VALVE LEAK
173	01	04	0	0	1002.923	*NPIS INJECTION
174	01	04	0	0	1002.923	*FEED WATER FLOW
175	01	04	0	0	1002.923	*STEAM FLOW
176	01	04	0	0	1002.923	*AUX FEEDWATER
177	01	04	0	0	1002.923	*LEAK PATH OUT OF PZR REL VLV
178	01	04	0	0	1002.923	*R L H L = BREAK LOCATION
179	01	04	0	0	1002.923	*SECOND SG LEAK
180	01	04	0	0	1002.923	*LEAK 501
181	01	04	0	0	1002.923	*LEAK 401
182	01	04	0	0	1002.923	*LEAK 301
183	01	04	0	0	1002.923	*LEAK 201
184	01	04	0	0	1002.923	*LEAK 101

09

JUNCT.	AREA	ELEVATION	INERTIA	K=F=0	K=VEL
185	1.0512	-12.256	2.5309	1.5724	1.2776
186	1.2472	-8.456	2.0274	0.7440	0.8889
187	1.615	-12.256	2.5309	1.5724	1.2776
188	2.3	10.17	1.4034	0.1921	0.1921
189	0.4446	-1.264	2.312	0.1491	0.3401

Line	Code	IC	J	IC	NUM	DIAM	CCULE	I	H
195	UMU002	0.5500	0.0	1.510	0.000	0.000	0.000	0.000	1.5000
196	UMU002	1.0000	0.0	2.500	0.000	0.000	0.000	0.000	0.4000
197	UMU102	1.0000	0.0	7.200	0.000	0.000	0.000	0.000	0.000
198	UMU112	1.0000	0.0	10.000	0.000	0.000	0.000	0.000	0.000
199	UMU122	1.0000	0.0	14.000	0.000	0.000	0.000	0.000	0.000
200	UMU132	1.0000	0.0	18.000	0.000	0.000	0.000	0.000	0.000
201	UMU142	0.5500	0.0	1.510	0.000	0.000	0.000	0.000	1.2000
202	UMU152	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
203	UMU162	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
204	UMU172	0.7000	0.0	2.100	0.000	0.000	0.000	0.000	1.0000
205	UMU182	0.7000	0.0	2.100	0.000	0.000	0.000	0.000	0.000
206	UMU192	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
207	UMU202	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
208	UMU212	1.5000	0.0	1.500	0.000	0.000	0.000	0.000	0.000
209	UMU222	20.0000	0.0	20.000	0.000	0.000	0.000	0.000	0.000
210	UMU232	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
211	UMU242	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
212	UMU252	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
213	UMU262	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
214	UMU272	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
215	UMU282	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
216	UMU292	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
217	UMU302	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
218	UMU312	1.7000	0.0	1.700	0.000	0.000	0.000	0.000	0.000
219	UMU322	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
220	UMU332	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
221	UMU342	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
222	UMU352	5.0000	0.0	5.000	0.000	0.000	0.000	0.000	0.000
223	UMU362	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
224	UMU372	2.2000	0.0	2.200	0.000	0.000	0.000	0.000	0.000
225	UMU382	2.2000	0.0	2.200	0.000	0.000	0.000	0.000	0.000
226	UMU392	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
227	UMU402	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
228	UMU412	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
229	UMU422	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
230	UMU432	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
231	UMU442	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
232	UMU452	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
233	UMU462	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
234	UMU472	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
235	UMU482	0.5000	0.0	0.500	0.000	0.000	0.000	0.000	0.000
236	UMU492	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
237	UMU502	0.3000	0.0	0.300	0.000	0.000	0.000	0.000	0.000
238	UMU512	0.2000	0.0	0.200	0.000	0.000	0.000	0.000	0.000
239	UMU522	0.1000	0.0	0.100	0.000	0.000	0.000	0.000	0.000
240	UMU532	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
241	UMU542	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
242	UMU552	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
243	UMU562	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
244	UMU572	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
245	UMU582	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
246	UMU592	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
247	UMU602	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
248	UMU612	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
249	UMU622	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
250	UMU632	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
251	UMU642	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
252	UMU652	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
253	UMU662	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
254	UMU672	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
255	UMU682	1.0000	0.0	1.000	0.000	0.000	0.000	0.000	0.000
256	UMU692	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
257	UMU702	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000
258	UMU712	0.0000	0.0	0.000	0.000	0.000	0.000	0.000	0.000

62

200	080149	1	0	0	0	0	0.4324	1.0	11	0
201	080203	1	0	0	0	0	0.4323	1.0	11	0
202	080213	0	0	0	0	0	3.0420	1.0	11	0
203	080223	0	0	0	0	0	0.4010	1.0	11	0
204	080233	1	0	0	0	0	0.4323	1.0	11	0
205	080243	1	0	0	0	0	0.3386	1.0	11	0
206	080253	0	0	0	0	0	1.0	11	0	0
207	080263	0	0	0	0	0	0.7083	1.0	11	0
208	080273	1	0	0	0	0	0.8323	1.0	11	0
209	080283	0	0	0	0	0	0.3590	1.0	11	0
270	080293	1	0	0	0	0	0.5274	1.0	11	0
271	080303	1	0	0	0	0	0.3590	1.0	11	0
272	080313	1	0	0	0	0	1.5392	1.0	11	0
273	080323	0	0	0	0	0	0.7083	1.0	11	0
274	080333	0	0	0	3	0	0.1408	1.0	11	0
275	080343	0	0	0	0	0	0.1408	1.0	11	0
276	080353	1	0	0	0	0	0.2188	1.0	11	0
277	080363	1	0	0	0	3	0.2417	1.0	11	0
278	080373	1	0	0	0	0	0.0931	0.0	11	0
279	080383	1	0	0	0	0	0.0	0.60	11	0
280	080393	1	0	0	0	0	0.7910	1.0	11	0
281	080403	1	0	0	0	0	0.0	1.0	11	0
282	080413	0	0	0	3	0	0.2865	1.0	11	0
283	080423	0	0	0	3	0	1.0	1.0	11	0
284	080433	0	0	0	3	0	1.0	1.0	11	0
285	080443	0	0	0	3	1.0	1.0	1.0	11	0
286	080453	0	0	0	0	0	0.0937	1.0	11	0
287	080463	1	0	0	0	0	0.3386	1.0	11	0
288	080473	1	0	0	0	0	1.0	1.0	11	0
289	080483	1	0	0	0	0	1.0	1.0	11	0
290	080493	1	0	0	0	0	1.0	1.0	11	0
291	080503	1	0	0	0	0	1.0	1.0	11	0
292	080513	1	0	0	0	0	1.0	1.0	11	0
293	080523	1	0	0	0	0	1.0	1.0	11	0

PRIMARY CRILANT PUMPS

PUMP DESCRIPTION BASED ON CE/EPRI/SEMISCALE DATA (12/77)

296	090011	1	0	0	1	0	3530	0.8844	10000	315	738
297	090019	540	38.31	383.594908	0	17.06408	102.2631	0			

PUMP HEAD TWO PHASE DIFFERENCE CURVE MULTIPLIER

301	091001	w10	0.0	0.0	0.1	w0.025	0.195	0.180	0.20	0.855	0.372	0.37
302	091002	0.5	0.74	0.735	0.86	0.0	0.85	0.0	0.725	1.0	0.0	

PUMP TORQUE TWO PHASE DIFFERENCE CURVE MULTIPLIER

304	092001	w10	0.0	0.0	0.11	0.025	0.195	0.180	0.21	0.304	0.9	0.3
305	092002	0.0	0.292	0.725	0.25	0.8	0.18	0.9	0.0	1.0	-0.4	

PUMP STOP DATA CARDS

307	093011	0.0	0.0	0.0								
308	*											
309	100000	16	0	0	16							

PUMP HEAD SINGLE PHASE DATA CARDS

311	101011	1	1	0	0	1.4436	0.14061	1.3436	0.30963	1.3186		
312	101012					.59296	1.2728	.7902	1.1336	1.	1.0000	
313	101021	1	2	0	0	-.07	.2	-.5	.4	-.25		
314	101022					.57554	0.	.74832	.2443	.77344	.3778	
315	101023					.40313	.6324	1.	1.0000			
316	101031	1	3	0	-1.	2.4722	0.80574	2.10474	0.0009	1.831		
317	101032					-.40083	1.620	-.200171	1.4705	0.	1.4036	
318	101041	1	4	0	-1.	2.4722	0.82297	1.9968	-.63352	1.5447		
319	101042					-.45530	1.3274	-.27109	1.1949	-.17716	1.0005	
320	101043					-.04073	1.0150	0.	.434279			
321	101051	1	5	0	0.	.25	.2	.24	.4	.38		
322	101052					.4118	.2768	.59763	.4584	.793467	.6492	
323	101053					1.	1.0000					
324	101061	1	6	10	0.	.434279	.001000	.0220	1.0000	.444		









NO	ITEM	IN	OUT	RU	YH	PF
527	170101	2	1	3	0.0	0.01424589
528	170102	2	1	3	0.0	0.01424589
529	170103	2	1	3	0.0	0.01424589
530	170104	2	1	3	0.0	0.01424589
531	170201	2	2	4	0.01675	0.002002
532	170202	2	2	4	0.01675	0.002002
533	170301	2	2	4	2.25	0.02709
534	170302	2	2	4	2.25	0.02709
535	170401	2	2	4	1.45413	0.06456
536	170402	2	2	4	1.45413	0.06456
537	170403	2	2	4	1.54167	0.05456
538	170404	2	2	4	1.54167	0.05456
539	170501	1	2	4	0.0	0.02497623
540	170502	1	2	4	0.0	0.02497623
541	170701	1	2	4	0.0	0.01298117
542	170702	1	2	4	0.0	0.01298117
543	170801	2	2	4	1.25	3.47222-3
544	170802	2	2	4	1.25	3.47222-3
545						0.05456
546						0.11111

\*\*\*\*\*  
 MATERIAL PROPERTIES DATA  
 THERMAL CONDUCTIVITY DATA  
 UM  
 MATERIAL PROPERTIES DATA  
 THERMAL CONDUCTIVITY DATA

NO	ITEM	IN	OUT	RU	YH	PF
551	180101	20	0.32004879+2	0.48918227+1		
552	180102	20	0.24034293+3	0.37481094+1		
553	180103	20	0.50867592+3	0.30360007+1		
554	180104	20	0.80700902+3	0.25575448+1		
555	180105	20	0.10653421+4	0.22132108+1		
556	180106	20	0.13236751+4	0.19550778+1		
557	180107	20	0.15420082+4	0.17560877+1		
558	180108	20	0.18403412+4	0.16000493+1		
559	180109	20	0.20986743+4	0.14769278+1		
560	180110	20	0.23470073+4	0.13800592+1		
561	180111	20	0.26153404+4	0.13068888+1		
562	180112	20	0.28736734+4	0.12542412+1		
563	180113	20	0.31320065+4	0.12575030+1		
564	180114	20	0.33903395+4	0.13111702+1		
565	180115	20	0.36486726+4	0.13822821+1		
566	180116	20	0.39070056+4	0.14742965+1		
567	180117	20	0.41653387+4	0.15943612+1		
568	180118	20	0.44236717+4	0.17511313+1		
569	180119	20	0.46820047+4	0.19549311+1		
570	180120	20	0.49403378+4	0.22235775+1		

G A P  
 32. 082 600. 138 1000. 17 1500. 207 2000. 241 5400. 431  
 ZIRCONIUM

NO	ITEM	IN	OUT	RU	YH	PF
571	180301	20	0.32004879+2	0.71050812+1		
572	180302	20	0.19560617+3	0.94403186+1		
573	180303	20	0.35927237+3	0.85170430+1		
574	180304	20	0.52274862+3	0.91552271+1		
575	180305	20	0.68634487+3	0.97748400+1		
576	180306	20	0.84994111+3	0.10395853+2		
577	180307	20	0.10135874+4	0.11038237+2		
578	180308	20	0.11771836+4	0.11721963+2		
579	180309	20	0.13407740+4	0.12467002+2		
580	180310	20	0.15043701+4	0.13293324+2		
581	180311	20	0.16679723+4	0.14228401+2		
582	180312	20	0.18315686+4	0.15269703+2		
583	180313	20	0.19951648+4	0.16454701+2		
584	180314	20	0.21587611+4	0.17710865+2		

541	180317			0.2045549e+0	0.23131070+2				
542	180318			0.24131461+0	0.25226011+2				
543	180319			0.29767423+0	0.27173174+2				
544	180320			0.3180338e+0	0.30420728+2				
545	*			304 STAINLESS STEEL					
546	180401	=2	0.	8.2928	800.	12.24522			
547	*			INCUNEL 600					
548	180501	=5	0.	8.4	200.	4.1	800.	0.0	10.0
549	*			VOLUMETRIC HEAT CAPACITY DATA					
550	*			IRANIUM OXIDE					
551	180101	=15	32.	34.05	172.	38.35	212.	40.05	302.
552	190102			752.	80.00	2012.	51.35	2732.	52.05
553	190103			3452.	83.00	7412.	72.60	4352.	84.70
554	190104			4712.	84.15	4882.	100.10	5102.	101.80
555	*			GAP					
556	190200	2	32.	.000075	5400.	.000075			
557	*			ZINCUNIUM					
558	190301	9	32.	25.02	212.	24.755	392.	30.375	572.
559	190302			432.	33.015	1292.	35.235	1742.	36.055
560	190303			3100.	35.235				
561	*			304 STAINLESS STEEL					
562	190401	=8	300.	44.89	400.	45.025	500.	45.19	600.
563	190402			700.	45.785	800.	46.265		
564	*			INCUNEL 600					
565	190501	=5	0.	51.39	200.	57.44	400.	61.80	600.
566	*			LINEAR EXPANSION COEFFICIENT DATA					
567	200101	=2							* URANIUM OXIDE
568	200102		32.	3.7752e-6	8000.	1.4440e-5			
569	200201	=2							* GAP
570	200202		32.	0.0	8000.	0.0			
571	200301	=4							* ZINCUNIUM
572	200302		77.	3.1711e-6	1478.	4.5051e-6	1473.	4.1900e-6	
573	200303		5000.	5.3000e-6					
574	200401	=2							* 304 SS
575	200402		0.	0.	5000.	0.			
576	200501	=2							* INCUNEL 600
577	200502		0.	0.	5000.	0.			
578	*			*****					
579	*			*****					
580	*			*****					
581	*			*****					
582	250001	1 2 3	0.00469	0.0					
583	260001	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
584	270001	=24							
585	270002	5000.0	0.0						
586	270003	2147.0	45.294						
587	270004	2102.0	50.1463						
588	270005	2057.0	55.043						
589	270006	2012.0	62.434						
590	270007	1907.0	72.2337						
591	270008	1822.0	83.242						
592	270009	1777.0	97.408						
593	270010	1732.0	111.757						
594	270011	1717.0	126.416						
595	270012	1702.0	140.09						
596	270013	1647.0	242.01						
597	270014	1652.0	317.093						
598	270015	1607.0	411.360						
599	270016	1562.0	521.551						
600	270017	1517.0	641.588						
601	270018	1472.0	771.309						
602	270019	1427.0	905.482						
603	270020	1382.0	1044.324						
604	270021	1337.0	1185.1220						

57



656	280028	1116.00	1405.01
657	280001	24	
658	280002	10.5	0.0
659	280003	10.5	45.290
660	280004	10.5	50.1903
661	280005	10.5	55.093
662	280006	10.5	62.439
663	280007	10.5	7.2337
664	280008	10.5	1.252
665	280009	10.5	97.944
666	280010	19.0	114.757
667	280011	25.0	146.916
668	280012	28.0	186.948
669	280013	27.0	232.41
670	280014	29.0	317.093
671	280015	35.0	411.304
672	280016	50.0	521.551
673	280017	67.0	641.533
674	280018	78.0	771.308
675	280019	75.2	905.942
676	280020	71.0	1044.324
677	280021	64.0	1185.1220
678	280022	56.5	1327.1412
679	280023	37.5	1472.833
680	280024	26.0	1614.524
681	280025	10.5	1905.01
682	280001	24	
683	280002	3000.0	0.0
684	280003	2147.0	65.299
685	280004	2102.0	50.1903
686	280005	2057.0	55.093
687	280006	2012.0	62.439
688	280007	1967.0	72.2337
689	280008	1922.0	83.252
690	280009	1877.0	97.944
691	280010	1832.0	110.787
692	280011	1787.0	146.916
693	280012	1742.0	186.948
694	280013	1697.0	242.41
695	280014	1652.0	317.093
696	280015	1607.0	411.304
697	280016	1562.0	521.551
698	280017	1517.0	641.533
699	280018	1472.0	771.308
700	280019	1427.0	905.942
701	280020	1382.0	1044.324
702	280021	1337.0	1185.1220
703	280022	1292.0	1327.1412
704	280023	1247.0	1472.833
705	280024	1202.0	1614.524
706	280001	1116.00	1405.01
707	280002	24	
708	280003	10.5	0.0
709	280004	10.5	45.290
710	280005	10.5	50.1903
711	280006	10.5	55.093
712	280007	10.5	62.439
713	280008	10.5	7.2337
714	280009	10.5	1.252
715	280010	10.5	97.944
716	280011	19.0	114.757
717	280012	25.0	146.916
718	280013	28.0	186.948
719	280014	27.0	232.41
720	280015	29.0	317.093

723	300014	34.7	611.100
724	300016	50.0	521.551
725	300017	64.4	641.533
726	300018	73.6	771.309
727	300019	78.6	905.042
728	300020	72.7	1048.324
729	300021	60.5	1189.122
730	300022	58.0	1327.141
731	300023	39.4	1472.033
732	300024	26.1	1614.524
733	300025	15.8	1765.61
734			