NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

LER 81-07/3L

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	V T V Y S 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)		(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT	

CON'T

01	REPORT SOURCE L (6)	0 5 0 0 0 2 7 1 (7)	0 2 0 5 8 1 (8)	0 3 0 4 8 1 (9)	
		DOCKET NUMBER	EVENT DATE	REPORT DATE	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During surveillance testing, Torus-RB Vacuum Breaker ΔP switch DPIS 16-19-32A act-
03 uated at 0.504 psid and was above the T. S. 3.7.A.5.a limit of ≤ 0.5 psid. The
04 switch was immediately reset. Redundant switch DPIS 16-19-32B tested within limits
05 and was available. Based on the above, there were no adverse consequences to the
06 public health and safety. There were no previous reportable occurrences of this
07 type.
08

09	SYSTEM CODE I B (11)	CAUSE CODE X (12)	CAUSE SUBCODE Z (13)	COMPONENT CODE I N S T R U (14)	COMP. SUBCODE S (15)	VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR 8 1	—	SEQUENTIAL REPORT NO. 0 0 7	/	OCCURRENCE CODE 0 3	REPORT TYPE L	—	REVISION NO. 0

ACTION TAKEN E (18)	FUTURE ACTION Z (19)	EFFECT ON PLANT Z (20)	SHUTDOWN METHOD Z (21)	HOURS (22) 0 0 0 0	ATTACHMENT SUBMITTED N (23)	NPRD-4 FORM SUB. Y (24)	PRIME COMP. SUPPLIER A (25)	COMPONENT MANUFACTURER B 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The event was due to setpoint drift on the Barton Model 288 Differential Pressure
11 Indicating Switch. The switch was exercised, reset, and returned to service.
12
13
14

15	FACILITY STATUS E (28)	% POWER 1 0 0 (29)	OTHER STATUS (30) NA	METHOD OF DISCOVERY B (31)	DISCOVERY DESCRIPTION (32) Surveillance Test
16	ACTIVITY RELEASED Z (33)	CONTENT OF RELEASE Z (34)	AMOUNT OF ACTIVITY (35) NA		LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

17	NUMBER 0 0 0 (37)	TYPE Z (38)	DESCRIPTION (39) NA

PERSONNEL INJURIES

18	NUMBER 0 0 0 (40)	DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)

19	TYPE Z (42)	DESCRIPTION NA

PUBLICITY

20	ISSUED N (44)	DESCRIPTION (45) NA	NRC USE ONLY

8103090553

NAME OF PREPARER Warren P. Murphy PHONE: (802) 257-7711

GPO 917-926