



Portland General Electric Company

Portland, Oregon

March 2, 1981

Trojan Nuclear Plant  
Docket 50-344  
License NPF-1



Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Eisenhut:

Your letter of October 31, 1981 forwarded NUREG-0737, Clarification of TMI Action Plan Requirements to PGE for action.

On January 2, 1981 PGE indicated, under Action Item III.D.3.4, "Control Room Habitability Requirements", that a survey of railroad transportation of toxic materials within 5 miles of the Trojan plant had not been completed. This survey has now been completed, and the results show that transportation of ammonia by railroad along the east side of the Columbia River warrants additional protective measures for the Trojan Control Room. Therefore, PGE will install redundant ammonia detectors in the Control Room Ventilation System and prepare emergency procedures for dealing with ammonia releases. The detectors will alarm and isolate the Control Room Ventilation System (CB-2). This modification and associated emergency procedures will be completed by January 1, 1983.

Sincerely,

Bart D. Withers  
Vice President  
Nuclear

c: Mr. Lynn Frank, Director  
State of Oregon  
Department of Energy

Mr. Robert A. Clark, Chief  
Operating Reactors Branch No. 3  
Division of Licensing  
U. S. Nuclear Regulatory Commission

P

A046  
5/10

8103090594