



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76011

24 FEB 1981

Docket No. 50-285/80-16



Omaha Public Power District
Attn: W. C. Jones, Division Manager
Production Operations
1623 Harney Street
Omaha, Nebraska 08102

Gentlemen:

Thank you for your letters of January 21, 30, and February 6, 1981, in response to our letter and the attached Notice of Violation dated December 27, 1980. In addition, telephone contact with members of your staff provided the following additional information with respect to significant finding C: In determining gamma exposures from TLD readings the same sensitivity factor is used for plant exposures as the Battelle Labs TLD study and the 132 MR control exposure is used to confirm the Battelle calibration curve. With respect to neutron exposures, different sensitivity factors are used since plant neutron exposures are of much lower energy. We have no further questions at this time and we will review your corrective actions during a future inspection.

Sincerely,

Karl V. Seyfrit
Karl V. Seyfrit
Director