

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
March 6, 1981

Docket No. 50-293

Mr. A. Victor Morisi
Boston Edison Company
M/C Nuclear
800 Boylston Street
Boston, Massachusetts 02199



Dear Mr. Morisi:

SUBJECT: BWR SCRAM DISCHARGE SYSTEM - LONG TERM MODIFICATIONS

REFERENCE: (A) BECO 81-38 FEBRUARY 13, 1981

(B) BECO 80-286 NOVEMBER 13, 1980

The staff has reviewed references (A) and (B) and determined that your commitments do not satisfy our criteria. We request that you modify your commitments to comply with the following:

1. The modifications must be complete by December 31, 1982.
2. The design must include our criterion on Diverse Instrumentation (Safety Criterion 3 in Generic SER on BWR SCRAM DISCHARGE SYSTEM, December 1, 1980).
3. Revised TS's may be required prior to operation with the modified systems and if so, must be proposed at least 3 months in advance of the modification completion dates.

Please provide a response to this request within 30 days of receipt.

Thank you for your cooperation.

Sincerely,

Thomas A. Ippolito
Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

8108120 812

March 6, 1981

Mr. A. Victor Morisi
Boston Edison Company

cc:

Mr. Richard D. Machon
Pilgrim Station Manager
Boston Edison Company
RFD #1, Rocky Hill Road
Plymouth, Massachusetts 02360

Henry Herrmann, Esquire
Massachusetts Wildlife Federation
151 Tremont Street
Boston, Massachusetts 02111

Plymouth Public Library
North Street
Plymouth, Massachusetts 02360

Resident Inspector
c/o U. S. NRC
P. O. Box 867
Plymouth, Massachusetts 02360