



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
March 6, 1981

TERA

Docket No. 50-298

Mr. J. M. Pilant, Director
Licensing and Quality Assurance
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601



Dear Mr. Pilant:

SUBJECT: BWR SCRAM DISCHARGE SYSTEM - LONG TERM MODIFICATIONS

REFERENCE: (A) YOUR LETTER OF DECEMBER 15, 1980

The staff has reviewed reference (A) and determined that your commitments do not satisfy our criteria. We request that you modify your commitments to comply with the following:

1. The design must include our criterion on Diverse Instrumentation (Safety Criterion 3 in Generic SER on BWR SCRAM DISCHARGE SYSTEM, December 1, 1980).

Please provide a response to this request within 30 days of receipt.

Thank you for your cooperation.

Sincerely,

Thomas A. Ippolito
Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

Mr. J. M. Pilant
Nebraska Public Power District

- 2 -

March 6, 1981

cc:

Mr. G. D. Watson, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney
Snell & Wilmer
3100 Valley Center
Phoenix, Arizona 85073

Cooper Nuclear Station
ATTN: Mr. L. Lessor
Station Superintendent
P. O. Box 98
Brownville, Nebraska 68321

Auburn Public Library
118 - 15th Street
Auburn, Nebraska 68305

Mr. Dennis Dubois
USNRC
Resident Inspector
P. O. Box 446
Nebraska City, NA 68410