



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

March 4, 1981

Mr. R. H. Engelken, Director
Region V Office of Inspection & Enforcement
1990 North California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, CA 94596



Re: Operating License DPR-54
Docket No. 50-312
Reportable Occurrence 81-12

Dear Mr. Engelken:

In accordance with Technical Specifications Section 6.9.4.1(e) and Regulatory Guide 1.16, Revision 4, Section C.2.a(5), the Sacramento Municipal Utility District reports the following Licensee Event Report Number 81-12.

On March 3 while performing the "Reactor Protection System" calibration, the setpoints for the High Reactor Building Pressure were higher than allowed by the Technical Specifications. The limit established by the Technical Specification is 4 psig. The four channels A, B, C and D were measured to be 4.08, 4.03, 4.05, and 4.05 respectively. The administrative setpoint for this parameter is $3.9 \pm .05$ psig.

Mr. H. Canter, resident NRC Inspector, was informed of this event today by Mr. R. Colombo.

A complete report will be submitted to your office within fourteen days.

Respectfully submitted,

R. P. Oubre
Plant Superintendent

RPO:RWC:rm



5

A002
5/11



8108130561

81-41

