

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C A S O S I | 0 0 - 0 0 0 0 0 0 - 0 0 | 4 1 1 1 1 | _____
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | L | 0 5 0 0 0 2 0 6 | 0 5 1 6 8 0 | _____
7 8 60 61 66 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | DURING THE CURRENT REFUELING OUTAGE WHILE PERFORMING RADIOGRAPHIC EXAMINATION
0 3 | OF MAIN STEAM LINES INSIDE CONTAINMENT, SIX WELDS WERE FOUND WITH INDICATIONS IN
0 4 | EXCESS OF THOSE PERMITTED BY ASME B&PV CODE, SECTION I. FIVE OF THE WELDS HAVE
0 5 | FLAWS CONSISTING OF SLAG INCLUSIONS AND/OR LACK OF PENETRATION. ONE WELD HAS THREE
0 6 | SMALL CRACKS IN THE ROOT. THERE WERE NO ADVERSE EFFECTS ON PUBLIC HEALTH AND
0 7 | SAFETY.

0 9 | SYSTEM CODE: C C (11) CAUSE CODE: B (12) CAUSE SUBCODE: C (13) COMPONENT CODE: P I P E X X (14) COMP SUBCODE: E (15) VALVE SUBCODE: Z (16)
17 | LER NO REPORT NUMBER: 8 0 (21) SEQUENTIAL REPORT NO.: 0 2 4 (24) OCCURRENCE CODE: 0 1 (28) REPORT TYPE: T (30) REVISION NO.: 1 (32)
18 | ACTION TAKEN: X (33) FUTURE ACTION: X (34) EFFECT ON PLANT: Z (35) SHUTDOWN METHOD: Z (36) HOURS: 0 0 0 0 (37) ATTACHMENT SUBMITTED: N (41) NRPD-4 FORM SUB: N (42) PRIME COMP SUPPLIER: A (43) COMPONENT MANUFACTURER: B 1 3 0 (44)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | THE INDICATIONS APPARENTLY HAVE EXISTED IN THE LINE FROM ORIGINAL PLANT CONSTRUCTION.
1 1 | ALL WELDS WERE REPAIRED UNDER SECTION XI REQUIREMENTS.
1 2 | _____
1 3 | _____
1 4 | _____

1 5 | FACILITY STATUS: H (28) % POWER: 0 0 0 (29) OTHER STATUS: N/A (30) METHOD OF DISCOVERY: C (31) DISCOVERY DESCRIPTION: RADIOGRAPHIC EXAMINATION (32)

1 6 | ACTIVITY CONTENT RELEASED: Z (33) AMOUNT OF ACTIVITY: N/A (35) LOCATION OF RELEASE: N/A (36)

1 7 | PERSONNEL EXPOSURES: NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: N/A (39)

1 8 | PERSONNEL INJURIES: NUMBER: 0 0 0 (40) DESCRIPTION: N/A (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: TYPE: Z (42) DESCRIPTION: N/A (43)

2 0 | PUBLICITY ISSUED: Z (44) DESCRIPTION: N/A (45) PDR: 8107090247 810708 PDR ADOCK 05000206 PDR S

NAME OF PREPARER: J. M. CURRAN PHONE: (714) 492-7700