

JUN 29 1981

Docket File
DMB
MS-016

Docket Nos. 50-317
and 50-318



Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors #3
Division of Licensing

cc: See next page

DISTRIBUTION:

Docket File
NRC PDR
L PDR
NSIC
TERA
ORB #3 Rdg
D. Eisenhut
OELD
OI&E (3)
R.A. Clark
M. Conner
P.M. Kreutzer (3)

ACRS (10)
J. Heltemes
Gray Files

8107100008 810629
PDR ADOCK 05000317
P PDR

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL			
SURNAME	PMKreutzer	MConner/ep	RAClark			
DATE	6/29/81	6/29/81	6/29/81			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 29 1981

Docket Nos. 50-317
and 50-318

Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

A handwritten signature in dark ink, appearing to read "Robert A. Clark".

Robert A. Clark, Chief
Operating Reactors #3
Division of Licensing

cc: See next page

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Judd
Chief Nuclear Engineer
16740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. P. W. Kruse, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Public Document Room
Calvert County Library
Prince Frederick, MD 20678

Director, Department of State Planning
301 West Preston Street
Baltimore, MD 21201

Mr. R. M. Douglass, Manager
Quality Assurance Department
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. T. L. Sydor, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: EIS Coordinator
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, MD 20014

Mr. J. A. Tierman, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Tawes State Office Building
Annapolis, MD 21204