

DMB
MS-016

JUN 29 1981

Docket No. 50-285



Mr. W.C. Jones
Division Manager, Production
Operations
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Jone

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors #3
Division of Licensing

cc: See next page

DISTRIBUTION:

Docket File	P.M. Kreutzer (3)
NRC PDR	ACRS (10)
L PDR	J. Heltemes
NSIC	Gray Files
TERA	
ORB #3Rdg	
D. Eisenhut	
OELD	
OI&E (3)	
R.A. Clark	
C. Trammell	

B107100055 B10629
PDR ADOCK 05000285
P PDR

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL			
SURNAME	PMKreutzer	CTrammell/ep	RAClark			
DATE	6/29/81	6/29/81	6/29/81			

Omaha Public Power District

cc:

Marilyn T. Shaw, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D. C. 20036

Mr. Emmett Rogert
Chairman, Washington County
Board of Supervisors
Blair, Nebraska 68023

Omaha Public Power District
ATTN: Mr. Spencer Stevens
Plant Manager
Fort Calhoun Plant
1623 Harney Street
Omaha, Nebraska 68102

Mr. Frank Gibson
W. Dale Clark Library
215 South 15th Street
Omaha, Nebraska 68102

Alan H. Kirshen, Esq.
Fellman, Ramsey & Kirshen
1166 Woodmen Tower
Omaha, Nebraska 68102

Mr. Dennis Kelley
U.S.N.R.C. Resident Inspector
P. O. Box 68
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U.S. Environmental Protection Agency
Washington, D. C. 20460

U.S. Environmental Protection Agency
Region VII
ATTN: EIS COORDINATOR
324 East 11th Street
Kansas City, Missouri 64106

Director, Nebraska Department of
Environmental Control
P. O. Box 94877, State House Station
Lincoln, Nebraska 68509