

July 8, 1981

Docket No. 50-219
LS05-81-07-013



Mr. I. R. Finfrock, Jr.
Vice President - Jersey Central
Power & Light Company
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Finfrock:

SUBJECT: SEP TOPIC V-11.A, REQUIREMENTS FOR ISOLATION OF HIGH AND
LOW PRESSURE SYSTEMS, SAFETY EVALUATION FOR OYSTER CREEK

The enclosed staff safety evaluation supplements our contractor's evaluation that has been made available to you previously. This evaluation is consistent with the findings in our safety evaluation on Topic V-11.A which proposes modifications to the RWCU valve indication and control circuits.

The need to actually implement these changes will be determined during the integrated plant safety assessment. This topic assessment may be revised in the future if your facility design is changed or if NRC criteria relating to this topic are modified before the integrated assessment is completed.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch No. 5
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

8107130408 810708
PDR ADOCK 05000219
P PDR

SEO4
S11
DSU USE EX(SI)

OFFICE	SEPB:DL	SEPB:DL	SEPB:DL	ORB#5:DL:PM	ORB#5:DL:C	AD:SA:DL
SURNAME	Bochoi:dk	RHermann	WRussell	JLombard	DCrutchfield	Glainac
DATE	6/2/81	6/22/81	7/1/81	6/24/81	7/7/81	7/7/81

Mr. I. R. Finfrock, Jr.

cc

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1200 M Street, N. W.
Washington, D. C. 20036

J. B. Lieberman, Esquire
Berlack, Israels & Lieberman
26 Broadway
New York, New York 10004

Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20006

J. Knubel
BWR Licensing Manager
Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Joseph W. Ferraro, Jr., Esquire
Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
1100 Raymond Boulevard
Newark, New Jersey 07012

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723

Mayor
Lacey Township
P. O. Box 475
Forked River, New Jersey 08731

Commissioner
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

U. S. Environmental Protection
Agency
Region II Office
ATTN: EIS COORDINATOR
26 Federal Plaza
New York, New York 10007

Gene Fisher
Bureau Chief
Bureau of Radiation Protection
380 Scotts Road
Trenton, New Jersey 08628

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Licensing Supervisor
Oyster Creek Nuclear Generating
Station
P. O. Box 388
Forked River, New Jersey 08731

Resident Inspector
c/o U. S. NRC
P. O. Box 445
Forked River, New Jersey 08731

TOPIC: V-11.A REQUIREMENTS FOR ISOLATION OF HIGH AND LOW PRESSURE SYSTEMS

I. INTRODUCTION

Several systems that have a relatively low design pressure are connected to the reactor coolant pressure boundary. The valves that form the interface between the high and low pressure systems must have sufficient redundancy and interlocks to assure that the low pressure systems are not subjected to coolant pressures that exceed design limits. The problem is complicated since under certain operating modes (e.g., shutdown cooling and ECCS injection) these valves must open to assure adequate reactor safety.

II. REVIEW CRITERIA

The review criteria are presented in Section 2 of EG&G Report 1309F, "Isolation of High and Low Pressure Systems."

III. RELATED SAFETY TOPICS AND INTERFACES

The scope of review for this topic was limited to avoid duplication of effort since some aspects of the review were performed under related topics. The related topics and the subject matter are identified below. Each of the related topic reports contain the criteria and review guidance for its subject matter.

V-10.B RHR Reliability
VI-4 Containment Isolation

Topic V-11.B is dependent on the present topic information for completion.

IV. REVIEW GUIDELINES

The review guidelines are presented in Section 7.3 of the Standard Review Plan.

V. EVALUATION

As noted in EG&G Report 1309F, "Isolation of High and Low Pressure Systems," the Oyster Creek Nuclear Station has two systems with a lower design pressure rating than the RCS that are directly connected to the RCS. These systems are the Core Spray (CS) and the Reactor Water Cleanup (RWCU) Systems. The RWCU system does not satisfy the staff's requirements because the redundant pressure interlocks are not provided and the check valves do not have position indication in the control room.

VI. CONCLUSIONS

Because of the severe consequences of a LOCA outside of containment the staff proposes that: 1) redundant interlocks should be installed on the RWCU suction valve; 2) the indication and control of the RWCU discharge valves should be modified to satisfy the interlock provisions of SRP Section 6.3 and BTP RSB 5-1; and/or 3) RWCU discharge check valve position indication circuits as specified in BTP-ICSB 3 should be provided.