

15.6.11 RADIATION PROTECTION PROGRAM

Specification

Radiological control procedures shall be written and made available to all station personnel, and shall state permissible radiation exposure levels. The radiation protection program shall meet the requirements of 10 CFR 20, with the exception of the following:

Paragraph 20.203 - Caution signs, labels and signals

In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mRem/hr but less than 1000 mRem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit* as described in Point Beach Nuclear Plant Health Physics Administrative Control Policies and Procedures Manual, Section 2.7. Any individual or group of individuals permitted to enter such areas shall be provided with at least one of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of these conditions.
- c. Coverage by an individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance as specified by the facility Health Physics Supervisor on the Radiation Work Permit.

The requirements above shall also apply to each high radiation area in which the intensity of radiation is greater than 1000 mRem/hr. In addition, locked doors shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Duty Shift Supervisor and the plant Health Physicist.

*Health Physics qualified personnel or personnel escorted by Health Physics personnel shall be exempt from the Radiation Work Permit issuance requirement during the performance of their assigned radiation protection duties, provided they comply with approved radiation protection procedures as they relate to entry into high radiation areas.