

JUN 30 1981

Docket Nos. 50-317
and 50-318

Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

By letters dated March 19 and May 18, 1981, you requested exemptions to 10 CFR 50, Appendix R for the Calvert Cliffs Nuclear Power Plant, Units Nos. 1 and 2. The specific exemption requests are:

- o Section III.E - Hydrostatic Hose Test
- o Section III.0 - Oil Collection Systems for Reactor Coolant Pumps
- o Section III.G.2 - Fire Barriers
- o Section III.G.3 - Alternative Shutdown

We have found agreement with your and other licensee's argument that Section III.E requirements for hydrostatic hose tests exceed the NFPA 196 requirements. Changes to Section III.E are presently being made so no exemption will be required for this item.

In our review of your RCP lube oil collection system, we find the system installed at both units meets the Section III.0 requirements. Therefore, no exemption is necessary for this requirement.

In regard to the use of water curtains for certain openings in fire barriers (addressed in March 19, 1981 submittal), we find that your request provides a sound technical basis warranting further staff review. The schedule requirements for this item are, therefore, suspended in accordance with 10 CFR 50.48(c)(6) until final Commission action on this request.

Your request for exemption from the provisions of 10 CFR 50.48(c)(5) regarding the submittal of your plans and schedules for complying with 10 CFR 50, Appendix R, Item III.G.3, on alternative shutdown capability, is under review and will be the subject of separate correspondence.

8107140287 810630
PDR ADOCK 05000317
P PDR

OFFICE					
SURNAME					
DATE					

Docket File
DMB - MS-016

In response to your May 18, 1981 request, we have reviewed your Summary of the April 23, 1981 Phone Conservation, (BG&E/NRC) and conclude that your understanding is basically correct.

Sincerely,

[Signature]
Original Signature
E. G. Case

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File

50-317

- NRC PDR
- Local PDR
- ORB #3 Rdg
- D. Eisenhut
- OELD
- OI&E (3)
- R. A. Clark
- M. Conner
- P. Kreutzer
- NSIC
- TERA
- ACRS (10)
- J. Heltemes
- R. Ferguson



[Signature]
DL:OR
T.M.lovak
6/18/81

OFFICE	DL:ORB#3	DL:ORB#3	DL:ORB#5	DE	DL:ORB#3	DL:OR	NRA
SURNAME	<i>[Signature]</i> PKreutzer	<i>[Signature]</i> MConner	<i>[Signature]</i> TWambach	<i>[Signature]</i> RFerguson	<i>[Signature]</i> RAClark	<i>[Signature]</i> DGEisenhut	<i>[Signature]</i> HRDenton
DATE	6/10/81	6/11/81	6/12/81	6/16/81	6/17/81	6/23/81	6/18/81



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 3 0 1981

Docket Nos. 50-317
and 50-318

Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

By letters dated March 19 and May 18, 1981, you requested exemptions to 10 CFR 50, Appendix R for the Calvert Cliffs Nuclear Power Plant, Units Nos. 1 and 2. The specific exemption requests are:

- Section III.E - Hydrostatic Hose Test
- Section III.0 - Oil Collection Systems for Reactor Coolant Pumps
- Section III.G.2 - Fire Barriers
- Section III.G.3 - Alternative Shutdown

We have found agreement with your and other licensee's argument that Section III.E requirements for hydrostatic hose tests exceed the NFPA 196 requirements. Changes to Section III.E are presently being made so no exemption will be required for this item.


In our review of your RCP lube oil collection system, we find the system installed at both units meets the Section III.0 requirements. Therefore, no exemption is necessary for this requirement.

In regard to the use of water curtains for certain openings in fire barriers (addressed in March 19, 1981 submittal), we find that your request provides a sound technical basis warranting further staff review. The schedule requirements for this item are, therefore, suspended in accordance with 10 CFR 50.48(c)(6) until final Commission action on this request.

Your request for exemption from the provisions of 10 CFR 50.48(c)(5) regarding the submittal of your plans and schedules for complying with 10 CFR 50, Appendix R, Item III.G.3, on alternative shutdown capability, is under review and will be the subject of separate correspondence.

In response to your May 18, 1981 request, we have reviewed your Summary of the April 23, 1981 Phone Conversation, (BG&E/NRC) and conclude that your understanding is basically correct.

Sincerely,

A handwritten signature in cursive script, appearing to read "Harold R. Denton".

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

cc: See next page

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potis and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Judd
Chief Nuclear Engineer
15740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. P. W. Kruse, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Public Document Room
Calvert County Library
Prince Frederick, MD 20678

Director, Department of State Planning
301 West Preston Street
Baltimore, MD 21201

Mr. R. M. Douglass, Manager
Quality Assurance Department
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. T. L. Sydor, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: EIS Coordinator
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, MD 20014

Mr. J. A. Tierman, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Tawes State Office Building
Annapolis, MD 21204