

DMB 016

DISTRIBUTION

- Docket
- NRC PDR
- L-PDR
- TERA
- NSIC
- ORB#1 Rdg
- Deisenhut
- OELD
- IE-3
- ACRS-10
- SVarga
- CParrish
- DChaney
- Gray File

JUN 29 1981

Docket No. 50-334

Mr. J. J. Carey, Vice President  
 Duquesne Light Company  
 Nuclear Division  
 Post Office Box 4  
 Shippingport, Pennsylvania 15077



Dear Mr. Carey:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by:  
 S. A. Varga

Steven A. Varga, Chief  
 Operating Reactors Branch #1  
 Division of Licensing

cc: See next page

B107150125 B10629  
 PER ADOCK 05000334  
 P PDR

OFFICE	ORB#1:DL	ORB#1:DL				
SURNAME	DChaney:ds	SVarga				
DATE	6/24/81	6/29/81				

DISTRIBUTION

Docket  
NRC PDR  
L. PDR  
TERA  
NSIC  
ORB#1 Rdg  
Deisenhut  
OELD  
IE-3  
ACRS-10  
SVarga  
CParrish  
DChaney  
Gray File

JUN 29 1981

Docket No. 50-334

Mr. J. J. Carey, Vice President  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Dear Mr. Carey:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by:  
S. A. Varga

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc: See next page

OFFICE	ORB#1:DL	ORB#1:DL					
SURNAME	DChaney:ds	SVarga					
DATE	6/28/81	6/29/81					

Mr. J. J. Carey  
Duquesne Light Company

cc: Mr. R. J. Washabaugh, QA Manager  
Duquesne Light Company  
Quality Assurance Department  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. J. A. Werling  
Station Superintendent  
Duquesne Light Company  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. T. D. Jones, Manager  
Nuclear Operations  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. F. J. Bilsert, Manager  
Nuclear Support Services  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. R. M. Mafrice, Nuclear Engineer  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin, Nuclear Engineer  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. N. R. Tonet, Manager  
Nuclear Engineering  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. J. D. Sieler, Manager  
Nuclear Safety & Licensing  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Karin Carter, Esquire  
Special Assistant Attorney General  
Bureau of Administrative Enforcement  
5th Floor, Executive House  
Harrisburg, Pennsylvania 17120

Mr. Roger Tappan  
Stone & Webster Engineering Corporation  
P. O. Box 2325  
Boston, Massachusetts 02107

Mr. F. Noon  
R & D Center  
Westinghouse Electric Corporation  
Building 7-303  
Pittsburgh, Pennsylvania 15230

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburgh, Pennsylvania 15219

Mr. John A. Levin  
Public Utility Commission  
P. O. Box 3265  
Harrisburg, Pennsylvania 17120

Irwin A. Popowsky, Esquire  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

Charles E. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077