


NUCLEAR REGULATORY COMMISSION

T-0883



In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
255TH GENERAL MEETING

DATE: July 10, 1981 PAGES: 140 - 347

AT: Washington, D. C.

TROY
1/0
DELETE:
B. White

RECEIVED
ADVISORY
REACTOR
JUL 10 1981
7 8 9 10 11 12 1 2 3 4 5 6

TR04
delete
B. White

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8107150162 810710
PDR ACRS
T-0883 PDR

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3
4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5
6 255TH GENERAL MEETING

7 - - -

8 Nuclear Regulatory Commission
9 1717 H Street, N.W.
10 Room 1046
11 Washington, D.C.

12 Friday July 10, 1981

13 The 255th meeting of the Advisory Committee on
14 Reactor Safeguards was convened at 8:30 a.m.

15 MEMBERS PRESENT:

16 J.C. MARK, Chairman
17 P.G. SHEWMON, Vice-Chairman
18 C.P. SIESS
19 D.W. MOELLER
20 M. BENDER
21 W. KEPR
22 M.W. CARBON
23 W.M. MATHIS
24 D.A. WARD
25 D. OKRENT
J.J. RAY

DESIGNATED FEDERAL EMPLOYEE:

R. MAJOR

ALSO PRESENT:

J.M. JACOBS, Secretary

Present for the NRC and Industry:

Mr. Clark
Mr. Hukill
Mr. Novak

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

Mr. Arnold
Mr. Broughton
Mr. Croneberger
Mr. Behrle
Mr. Tedesco
Mr. Phillips
Mr. Chestnut
Mr. Rogin
Mr. Chow
Mr. Stolz
Mr. Chisholm
Mr. Tadani
Mr. Broughton
Mr. Croneberger

1 trying to avail oneself of the microphone.

2 We will now begin the meeting, and the first item
3 today is to hear the state of discussions on the possible
4 restart of TMI-1. I understand that some of the Met Ed
5 people, who were coming down extra-fast by private plane,
6 haven't arrived yet, but are expected to be here shortly.
7 But I believe we have the basis for starting off.

8 Dade, do you want to take this over?

9 MR. MOELLER: Thank you, Mr. Chairman. I wanted
10 to provide the Committee with the report of the
11 Subcommittee's view. The Subcommittee held a meeting on
12 June 25 and 26 to review modifications made to the plant and
13 to consider their application for restart.

14 This was the third such meeting at which these
15 issues had been discussed. A previous Subcommittee meeting
16 had been held on January 31st and February 1, 1980, in
17 Middletown, Pennsylvania; and again, we had a Subcommittee
18 meeting on November 28 and 29, 1980, here in Washington,
19 D.C.

20 Attending the latest Subcommittee meeting were
21 William Kerr, Charles Mathis, and Harold Etherington, in
22 addition to myself. And we had at this Subcommittee the
23 following consultants, who assisted us in the review: I.
24 Catton, W. Keyserling, W. Lipinski, and Z. Zudans.

25 As background for the current review, I wanted to

1 note that the Committee in its interim or status report that
2 it entered on December 11, 1980, mentioned five items that
3 they wanted to closely follow, and you may want to give
4 these attention during today's meeting:

5 One was the status of reliability assessments of
6 the plant as modified;

7 Two was the instrumentation for assessment of
8 inadequate core cooling;

9 Three was the instrumentation for monitoring the
10 position of the pressurizer PORV;

11 Four was thermal mechanical effects of high
12 pressure injection on the reactor pressure vessel integrity
13 for a small break LOCA with no emergency feedwater flow;

14 And the fifth item was the consequences of D.C.
15 power failure.

16 Also at our Subcommittee meeting, we not only
17 addressed each of these items, but we addressed the matter
18 of the additional remarks in our December 11, 1980, letter
19 relative to the need for studies on hydrogen control and
20 filtered venting containment systems.

21 In the way of background, I might also mention
22 that TMI-1 is being treated as an operating reactor for
23 purposes of restart. It is not being treated as an NTOL.

24 In terms of the Subcommittee meeting, the latest
25 Subcommittee meeting, I wanted to mention several items.

1 One was the instrumentation for the assessment of inadequate
2 core cooling. This situation, as you know, is a generic
3 one, and the problem for TMI-1 is much the same as it is for
4 other plants. The TMI group has reviewed the full range of
5 possibilities and weighed the advantages and disadvantages
6 of each. However, they oppose such instrumentation,
7 specifically an RPV liquid level gauge. But the NRC's
8 position is that such will be required of them on a schedule
9 which they will tell you, I'm sure, this morning.

10 The Subcommittee members quizzed the NRC staff
11 regarding the decision to require a higher PORV set point
12 and a lower trip set point, the end of that being to reduce
13 the frequency of PORV openings. Again, this is a generic
14 matter which is still under dispute. And we still were
15 unable to obtain any real information on a quantitative
16 estimate of whether this does reduce risk and by how much.

17 Another question that came up in the Subcommittee
18 meeting was the setting of the containment purge valves,
19 which are set at 30 degrees for regular operation. And then
20 the staff -- or the tech specs are written to say that 4
21 psig containment pressure will be one of the signals for
22 containment isolation. Several of our consultants
23 questioned whether a containment with the purge valve set at
24 30 degrees would ever reach 4 psig, and therefore was this
25 particular signal of any value in terms of containment

1 isolation.

2 The TMI-1 group has responded to most of the
3 studies requested in our December 11, 1980 letter, except
4 those in the additional comments. That is again, hydrogen
5 control and vented filtered containment. In general, we
6 concluded that a more positive demonstration of progress
7 should be encouraged. If a problem is generic, the Licensee
8 appears at times to be satisfied to leave the resolution to
9 others, namely to groups like EPRI or the vendors. And we
10 tried in our Subcommittee meeting to point out to them that
11 we desired more action independently on their part in
12 resolving these issues.

13 Our review of the human factors aspects of the
14 control room left some items unresolved. Some instruments
15 upon failing will read at mis-scale. Our consultant thought
16 that was not a good policy. Certain dial settings are
17 inconsistent with conventional approaches, meaning that the
18 needles move in different directions than what would
19 normally be expected. Improvised labels are to be
20 controlled administratively. We weren't sure that that was
21 the best approach there.

22 We felt that security needed special attention, in
23 view of the continuing activities to decontaminate Unit 2.
24 A comprehensive review of the security matters at TMI-1 had
25 been done independently by the Los Alamos National Lab, and

1 the Licensee is moving to implement these recommendations.
2 We covered this in a closed session during the Subcommittee
3 meeting and we did not plan it to be on the agenda today for
4 the full Committee.

5 Emergency planning we reviewed, particularly the
6 drill held early in June, which the reports we received
7 indicated that it was quite successful. FEMA has conducted
8 an independent assessment of these aspects and is providing
9 information to the NRC staff on emergency matters. They
10 have a plan for a startup test program at TMI-1 and it's
11 comparable, with some differences, to that which you have
12 already reviewed for Sequoyah and other plants.

13 I would like also to bring to your attention one
14 other matter which was discussed at the Subcommittee
15 meeting, and that is the House Committee report which, after
16 an in-depth study of the TMI-2 accident, indicated that it
17 was their belief that the Licensee willfully withheld
18 information on the severity of the TMI-2 accident from
19 federal and state officials. The report, which you have
20 also seen, by Ed Abbott indicated a somewhat similar
21 conclusion.

22 Now, the report of the NRC I&E group, on the other
23 hand, as I understand it, attributes the lack of information
24 to a number of causes, but ascribes a predominant amount of
25 it to the confusion that accompanied the situation.

1 In planning for the restart of TMI-2 and whether
2 we would issue a favorable letter on the Licensee's request,
3 we have to look at this matter. Now, the Licensee has made
4 a number of organizational changes and has issued a
5 directive to their staff which was read to us during the
6 Subcommittee meeting indicating and requiring that if an
7 accident should occur in the future that they are to provide
8 state and federal officials with complete and accurate
9 information.

10 So our task today as I see it, among many other
11 things, will be to assure ourselves that steps taken by the
12 Licensee are adequate to assure a free flow of accurate
13 information should TMI-1 restart and should at some time in
14 the future some type of an accident occur.

15 MR. OKRENT: Is it our task somehow to arrive at
16 some judgment as to what was the situation around the time
17 of the TMI-2 accident? Is that an issue here?

18 MR. MOELLER: Speaking personally, a personal
19 opinion, I do not feel qualified in terms of being a lawyer,
20 a criminal justice, or whatever it would be, to make that
21 decision. However, I do believe firmly that it is our
22 responsibility to assure ourselves that whatever the
23 situation was, that steps have been taken to correct it.

24 MR. OKRENT: Does the staff feel that from their
25 point of view that a decision with regard to just what

1 transpired or did not transpire during the TMI-2 accident is
2 somehow a go or no-go situation or bears directly on their
3 view of restart of TMI-1?

4 MR. MOELLER: Tom Novak?

5 MR. NOVAK: Tom Novak from the staff.

6 Certainly the staff has reviewed the event in much
7 detail. There is a comprehensive report and position by the
8 Office of Inspection and Enforcement. Those views represent
9 the views of the staff.

10 It's my opinion that as we have gone through the
11 TMI-1 restart that it's a separable issue in the sense that
12 we have been asked to judge the adequacy of the management
13 of the organization that would operate TMI-1, the emergency
14 planning and all other features necessary to cope with a
15 possible accident, and to ensure ourselves that those
16 provisions that are being provided by the Licensee satisfy
17 the requirements of the Commission and the requirements that
18 the staff believes are a correct interpretation of the
19 Commission's order for restart.

20 So in my view this issue is not directly
21 appropriate for decision on the restart of TMI-1. I believe
22 that there has been a lot of work, and I think in the
23 Subcommittee meetings this has been voiced by the staff, in
24 trying to understand the conditions and the events that
25 occurred immediately following the accident. And we have

1 tried to make our views as clear as we can and they are
2 there for the Commission to appreciate and to use as they
3 feel appropriate.

4 I don't think I have any other comments to make at
5 this time.

6 MR. MOELLER: Dr. Plesset had a comment, and then
7 Mr. Bender.

8 MR. PLESSET: I was going to wait until you finish
9 the report.

10 MR. MOELLER: I have finished it. The one item
11 remaining is I'll call on the other Subcommittee members who
12 were present.

13 MR. PLESSET: I will make very briefly a few
14 comments. I am sure that you followed, as did the staff,
15 how the action plan was implemented at TMI-1. I just wanted
16 to say, I don't believe that just implementing the action
17 plan means the plant will operate safely. I think there is
18 too much thought given to that as a cure-all. That's one
19 remark I was going to make.

20 The other one is, I couldn't care less about an
21 analysis of filtered vented containment at TMI that
22 management would bring in. I don't think that's particular
23 of concern as far as safe operation of the plant goes.

24 My point I want to make is, I think that the
25 accident at TMI-2 has put too much blame on operators. I

1 think the basic point -- and this has been made in some
2 reports and reviews of the subject by the management -- I
3 think the central point, more important than the other
4 things I have just mentioned, is how is the management
5 there? Is it really going to be competent, because if it
6 isn't it's a very serious thing to let these people operate
7 a nuclear plant.

8 If it's been fixed, that's worth knowing. If it
9 hasn't been fixed or has weaknesses, I think we have to know
10 that, and I think this is a central issue. I don't think we
11 want to get into legalities. That's my point. All we're
12 concerned about is is this group of people fit to run a
13 plant, because aside from any changes that might have taken
14 place the answer would ordinarily be expected to be know,
15 unless there's been really drastic changes, and one would
16 want to have a very definite demonstration of this. And I
17 should think both the Committee and the staff would need to
18 be reassured very strongly on this point.

19 That's all I wanted to say.

20 MR. MOELLER: Thank you.

21 Mr. Bender?

22 MR. BENDER: I wanted to address the matter of
23 communications, because it seems to be the main thing on
24 this particular plant operation. I don't think it's unique
25 to TMI-1. In rehashing the circumstances at TMI-2, it

1 hardly seems to be appropriate.

2 It seems to me that it's a two-way street.

3 Undoubtedly we need to make sure that the Applicant, the
4 Licensee, knows what his obligations are and that probably
5 ought to be explored some if it hasn't been. On the other
6 hand, I haven't learned enough about the capabilities on the
7 other side to know that the information provided is and will
8 be used knowledgeably.

9 There's some suggestion that a great deal of
10 information should be imparted to the state authorities and
11 the NRC. We have had some searching discussions as to how
12 the NRC should use the information which it receives and how
13 much it should receive. Now, I find a total lack of
14 understanding as to whether there is an NRC position on it,
15 whether the Commissioners have sanctioned the knowledge that
16 the NRC is requiring. And I have some doubt as to whether
17 the state officials have the kind of competence that would
18 enable them to deal with detailed information on the
19 operating status of a plant.

20 And so I think we need to think some about how we
21 will respond to a question of adequate communications.

22 MR. MOELLER: Thank you.

23 Let me call upon Mr. Kerr or Mr. Mathis. And I
24 guess Mr. Etherington is not here. Mr. Kerr, did you have
25 any comments?

1 MR. KERR: I would say that we have heard from the
2 Applicant in the number of meetings that you have mentioned,
3 a considerable amount of detail about the reorganized
4 management. It involves both new people and new
5 organizations, and that is part of our consideration.

6 It seems to me that efforts have been made both to
7 improve the organization and to add to the capability of
8 both management and the operating organization, and I would
9 judge that these changes represent significant
10 improvements.

11 MR. MOELLER: Thank you.

12 Mr. Mathis?

13 MR. MATHIS: I might make just one additional
14 comment that follows up on what Mike had to say. In our
15 review in the Subcommittee meeting there were discussions
16 concerning the ability of the state people to know enough to
17 ask the right questions during an emergency, and I think
18 there is an admission on their part, as you pointed out,
19 that there is a deficiency there and they've got some work
20 to do, too. I think that's all I have to add.

21 MR. MOELLER: Thank you.

22 Dr. Okrent?

23 MR. MARK: You mentioned that the containment
24 isolation, I believe it was, was set at 30 degrees.

25 MR. MOELLER: The purge valves.

1 MR. MARK: Do they close at 30 degrees? Is that
2 Fahrenheit or Centigrade or what?

3 MR. MOELLER: No, that's the angle of the
4 setting.

5 MR. KERR: Zero degrees is closed, I think. 30
6 degrees is 30 degrees open.

7 MR. MARK: Okay.

8 MR. SHEWMON: Is it half open?

9 MR. MARK: That's about half of it.

10 MR. KERR: The idea is that they will be able to
11 close against the flow that would result in an accident if
12 they're set at this point, whereas they probably might not
13 be able to close if they were set at a more open position, I
14 think. That's my understanding.

15 MR. MOELLER: Mr. Okrent?

16 MR. OKRENT: I guess I have a different view of
17 what requirements it's appropriate to place on the technical
18 capabilities of people within a state organization
19 responsible for managing emergency measures. I don't think
20 it's appropriate that they be asked to be experts in each
21 and every hazard that exists in society.

22 It seems to me that people who are running the
23 facility, whether it's an LNG facility or a facility that
24 makes dioxin for nuclear reactors, that people who run it
25 should be able not only to assess the status of the plant,

1 but also to explain in language intelligible to the layman
2 what the potential hazards are and what might occur and so
3 forth, so that those people who have the responsibility for
4 taking emergency action have a basis for decisionmaking.

5 If in fact a group running the facility is unable
6 to provide this information, that's where the deficiency
7 lies and it has to be remedied.

8 MR. BENDER: I think Dr. Okrent is taking issue
9 with the point I made and I would want to respond to it. Of
10 course it's important that the organization running the
11 plant has knowledge enough to provide to the public some
12 understanding of accident circumstances. But it is a public
13 governmental authority that issues orders to the public, and
14 it can't do it without adequate knowledge.

15 And I don't care how capable the operating
16 organization is to develop information. If the recipient is
17 not adequately knowledgeable to use the information, he is
18 likely to lead the public in the wrong direction. And I
19 think we cannot assume that all the burden has to be on the
20 operator.

21 MR. PLESSET: I would like to side with Dave on
22 this. I think you should not expect political persons who
23 have been successful in running for office, or their
24 appointees, to make these judgments. What it boils down to
25 is in my opinion, and I think Dave is saying somewhat the

1 same thing, it devolves upon the management. And beyond
2 that, there has to be some confidence and trust in that
3 management. And if you don't have that, you're really in
4 trouble and you're not going to get some officials in the
5 government to act responsibly if they don't have that
6 confidence.

7 The technical decision has to be made by the
8 management of the facility, whether it's an LNG or nuclear
9 plant or whatever.

10 MR. BENDER: It's not up to the management of the
11 facility to decide whether the public is in sufficient
12 jeopardy to recommend that they move from their living
13 quarters somewhere else. That's the job of the public
14 authorities.

15 All the organization running the plant is report
16 the conditions. The interpretation of it is a public
17 responsibility. And I can't accept the fact that because an
18 individual is politically designated that he doesn't need
19 competence. And I think that message needs to be
20 communicated back to those that are concerned about it.

21 MR. SHEWMON: Dade, I too could take sides on this
22 and feel reasonably strongly. But I think we would be
23 better if we got on and we could argue this in a letter or
24 something.

25 MR. MOELLER: All right. You have in your folder

1 -- does someone know what section -- tab 8, an agenda for
2 today's review of this restart matter. The first item on
3 that agenda is review of new management organization and the
4 resultant increase in staffing. This will be a presentation
5 by the Licensee.

6 Before I call on them, let me ask, does the staff
7 have any comments?

8 MR. NOVAK: On your summary, you mean?

9 MR. MOELLER: Yes.

10 MR. NOVAK: I don't believe so, no.

11 MR. MOELLER: Thank you. Then we'll move to the
12 Licensee, and for the review of the first item we will call
13 upon Mr. Robert Arnold.

14 MR. ARNOLD: Thank you very much, Dr. Moeller.
15 The company appreciates very much the opportunity to be
16 before this Committee.

17 I think with regard to some of the immediately
18 preceding discussion I would like to make a couple of
19 comments. First of all, that the company does not feel that
20 it's their job to, I guess, make the judgment on the issue
21 that the Committee was immediately discussing. However, we
22 have made the internal commitment and have communicated that
23 externally as well, that our intent and our sense of our
24 responsibility is to be fully forthcoming, fully
25 straightforward in our communications with both the state

1 and federal agencies. And we believe that we have set up
2 our organizations and trained our people such that that will
3 in fact happen.

4 I think that we have recognized since very shortly
5 after the accident that in terms of the restart of Unit 1
6 that the capability of the management, of the organization,
7 and the confidence of others in that capability was an
8 absolutely essential ingredient for authorization to restart
9 Unit 1. And we do believe that we have demonstrated that we
10 have been responsive to that concern.

11 In terms of the presentations, Mr. Philip Clark
12 will start off with the review of management organization.
13 We would ask the Committee's indulgence in rescheduling the
14 next item to immediately after the break. The person we had
15 intended to make that presentation became ill last night and
16 so is not available this morning, and we would like a little
17 bit more time to readjust on that. But other than that, we
18 are ready to proceed in accordance with the sequence of the
19 agenda. And Mr. Clark will make the opening presentation
20 and will chair our remaining presentations.

21 MR. MOELLER: We have noted that and we will
22 simply postpone the one item.

23 MR. CLARK: Starting before the TMI accident, GPU
24 management recognized that nuclear power was different and
25 we had started to revise our organization to deal with

1 nuclear stations. That plant was set back by the accident
2 and then accelerated. And I want to show you today the
3 results.

4 (Slide.)

5 This slide shows some of the evidence that we
6 incorporated in the organization of the staff. First we had
7 set up a full-time organization dedicated solely to nuclear
8 generation. That organization was put in effect and
9 recognized in our licenses with NRC in September of last
10 year and has been operating ever since.

11 It is operating today as a nuclear group. It is
12 intended that it be a nuclear corporation. That change from
13 group to corporation requires approval by SEC, Pennsylvania
14 PUC and New Jersey BPU, and the NRC. We have two of those
15 four and we expect the others this summer.

16 But even without being a corporation, we are
17 operating as a group with the organization staffing as I am
18 going to describe it to you. We have increased -- and I
19 will show numbers later -- the onsite technical and
20 management resources. We have set up strong central
21 technical control at the plant, with continuity from the
22 design through the construction and the control of the
23 technical configuration of the plant during operation.
24 Prior to the accident that responsibility changed hands with
25 time.

1 We have put full-time on-site management for
2 operation and maintenance of each plant, and we have taken
3 the support activities, administration, engineering, and
4 radiation protection, and put those separately in the
5 organization so that the plant management can devote
6 themselves to the operation and maintenance.

7 We have set up an independent nuclear assurance
8 division, with training, quality assurance, and a nuclear
9 safety assessment department independent of the operating
10 organization and the engineering. We have pooled the
11 resources that were applied to TMI-1 into Oyster Creek and
12 in our case, very importantly, which were applied to the
13 Forked River plant. We have pooled them all and augmented
14 them substantially since the accident, and we are proceeding
15 to develop and implement personnel policies and procedures
16 which are appropriate for nuclear power.

17 And as an example of that is the requirements we
18 are establishing for periodic requalification of radiation
19 protection technicians and other classifications, so that we
20 are able to continually assure that those people are up to
21 date and qualified to perform their duties.

22 (Slide.)

23 Before I show you the organization, I want to show
24 the purpose of the GPU Nuclear Group as we have promulgated
25 it to the organization. That purpose is: first, to manage

1 and direct the nuclear activities, provide the required high
2 level of protection for the health and safety of the public
3 and the employees; second, consistent with the above, to
4 generate electricity in conformance with the rules and
5 regulations. This is an attempt on our part to make sure
6 that the organization understands unequivocally where the
7 organization is with regard to the priority to be placed on
8 protection of public health and safety.

9 (Slide.)

10 This next chart shows the organization of GPU
11 Nuclear. The office of the president, with Bob Arnold and
12 me. We have a vice president on site for operation and
13 maintenance of each of the nuclear plants. We have a vice
14 president for technical functions, in whom resides the
15 technical control of the plant configuration, the technical
16 content of the procedures, the technical content of the
17 training. We have a vice president for nuclear assurance,
18 who has the training and the nuclear safety assessment
19 function, and that means that since the accident we have a
20 vice president of communications. Before the accident there
21 was one public relations media person working on TMI. Today
22 there are on the order of 30. In addition, the professional
23 level of the communications staff is vastly increased.

24 We have a vice president for radiation and
25 environmental control, reporting to the office of the

1 president independent of the operating staff, to provide the
2 kind of quality aspect of the radiation protection. We have
3 a vice president of maintenance and construction to deal
4 with the ongoing modifications, the craft labor, the buildup
5 for outages, and relieve the onsite plant management of the
6 responsibility of carrying out those outages, so they can
7 concentrate on the operation and maintenance of the plant.

8 We have a GORB, general office review board, which
9 is a safety review board reporting to the office of the
10 president. It has both inside and outside members. There
11 are roughly five members of that 11-man group who are not
12 employees of the organization, but come from outside, from a
13 variety of backgrounds and disciplines. And we have
14 established a full-time chairman for the GORB and provided
15 staff support to see that that function can operate
16 effectively.

17 There are 12 boxes on his chart at that level.
18 Five of them designated by these dark lines are new to GPU
19 since the accident. Five of them are shifted from
20 construction, which was Forked River, to operational
21 activities. Two of them before the accident had
22 responsibility for nuclear plus generation, and their scope
23 has been narrowed to nuclear activities only. We feel at
24 this level of the organization there is a good deal of new
25 blood and people from outside with a new perspective.

1 There is a many-fold increase in the amount of
2 management attention at that level applied to the operation
3 and maintenance of our plants.

4 MR. BENDER: Mr. Clark, before you take that off,
5 the two people that came in to take over the management of
6 TMI-1 and TMI-2 which you show as new to the organization,
7 what was their background?

8 MR. CLARK: Mr. Hukill, who is here today, spent
9 over 20 years in the Navy in the nuclear business. I think
10 importantly he not only was the CO on the ship, but he spent
11 several years in headquarters, where he was involved in
12 establishing the training programs, monitoring the
13 performance of the operational aspect of the fleet. So he
14 not only was exposed to the system; he then was involved in
15 directing and managing parts of the system, which I think is
16 very important to provide the needed inside.

17 Mr. Hovey was with General Electric for a while,
18 involved in their nuclear activities, including Vallecitos.
19 And most recently before he came to us he was with AGNS as
20 the manager of the plant that they were designing and
21 constructing for waste processing; and I think is very
22 knowledgeable particularly in the technical things involved
23 in the liquid processing waste management, and I think has a
24 very good background for TMI-2.

25 MR. BENDER: Fine. Just to complete the picture,

1 there is a new vice president for maintenance and
2 construction. What was his background?

3 MR. CLARK: Mr. Manganaro was in the Navy for
4 probably over 25 years, including a tour as commanding
5 officer of shipyards which were doing overhaul and
6 maintenance of nuclear ships. And I think he has a very
7 good background for the kind of activity he is involved in
8 for us.

9 MR. BENDER: Thank you very much.

10 (Slide.)

11 MR. CLARK: There are a number of ways to try to
12 capture what capability you have in the organization, and
13 this chart is an attempt to show some of them. Within the
14 organization -- and this is as of December 30th, 1980; the
15 numbers are at the end of last year. We look at the total
16 staff level of 1947. As of June we had 2149. I don't have
17 a breakdown of how they're spread, but there would be
18 increases in essentially all of these numbers by about ten
19 percent, with a total of 200 added.

20 We had in the organization at that time 416
21 technical professionals. Those are degreed people in
22 science or engineering. Amongst those people they had 5,000
23 years of professional experience and 3100 years of nuclear
24 experience. On the average, they had seven-plus years of
25 nuclear experience.

1 I think another measure over and above the
2 technical background is the operating experience. We have
3 119 people with a senior reactor operator license or
4 equivalent, by which we mean a Navy engineering officer of
5 the watch qualification.

6 I think importantly from our standpoint and yours,
7 we see a pretty good spread amongst the three plants. There
8 are technical professionals, 35 to 40, in the staff of the
9 plant for operation and maintenance. I think we also see a
10 good deal of operating experience in things like technical
11 functions, with 35 SRC-licensed people or equivalent, some
12 also in nuclear assurance. So that in addition to the
13 technical expertise, we have the operating experience and
14 background spread through the organization, and we think
15 it's important to have both of those elements.

16 For comparison, before the accident the total
17 staffing applied to TMI-1 and TMI-2 both onsite and offsite
18 is about 630 people. Today applied to TMI-1 we have onsite
19 650 people for TMI-1 alone, and offsite it's a little hard
20 to judge. The support people keep changing, but 170 or more
21 people.

22 So in terms of the total resources applied to the
23 operation and maintenance of these plants, we think we have
24 made major increases in the total staffing most importantly
25 we think in terms of the technical background and in terms

1 of management capability, which prior to the accident was
2 not applied to the operation and maintenance of the plants.

3 MR. BENDER: Mr. Clark, the numbers are
4 impressive. How do they compare now with a similar
5 complement of people that might be at other plants,
6 equivalent to TMI-1 during the startup stages?

7 MR. CLARK: We're looking very carefully at that
8 and it is very hard to get good numbers, because even in our
9 case, in addition to those numbers, we have applied
10 full-time to our plants on the order of 1200 contractors.
11 And they are onsite or they are dedicated offsite
12 resources.

13 The mix between employees and contractors, we have
14 been moving and intend to continue to move to bring more
15 in-house. But when you start comparing with anybody else,
16 it's very hard to find out what they have in both
17 categories.

18 Let's take guards. Amongst the three plants we
19 have 220 security people. A lot of people contract that and
20 they may or may not show up in those numbers.

21 Given those qualifications, however, it's our
22 belief that our staffing is well on the high side of the
23 staffing for people in an equivalent position. We have
24 looked at the '79 surveys by EEI and other people and we are
25 well above those numbers. It's our sense that other

1 utilities are also increasing their staffing, but that we
2 are above it.

3 We do get some input from our outside members of
4 the GORB, people, some of whom may be known to you -- Bill
5 Lowe, Clu Raddis, et cetera. Their sense expressed to us,
6 as I understand it, is that in terms of the total management
7 and staffing, we are well on the high side of other
8 companies.

9 MR. BENDER: Thank you.

10 MR. MOELLER: In terms of the 1947 as of December
11 or the 2149 as of June, are these all full-time employees?

12 MR. CLARK: Yes, sir, full-time employees assigned
13 to the Nuclear Group. And because we are not a corporation,
14 some have a Met Ed payroll or Jersey, but they work for us.

15 MR. MOELLER: But they are all full-time, your
16 people?

17 MR. CLARK: Yes, sir.

18 MR. MOELLER: Okay.

19 MR. CLARK: That was all that I had prepared.

20 MR. MOELLER: Any additional questions for Mr.
21 Clark?

22 MR. WARD: Would you tell us or will someone tell
23 us a little bit more about how the review board functions
24 and interacts with management?

25 MR. CLARK: Yes. We have a full-time chairman who

1 is an employee. We have three general office review boards,
2 one for each of the three plants. It's a slightly different
3 composition because at TMI-2 we are looking for chemical
4 processing expertise, a little different mix at Oyster
5 Creek, for example.

6 They have as consultants to them representatives
7 from the NMSS suppliers. Each board meets for about a day
8 and a half every three months. There are formal minutes
9 kept of the meetings. There are formal recommendations from
10 the board to the office of the president, which we respond
11 to formally.

12 They are provided with staff support from our
13 nuclear safety assessment department here, so that they have
14 the capability, which I think this Committee would recognize
15 is necessary, to have an ongoing continuing effective
16 process, rather than an episodic kind of review that you
17 would have.

18 They are quite active. Our employees are either
19 division level, which is this level, or the level below it.
20 We have put high-level people on it and we think very
21 competent people from outside.

22 Does that respond to you?

23 MR. WARD: Yes, thank you.

24 MR. MOELLER: Any other questions?

25 (No response.)

1 MR. MOELLER: Well, thank you, Mr. Clark.

2 The next item on our agenda, then, if we postpone
3 the item shown, will be to move into emergency
4 preparedness. And for that we will call upon the NRC staff,
5 who in turn I guess will call upon FEMA for a report.
6 Harley Silver?

7 MR. NOVAK: Steve Chesnut will introduce our
8 presentation.

9 MR. MOELLER: Thank you.

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. CHESNUT: Good morning. My name is Steve
2 Chesnut. I have served as the team leader for the TMI-1
3 emergency preparedness for the past year, and I wish to
4 report that we have completed our review of the TMI-1
5 on-site emergency plans in accordance with the new emergency
6 planning rules and the new restart order, and we have
7 recently completed the last item on that restart order,
8 which was the conduct of a test exercise of the TMI-1
9 emergency plan. That was conducted on June 2.

10 There was one exercise involving not only the
11 licensee but also the state government as well as four of
12 the five counties within the plume exposure emergency
13 planning zone around TMI. The results of that exercise were
14 that the licensee as well as the state and counties
15 demonstrated an adequate preparedness, based not only on
16 that exercise but on the review of the existing plans as
17 well.

18 York County did not participate in that exercise.
19 They have agreed to or we are in the process of forming up
20 plans for an exercise involving York County, which is
21 scheduled for late August of 1981.

22 I will also be here to answer any of your
23 questions with regard to the communications you talked about
24 earlier, the provisions with the licensee's plan and also
25 coordination with the state. Also Mr. Robert Jaske from

1 FEMA, who is the Acting Director of the Radiological
2 Emergency Preparedness Division of FEMA, will be also
3 available to answer questions in those areas as well.

4 MR. MOELLER: Could we have a statement from Mr.
5 Jaske, did you say was his name?

6 MR. CHESNUT: Yes, sir.

7 MR. MOELLER: Simply telling us what FEMA's
8 conclusions were in a sentence or two.

9 MR. JASKE: FEMA did, of course, participate and
10 evaluate the accident -- or I mean, excuse me, the exercise,
11 and we did submit a statement of findings to the NRC staff
12 on June 16th, which I believe should be available to you.

13 We concur in Mr. Chesnut's statements that the state
14 demonstrated adequate capability to respond to an accident.

15 Our report on the accident noted 72 deficiencies,
16 which did not detract from our overall conclusion of
17 adequacy. These deficiencies are principally the type of
18 deficiency that can be cured by additional drilling and
19 sub-exercise refinements of such things as communications
20 and state and county coordination, which due to the newness
21 of the plan to all the parties did have some rough spots.

22 We are working actively with the participants in
23 the counties and in the state to resolve any of those
24 details, which we did note in the formal report.

25 MR. MOELLER: Thank you, Mr. Jaske.

1 Mr. Carbon, did you have a question?

2 MR. CARBON: I think it is pretty much answered,
3 Mr. Chesnut. You are from the NRC staff?

4 MR. CHESNUT: Yes, sir. I am from the Division of
5 Emergency Preparedness.

6 MR. MOELLER: Mr. Bender.

7 MR. BENDER: Mr. Chesnut, in sending up this team
8 to deal with emergency response, did the NRC or FEMA either
9 one attempt to establish some qualifications for the people
10 that were responsible for emergency management?

11 MR. CHESNUT: Are you referring to in the review
12 of the planning or for the NRC's own response to an
13 emergency?

14 MR. BENDER: In reviewing the program, I guess I
15 have in mind that the NRC has some responsibilities, the
16 state has some and FEMA has some responsibilities. In order
17 to have an effective team, I would presume there would be
18 some requirements for experience, some training
19 capabilities, as well as some practice exercises.

20 Does that kind of set of requirements exist?

21 MR. CHESNUT: Yes, sir. For people who are
22 reviewing plans, we have all undergone in-house training on
23 the standards.

24 MR. BENDER: I am not talking about the planning
25 reviewers, although it is good to know they have

1 capabilities too.

2 MR. CHESNUT: In I&E there is a separate branch
3 called Instruments Response Branch, and they have been
4 responsible for improving NRC's own emergency preparedness.
5 We are in the process of hiring full-time duty officers who
6 are trained to respond in initial hours. In addition to
7 that, for many of the exercises that have been conducted of
8 the many licensee plants around the country, the NRC's
9 instant response teams have periodically participated in
10 some of those drills and exercises.

11 MR. BENDER: Well, that is a partial answer but
12 it's a long way from being a complete answer. I know that
13 some drills have been carried on. I think the question
14 still is what kind of qualifications are required for people
15 that have to manage such emergencies, and do we have such
16 qualifications and are the people in charge now being judged
17 as to whether they meet them?

18 MR. MOELLER: Mr. Bender, you are referring not
19 only to NRC or FEMA but to the state or local people.

20 MR. BENDER: I'm talking about the whole emergency
21 response team. I really don't know what it is. I wish I
22 did. But in the absence of knowing, I am hoping that the
23 planning or review organization is doing something to take
24 it into account.

25 MR. CHESNUT: Well, I think we are. What we have

1 done is we identified the many functional areas which needed
2 to be addressed in an emergency. Within the NRC there is a
3 lot of expertise in each of those areas. So in many cases
4 it is a matter of developing standard procedures and having
5 people with the right expertise to address the problem, and
6 that is what we are doing. We are testing the coordination
7 of all those individuals.

8 At the state level, for instance, FEMA does
9 perform reviews of the ability of the state to respond.
10 That includes some of the training and qualifications of
11 those individuals. The state of Pennsylvania, for instance,
12 has a technical branch, the Bureau of Radiological
13 Protection, where they have several nuclear engineers and
14 health physicists to digest the technical information from
15 the licensee and make a recommendation for protective action
16 to the state, which would be the Pennsylvania Emergency
17 Management Agency or the governor.

18 Those agencies respond to all kinds of
19 emergencies, from tank car collisions to radiological
20 disasters, so they are used to applying emergency
21 resources. But they use the Bureau of Radiation Protection,
22 for instance, as a technical response branch in those areas.

23 Those, of course, are reviews. We have no set
24 standards for each state to have a certain individual with
25 certain qualifications able to respond.

1 MR. MOELLER: Mr. Shewmon has a question.

2 MR. SHEWMON: This could come from Mr. Chesnut or
3 the licensee's response, but I am so ignorant of this I
4 don't really know whether we are talking about something
5 like the QA audit or somebody goes in and asks a certain
6 fraction of those involved what they do, or at the other
7 extreme of my experience at a grade school fire drill where
8 everybody gets up and walks out in the yard.

9 Could you tell me briefly whether the populace is
10 involved in this, whether it is an audit or whether they
11 indeed physically transported people out of areas to see how
12 it worked?

13 MR. MOELLER: Go ahead, Mr. Chesnut.

14 MR. CHESNUT: I think you were referring mainly to
15 an evacuation order. There are more facets to emergency
16 planning than conducting an evacuation. We normally don't
17 have evacuations of the local populace. These drills
18 usually go to a point where an evacuation would be a
19 decision and the state actually deploys its resources to
20 effect it, such as the state police or traffic control or
21 something of that nature.

22 MR. SHEWMON: The exercise was a drill down to the
23 level of the people who would be managing and carrying it
24 out.

25 MR. CHESNUT: Yes, sir.

1 MR. SHEWMON: Thank you.

2 MR. MOELLER: Any other questions for Mr. Chesnut?

3 Thank you very much.

4 We will move on, then, to the licensee and request
5 your comments on the drill.

6 MR. CLARK: Mr. Rogin, the Director of Emergency
7 Preparedness, will make that presentation.

8 MR. KERR: Mr. Jaske, excuse me. You mentioned, I
9 believe, 72 deficiencies that were noted in your report?

10 MR. JASKE: Yes, sir.

11 MR. KERR: Is there any number of deficiencies
12 that would have convinced you the plant was inadequate, or
13 does it have more to do with the seriousness of the
14 deficiencies rather than the number?

15 MR. JASKE: Well, the basic plan is quite
16 workable, and the deficiencies I mentioned are those we
17 discovered in actually performing the exercise itself. I was
18 talking about deficiencies related to the exercise
19 objectives, which are sometimes refinements of the plan or
20 sometimes do not always include every element in the plan,
21 as we have just discussed, the full evacuation carried out.

22 I don't know whether you have had an opportunity
23 -- you know, you are free to examine.

24 MR. KERR: I can answer that. I have not examined
25 the list. But the deficiencies were, then, not deficiencies

1 in the plan but it is in its execution?

2 MR. JASKE: That's correct.

3 MR. KERR: So you judged the plan to be acceptable.

4 MR. JASKE: That's correct.

5 MR. KERR: Thank you.

6 MR. MOELLER: Mr. Ray.

7 MR. RAY: Before Mr. Jaske leaves, could you tell
8 us how that 72 deficiencies is split from the viewpoint are
9 assignable to the licensee?

10 MR. JASKE: Well, FEMA's judgment of the state and
11 local effectiveness concentrated almost entirely on the
12 state and local government. The only place where we noted
13 any difficulties was in some of the discussions between the
14 utility and the state about an accident classification,
15 which we have taken care of by being sure that the accident
16 category descriptions are more clearly identified.

17 There was some confusion over the nomenclature. We
18 made quite a point of that with the state. The Governor's
19 Office was involved in a misapplication of nomenclature at
20 one point in the exercise, and we highlighted that as a
21 problem that needs solution, and I assure you that that will
22 be solved.

23 But essentially, 95 percent or more of the
24 deficiencies relate to the state and local government. We
25 did not make an evaluation of the licensee except in that

1 one case where there was communication.

2 MR. ROGIN: I am the Manager for Emergency
3 Preparedness for GPU Nuclear Group. I would like to say a
4 few words perhaps to answer some of the questions with
5 regard to the extent of the exercise and what our
6 observations were with regard to its utility and its
7 ultimate result.

8 We were evaluated by the staff in three different
9 areas, one of which certainly was our ability to implement
10 the plan effectively should an emergency occur, and the
11 other two were related to our ability to prepare for such an
12 implementation.

13 One was with regard to our own ability in house to
14 plan for and develop a reasonable scenario and conduct
15 exercises which would provide some training opportunities
16 for people, and secondly with our own ability to
17 self-evaluate our performance and to identify those things
18 which we felt needed additional attention and effort on our
19 part in order to assure that we were maintaining an
20 appropriate level of emergency preparedness.

21 The staff has indicated to us in their results
22 that we had done those jobs satisfactorily. We had
23 identified the major -- there were no major shortcomings or
24 deficiencies indicated -- but there were some areas which
25 needed additional attention, and we had identified those as

1 part of our own self-critique and taken or initiated the
2 appropriate actions to follow up on those, and those areas
3 will be a subject of additional attention by the staff.

4 So overall we felt that the exercise was one which
5 gave us a very good opportunity to implement the full scale
6 of our plan and to coordinate with the state and the local
7 governments to assure that we could in fact execute and
8 implement a coordinated response to an emergency.

9 Just to give you some feel for an answer to the
10 one question with regard to the magnitude of the exercise.

11 (Slide)

12 It was indicated in general that it went to the
13 point where it tested right down to the local population,
14 but we didn't actually evacuate anyone. But these are major
15 events which did occur as part of the exercise. We had full
16 accountability of personnel on the site for both units.

17 We actually had a search and rescue scenario. We
18 called in an off-site fire department and ambulance services
19 to respond, and in fact during the course of the event on
20 June 2nd we also conducted our Radiation Management
21 Corporation supervised annual radiation health physics
22 drill, which called for us to take a simulated contaminated
23 person and transport them to Hershey Medical Center, and
24 then we will get a full, formal critique on that, including
25 the Hershey Medical Center part of it.

1 We also went through contamination drills. As I
2 indicated, we had a fire drill with several companies off
3 site responding, and these are all people, by the way, who
4 would normally be our first line response if we had an
5 actual event, and all these people had been participants in
6 previous drills on site, including actually taking some of
7 them inside the protected area on a couple of occasions to
8 practice our security processes.

9 We had the state police not only in terms of
10 assistance of traffic control, but they also provided
11 helicopter assistance for population notification in the
12 surrounding areas. So in essence we activated all of our
13 response organizations. We went all the way through a
14 scenario to general emergency declaration and recommendation
15 by the GPU Nuclear management that the state should consider
16 an evacuation within the plume exposure pathway, and the
17 state then followed up and began the process of evacuating
18 but did not in fact evacuate people.

19 We had five counties in the risk area which
20 participated. The fifth one, York County, was mentioned, and
21 we expect to have an exercise with them in the not too
22 distant future. Some specific dates are being discussed
23 right now. We also had several municipalities in each of
24 the counties, so we feel right from the control room all the
25 way down to the local township or municipality level, the

1 whole system of communications and implementation for
2 emergency response was exercised. There was very little
3 simulation that occurred.

4 We did not evacuate the entire site. We took a
5 selected number of people once we had the accountability
6 drills completed and took 15 people out of Unit 1 and
7 actually took them through the evacuation process to get a
8 feel for that, and of course we didn't have a real
9 contaminated person so we simulated that.

10 But that gives you a fair flavor for the kinds of
11 things that occurred. We have already begun discussions as
12 a result of the FEMA and NRC feedback to us on the drill.
13 We are working already with the state in several areas in
14 discussing how we can make arrangements to improve upon some
15 of those areas where we identified shortcomings.

16 And finally, I would only mention that the company
17 has entered into a maintenance agreement with a consulting
18 firm that we have used in the recent past for the next 18
19 months to two years, and they will be assisting the counties
20 and local municipalities through the good offices of
21 Pennsylvania Emergency Management Agency, working with them
22 as an extension of their office to assure the upgrading of
23 the emergency plans of all the counties and local
24 municipalities within the risk area.

25 So we feel we have had an exercise which clearly

1 exercised all of the various aspects of our plan and gave us
2 some areas which we wanted to direct some attention to but
3 did not identify any area which was significantly deficient
4 or would impact upon our ability to manage a real emergency.

5 MR. BENDER: Could you tell us a little bit about
6 what kind of advice and instructions you received from NRC
7 and from the state during this exercise?

8 MR. ROGIN: In terms of the preparation for or the
9 actual exercise?

10 MP. BENDER: The actual exercise. How were they
11 involved?

12 MR. ROGIN: It might be better if I asked Mr.
13 Arnold, who served as the actual emergency support director
14 and communicated directly with the site director of
15 operations of NRC to answer that question because the
16 communications were personally between the two people.

17 MR. ARNOLD: The way in which the scenario
18 developed, I think, was such that the company was evaluating
19 the conditions of the plant in providing information to the
20 state and the NRC people who were participating in the drill
21 as to plant conditions. There were, as the situation was
22 simulated to become quite serious, several conversations
23 between myself, the NRC senior person participating in the
24 exercise who was at the emergency off-site facility with us,
25 the nuclear engineer from the staff, the Department of

1 Environmental Resources, who was also there, and Mr. Tom
2 Jeruski, who was head of the Radiation Protection Department
3 or Bureau of Radiation Protection, as to what the plant
4 situation was and whether protective action would be
5 required.

6 So there was dialogue on that, and I think keeping
7 abreast of all parties as to what the company's
8 understanding of the situation was. I can't recall any
9 specific kind of inquiry or advice as to how we may need to
10 proceed differently than we were that came out of those
11 discussions.

12 MR. BENDER: Let me pick a few items out of the
13 scenario. One of the things that is shown here is a
14 post-accident sample of the reactor cooling system. That
15 presumably came from some decision that there might be a
16 fuel failure of some sort. Is that an automatic thing or --

17 MR. ARNOLD: Yes, it is. We have to demonstrate
18 that we can provide within a certain time -- I think three
19 hours is what we are committed to -- that we can obtain a
20 reactor coolant sample in the situation where there had been
21 fuel damage. So that is part of the institutionalized
22 response to a reactor trip.

23 MR. BENDER: Did the state or the NRC ask when are
24 you going to do that?

25 MR. ARNOLD: I did not receive that inquiry, to my

1 knowledge, but they would have been aware from their
2 information, their participants in the control room as to
3 whether or not that action was under way, and I am quite
4 sure that the plant people took the initiative in following
5 through on that procedure, to tell you the truth.

6 MR. BENDER: Let me just ask about one other
7 item. The last item on the scenario says the reactor
8 cooling system is on natural circulation moving to decay
9 heat, and I don't know what the postulate was at that time
10 as to whether nuclides were in the system or not. What kind
11 of communication is involved in telling people about the
12 status of the system at that time? What did you have to
13 tell them? What did they ask?

14 MR. ARNOLD: In the emergency off-site facility we
15 have status boards, and although we can't dummy in the
16 signals for an actual situation, we can call on the CRT for
17 various parameters. So those that were germane to the
18 establishment of natural circulation or demonstration that
19 natural circulation was occurring were available to the NRC
20 participants and state as well as myself.

21 In the direction that we were going for removal of
22 decay heat, that of going to natural circulation having
23 steam to the atmosphere, was identified to the state as the
24 plant situation degenerated, so that I could ask Mr. Hank
25 Hukill, who was the emergency director in the control room,

1 if there was any initiation from the state or NRC people as
2 to what we should be doing differently, but there certainly
3 was not from the off-site facility.

4 Mr. Hukill.

5 MR. HUKILL: I am Director of Unit 1. I was the
6 emergency director during the exercise. We had the NRC, our
7 senior representative on the site, right in the control room
8 with me. He had a man on the emergency phone with
9 Bethesda. He asked me several questions which I don't
10 remember what they were now, but I reported to him what we
11 were doing and he asked on several occasions what we were
12 doing.

13 We were also in the control room in continuous
14 communication with the state Bureau of Radiation
15 Protection. They asked several questions concerning what
16 our readings were and what our off-site readings were and
17 what our recommendations were until that really passed to
18 Bob Arnold at the off-site control center.

19 MR. BENDER: I was just trying to think about
20 trying to reconstruct the TMI-2 incident in asking people,
21 well, how did it go and how do you report how the event
22 transpired and what people remembered, and I think it is
23 kind of interesting to recognize that here in just an
24 exercise it is hard to remember all the things that were
25 going on. You might think about what kind of recordkeeping

1 you are supposed to have during one of these things.

2 MR. HUKILL: We do have a log that was kept. I
3 have a separate log keeper that just walked behind me during
4 the whole drill and writes down every single question asked
5 me and every decision made. So I could go back to that and
6 find out what I had been asked, but I can't remember it all.

7 MR. ARNOLD: I think your point is well made, and
8 I would like to identify that we have for the emergency
9 support director a tape recording. We tape all of his
10 communications.

11 MR. MOELLER: Mr. Rogin, I think because of time
12 we are going to want to move along on this. Mr. Carbon has
13 a question.

14 MR. CARBON: Yes. How would you notify the
15 general public in a real emergency, and what kind of timing
16 do you anticipate, what amount of time to evacuate a certain
17 group of people? How fast does this take place and how is
18 the evacuation carried out, just briefly?

19 MR. ROGIN: With regard to notification, we have
20 to notify principally two people to start the scheme, that
21 is, with regard to the public. The first is Dauphin County
22 and the second is Pennsylvania Emergency Management Agency.
23 PEMA then picks up notification of the other four counties,
24 and then each of the five counties in turn has its own
25 notification process.

1 PEMA also notifies the Bureau of Radiation
2 Protection, who then closes the loop back to the licensee,
3 and then from that point on, our communication is between
4 the Bureau of Radiation Protection and the licensee,
5 and then they in turn take care of any future updates,
6 notifications and reclassifications of accidents, except in
7 the case of a general emergency. And when we go to a
8 general emergency, we have an exception to the case and both
9 the licensee and the state go directly to all five counties.

10 The timing on that -- the requirement is 15
11 minutes from declaration of the first classification of the
12 event. My feeling is we would probably take care of the
13 first part of that, which is the state and the county,
14 within several minutes, and I think the state has certainly
15 come in well below the 15 minutes, in any case. So within 15
16 minutes the public down to at least the county level has
17 been notified and determinations were being made.

18 With regard to how much beyond that the
19 notification ought to go, with regard to notification of the
20 general public we are installing a system now which is the
21 siren system backed up by some other means, and the decision
22 on that really resides with the state. When they determine
23 that the general public needs to be alerted to an event,
24 then they sound the alert.

25 With regard to the evacuation, if course it is a

1 variable. Our studies conducted some time ago indicate that
2 on the best case we could evacuate the entire ten-mile EPZ
3 in five to ten hours, and the latitude demonstrates the
4 difference in degree of mobilization of the state police and
5 others at the time evacuation is ordered. It could go up to
6 as much 13 hours, depending on poor weather, improper
7 mobilization or poor mobilization, lack of timing and so
8 forth.

9 MR. CARBON: Thank you.

10 MR. WARD: The exercise apparently lasted seven or
11 eight hours, is that correct?

12 MR. ROGIN: Just a little better than ten, sir.

13 MR. WARD: Could you tell me the day of the week
14 and the time of day?

15 MR. ROGIN: I think it was Tuesday. I'm sure it
16 was Tuesday, and we started about 5:30 in the morning
17 because we wanted to go through a shift change, so we had a
18 change of shifts before we were actually at the highest
19 classification.

20 MR. WARD: So the final parts of it were during
21 daylight hours.

22 MR. ROGIN: Yes, sir. The evacuation orders came
23 about something like 12:30 or 1:00. The general emergency
24 declaration was like 12:30, and by the time we gave
25 everybody a chance to exercise the state requirements and so

1 forth, we terminated right around 3:00.

2 MR. WARD: Do you believe that is a good test of a
3 situation you might have in weekends or night-time hours,
4 for example?

5 MR. BOGIN: I think it does because we started out
6 -- of course, there are always certain artificialities in an
7 exercise. People did know the date of the exercise although
8 they had no idea of the time. That was required for a
9 variety of reasons. But we started out on the back shift.
10 We had to go through a shift change. We had to bring in
11 people early for the various governmental agencies within
12 the state and counties.

13 Clearly there might be a little variation on the
14 theme if it was totally unannounced and so forth, but I
15 think the system is such that all our previous tests to that
16 system, including call-outs in the evenings and so forth, we
17 have proven that our system is responsive. We really think
18 we could do it just as well on Saturday now as we could on
19 Tuesday morning.

20 MR. WARD: Thank you.

21 MR. MARK: It was mentioned, I have forgotten
22 exactly by whom, of Mr. Gerusky, the state radiation
23 protection officer, being involved in some aspects of the
24 exercise. Now, he expressed himself, I think, as less than
25 fully satisfied with the communications, depth of and so

1 forth, that he was involved in in April '79. Has he
2 expressed himself recently on his feelings, let's say, about
3 the company's present relationship or status with respect to
4 the office he is responsible for?

5 MR. ARNOLD: Perhaps it might be more appropriate
6 to address that question to Mr. William DornLife, who is a
7 nuclear engineer on Mr. Gerusky's staff and who is here
8 today, if he wouldn't mind responding.

9 MR. MARK: Well, I remember one time he was rather
10 disappointed or critical or something. Has he changed his
11 opinion is what I am really trying to find out.

12 MR. ARNOLD: I think Mr. Gerusky may be in more of
13 a position to respond to that than the company, although I
14 have no reason to think that Mr. Gerusky would not tell this
15 committee that he was not fully satisfied with the
16 interaction of the company at this time.

17 MR. DORNSIFE: I am the state's nuclear engineer
18 and the one that was at the EOF during the June 2nd
19 exercise, and also was the nuclear engineer during the TMI
20 accident, so I can see a different perspective from the two
21 things, so I could comment either on that improvement in the
22 situation or also in the communications.

23 First of all communications-wise. We did have
24 some procedural deficiencies in communications particularly
25 with the operational data to the BRP, and we found from

1 previous drills with this licensee and other licensees in
2 the Commonwealth, and also, of course, with the real
3 accident, that probability the majority of times our
4 protective recommendations will be either partly if not
5 highly based on operational status of the plant. So we
6 feel that knowing the operational status of the plant is
7 very important.

8 There was a problem with the direct line that was
9 set up that was used for radiological information because of
10 some physical limitations with getting information over that
11 line. There was a deficiency in the early exercise.
12 However, by going to the EOF and interfacing directly with
13 the licensee and people at the EOF has certainly, in my
14 opinion and I'm sure Mr. Jeruski's also, has cured that
15 deficiency and has gone a tremendously long way toward
16 having the state understand the things we didn't fully
17 understand during the TMI-2 accident.

18 Having the state and the NRC at the EOF and having
19 information available is a large step forward, in our
20 opinion.

21 MR. MARK: Thank you.

22 MR. MOELLER: Thank you.

23 Thank you, Mr. Rogin.

24 The next item on the agenda is the discussion of
25 the proposed reliability study and its objectives, and the

1 licensee will respond on that.

2 MR. CLARK: Mr. Keaton, the Director of Systems
3 Engineering in our Technical Functions Division, will make
4 that presentation.

5 MR. MOELLER: Let me remind Mr. Keaton that we do
6 want to cover it thoroughly, and yet please note that we
7 have to keep moving along.

8 MR. KEATON: I will certainly try to keep this
9 very short, and in fact I have only one Vu-graph, which may
10 help to hold the time down.

11 I would like to remind some of the members of this
12 committee and perhaps inform some other members that
13 previously we have done a probabilistic risk assessment
14 study on one of our plants, but that plant was Oyster Creek
15 rather than TMI. That study was started early in '78, and
16 the first cut at it was finished early in 1979.

17 The occurrence of the accident directed the
18 attention of people who had been involved in that to other
19 things for quite a while. We have now resumed the work
20 required to complete that study and we expect to have the
21 final results later this year.

22 (Slide)

23 Basically what we are intending to do for Three
24 Mile Island unit 1, as shown on the slide, is an analogous
25 study to that which was and is being done for Oyster Creek.

1 Our incentives for doing it are, one, to understand the
2 factors that lead to the risk to the public, and also the
3 factors which lead to availability or unavailability of the
4 plant.

5 The process that we intend to go through will be
6 similar to that we used for Oyster Creek. It is a thorough
7 and comprehensive risk assessment based on getting a
8 detailed understanding of the systems, conducting event
9 trees and fault trees, and using both industry data for
10 failure rates and then augmenting those by actual experience
11 at TMI where that experience is available.

12 We intend to try to cover not only random failures
13 but common mode, common cause type of events, and also
14 external hazards. The reasons why we are interested in
15 doing this are that we find that the results from such a
16 study can be used in a very meaningful way in our
17 decision-making process, particularly with respect to
18 allocation of capital resources, because we frequently face
19 a situation of should we put money to improve safety on this
20 area or on this area.

21 As we stand today, we have to make those decisions
22 based on engineering judgment. We think that with the
23 results of the study that we can in some cases quantify the
24 answers to those questions and augment the engineer judgment
25 to where those are hopefully better decisions.

1 We intend to have the specification prepared for
2 this study in the third quarter of 1981. We don't believe
3 that we have the resources in house to do the study
4 ourselves, so we do intend to go out for bid. We intend to
5 commence the study toward the end of the year. We visualize
6 that at least the initial go-through is probably on the
7 order of a 12-months study, and our experience with Oyster
8 Creek indicates there will be some follow-up studies
9 required.

10 MR. MOELLER: Are there any questions for Mr.
11 Keaton on this?

12 Roughly what amount of budget are you talking
13 about? What does such a study cost, a ballpark number?
14 Does anyone know?

15 MR. KEATON: It is on the order of several hundred
16 thousand dollars.

17 MR. MOELLER: That's fine. I wanted to have an
18 idea. Okay, thank you very much, then.

19 Mr. Silver, do you have any comments on this?

20 MR. ARNOLD: Dr. Moeller, the Oyster Creek study
21 has cost several million dollars at this point.

22 MR. MOELLER: Thank you.

23 MR. NOVAK: The staff has no comment.

24 MR. MOELLER: We will move on to the next item,
25 which is the new instrumentation for detection of inadequate

1 core cooling. We will have the licensee give the report on
2 that.

3 MR. CLARK: Mr. Keaton will make that presentation.

4 MR. MOELLER: All right. He will do that one,
5 too. Thank you.

6 MR. KEATON: Excuse me. I had misunderstood the
7 order and I thought the staff was going first or I would
8 have been better prepared.

9 As I indicated to the subcommittee and would like
10 to reiterate to this group, in previous discussions we have
11 tended to emphasize to you some of the problems that we have
12 found in trying to understand some of the requirements which
13 have been imposed primarily through NUREG-0737. Today I
14 would like to shift that emphasis and concentrate more on
15 what we have been doing and what we have found out and where
16 we think we are going.

17 We recognize that some of the earlier
18 presentations have left a rather negative impression of our
19 approach to this, and we do continue to have some questions,
20 but I want to indicate to the committee that we are not
21 sitting and doing nothing but we are really trying to make
22 process in this area.

23 (Slide)

24 As you know, the requirement that we are
25 addressing is given in NUREG-0737, Section II.F.2 ch

1 requires the evaluation of additional instrumentation for
2 detection of inadequate core cooling. As we have pointed
3 out in some discussions with the subcommittee, it is not
4 clear that in fact water level is the most desirable signal,
5 and there may be real reasons to consider alternative
6 signals, which might, I think, provide some different types
7 of information.

8 (Slide)

9 The approach that we have been and are continuing
10 to take is basically a two-fold one. One is to try to
11 understand the criteria that might be used for these types
12 of signals, and to that end we have worked with the B&W
13 owner's group in the work that was done primarily by B&W.
14 We have done some in-house consideration of how we might
15 look at operator guidelines with respect to a LOCA or
16 overcooling accident, and what we would do with level
17 instrumentation and level information if we had such
18 information.

19 And also we early on became aware of the fact that
20 this kind of information might be used for other things than
21 just inadequate core cooling, so we have been trying to
22 consider what the criteria for that would be as well.

23 With respect to potential detectors, our initial
24 efforts were through the B&W owners groups to evaluate the
25 different systems that have been considered. We followed

1 this with some in-house evaluations of detectors and came to
2 the conclusion that we weren't very satisfied with either of
3 those two, so we have initiated a study by an external
4 consultant to carry out an independent evaluation of the
5 systems that are available and to consider whether there are
6 some other systems that aren't currently being developed
7 that might be useful.

8 We have agreed to work with Penn State University
9 in a proposal they have developed for the use of neutron
10 detectors for water level inside a vessel, and we are also
11 aware of and expect to evaluate the EPRI study which is
12 currently in progress and is due to be available in about
13 October.

14 Our approach, then, has been based upon the
15 results of these two paths to decide that one of the systems
16 is useful and should be installed, in which case we would
17 propose to install it, or if that is not the case, to
18 support the development of other systems and alternates,
19 such as, for example, an inventory system.

20 (Slide)

21 In understanding the uses that might be made of
22 water level or related instruments, we have looked at the
23 various types of events that we think this information might
24 be considered for. With respect to a LOCA, our first
25 conclusion -- and I believe this is basically agreed to by

1 the NRC staff -- is that the required operator actions can
2 be taken based upon the existing instruments, and we think
3 this is very important because if that were not the case, we
4 would be in a situation of needing to install something
5 before we could restart the reactor.

6 But we found and the NRC staff testified that the
7 required operator actions can in fact be based on the
8 instruments we now have. In the case of a LOCA, about the
9 only real use we have identified for water level is it can
10 be used as a confirmatory signal, that the operator could
11 look at it to back up the signals that already exist in
12 assuring that he was taking the correct actions.

13 The suggestion was made at the subcommittee
14 meeting by one of the members or consultants that another
15 possible use of void fraction would be to use it as the
16 basis for the pump trip criteria. That, of course, is not
17 the case right now. It is based upon the occurrence of 1600
18 pounds of pressure in the reactor coolant system.

19 But since really the reason to trip pumps is to
20 avoid getting too large of a homogeneous void fraction in
21 the system, it is in fact conceivable that that might be an
22 alternative and perhaps even preferred criterion for
23 tripping the pumps. Frankly, we haven't done too much work
24 on it in the past two weeks, but we do want to consider it.

25 With respect to overcooling events we believe that

1 the required operator actions can be taken adequately based
2 upon the instruments that exist. The suggestion was again
3 made at the subcommittee meeting that if we had not a level
4 instrument but a true measure of the mass inventory of water
5 in the system, that in fact then that instrument could be
6 used to distinguish between an overcooling event and a LOCA,
7 because although both of those events lead to a change in
8 level, they do not lead to a change in mass inventory.

9 But that would be a system that is somewhat
10 different from one which displays level, although obviously
11 they are closely related. It is a matter of how information
12 would be processed and how it would be displayed and whether
13 it would be displayed as a water level or as a mass
14 inventory of water.

15 With respect to venting the RCS system, as you
16 know, we are committed to install vents at the high points
17 of the loops and at the pressurizer, although not
18 necessarily prior to restart, and the suggestion has been
19 made that use of a water level instrument would be a good
20 method of determining when and whether to vent and also when
21 to terminate the vent.

22 In this case I think the instrument would be
23 required to be, in fact, a level indicator because there you
24 care not about the inventory of the system as a whole but
25 the extent and nature of voids that would be effected by the

1 venting operation.

2 We have not yet taken a position on whether that
3 is required for the venting. Frankly, the guidelines for
4 that are under development and we think it is an open issue
5 whether it is really needed.

6 A similar situation with respect to the bubble in
7 the head, such as the St. Lucie incident. We have new
8 operator guidelines that are currently being developed for
9 how an operator should respond to that event. We aren't
10 sure whether level in the vessel or inventory in the vessel
11 is a required or desirable signal, and we won't know that
12 until we have gotten the guidelines better understood.

13 I do want to tell the committee that on our own
14 initiative we decided several months ago that there would be
15 a significant advantage to us, we felt, to have an
16 indication of whether saturation conditions exist at the
17 reactor head, and we do presently have a project under way
18 that will lead to installing thermocouples, monitoring the
19 water at the top of the vessel so that we can look to see
20 whether it is saturated or not. That will give us an
21 indication of whether a bubble could be drawn or not.

22 Finally, it has been suggested by various people,
23 including myself, that level or inventory or void fraction
24 information might be useful in analyzing after the fact,
25 going back and looking at what really happened during some

1 of the severe transients that might occur.

2 We had experience with one of those transients,
3 you might remember, in March or April of 1978 at TMI-2 where
4 we had a severe overcooling transient caused by the steam
5 safety valve sticking open, and we were forced to do a
6 considerable amount of evaluation of that event after the
7 fact to address the question of whether the core had been
8 uncovered or not.

9 We were able to conclude that the core had not
10 been uncovered without having level instrumentation. On the
11 other hand, if we had had something like water level or
12 inventory, we most certainly would have used it.

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Turning fairly quickly now to looking at the
2 systems that we believe are probably the frontrunner for
3 level measurement, this slide basically summarizes, when,
4 the vessel delta P system Westinghouse is associated with
5 and work has also done been done by EG&G, and of course, the
6 same kind of system is used in water reactors and in our
7 opinion. will give a good measure of water level under
8 reasonably quiescent conditions.

9 The vendor claims that this system can be used to
10 measure void fraction when the reactor coolant pumps are
11 running. I'm not prepared to refute that, but I can tell
12 you that there's a great deal of skepticism as to how
13 accurate or reliable that type of information is likely to
14 be.

15 B&W has a hot leg delta P system which has been
16 looked at which works on this same principle. The hot leg
17 level in a B&W system is a good signal in terms of anticipa
18 tion in that you will see changes in void fraction or
19 changes in level in the hot leg long before it gets low
20 enough to affect the core. So from an anticipatory
21 standpoint, that's good. From the standpoint of meeting the
22 total range coverage, and of course, the hot leg by itself
23 doesn't do that. It takes it down to only about eight feet
24 above the core.

25 The Combustion Engineering system of heated

1 thermocouples indicates the level at discrete intervals,
2 depending upon the number of thermocouples. We still have
3 some question in our mind as to how well the system really
4 will work in the presence of two-phase mixture. And given a
5 single phase and well-defined boundary between them, I think
6 the system unquestionably will work very well.

7 But in the case of the two-phase conditions, the
8 design of the detector is supposed to get an equivalent
9 collapsed level, and we have not completed our evaluation of
10 whether we think it will do that or not.

11 The neutron detector signal, of course, is
12 potentially a very attractive one because it is a non-
13 intrusive detector, and this is a system that we have agreed
14 to work with. The tests that have been done to date, not by
15 Penn State but sponsored by EPRI, indicate that there is
16 good sensitivity to water level as long as it's within about
17 eight feet of the top of the core. If it's more than that,
18 the response to the neutron detectors is difficult to
19 interpret.

20 Finally, the core exit thermocouples, of course,
21 don't indicate water level as such to keep the core
22 covered. They might be used as some sort of indication of
23 what was going on, once the level has dropped below the top
24 of the core. That would mean trying to take the
25 temperatures and back-calculate to an equivalent level.

1 So, our conclusion on those is that really, we
2 don't see anything that strikes us as an ideal detector at
3 the moment, although some of them have varying degrees of
4 promise.

5 (Slide.)

6 Where we believe we stand at the moment -- and
7 this certainly is not intended to think that we have
8 finished -- is that we have not seen anything that makes us
9 believe that such a system is required prior to restart of
10 Unit 1. And there I think we're in agreement with the NRC
11 staff. We don't need it as an input to safety systems, so
12 far as we know. And as I said earlier, the operator can
13 respond today based upon information that is available today.

14 We further feel there is a considerable question
15 as to what the criteria for these detectors are. The major
16 issue to us is, is the real detector that we want a water
17 level indicator, a mass indicator or even a void fraction
18 meter? Those are not the same thing, although water level
19 and mass inventory are relatively closely related.

20 We believe that the information could be used for
21 confirmation. In some cases it would be helpful for later
22 evaluation in some of the longer-term actions such as
23 venting, where we are still developing the guidelines and we
24 might find such information would be very helpful.

25 As I indicated earlier, the idea of using void

1 fraction as a basis for reactor trip we think merit: some
2 further evaluation and we haven't done that yet.

3 With respect to the detectors, our principal
4 concern is whether a detector that can be used under
5 quiescent conditions can also be used under pump flow
6 conditions where you are transitioning from a level to a
7 void fraction. To us, it is not clear that the existing
8 systems can do that, although there is disagreement on that
9 point, and some other people believe that they can.

10 We tried to do a rack-up of the existing systems
11 against the existing criteria in NUREG-0737. It was our con-
12 clusion that none of those systems meet all criteria,
13 although the staff has indicated in some cases it would be
14 acceptable to them. So we do not feel that we are in the
15 position yet where we are prepared to adopt one of the
16 existing systems without at least doing some further looking
17 at other approaches that might have advantages over the
18 existing systems.

19 We furthermore are very much concerned with
20 prematurely installing this before we know what system we
21 want, and before we really know how we would use the system
22 if we had it in there. Adding equipment per se to a nuclear
23 plant always has the disadvantage of the complexity of the
24 system in making the operating training and procedures more
25 difficult.

1 So we want to make sure where we do add equipment
2 that we do it in a fashion where the advantages outweigh the
3 disadvantages, and we need to understand both the hardware
4 and the software that would go along with it better than we
5 do today, before we would be able to make the statement that
6 we thought it was better.

7 So we plan to continue very actively the
8 evaluation that we have had underway, and plant to continue
9 our interaction with the staff on these questions, and
10 hopefully, will be able to arrive at a conclusion that is
11 acceptable to both of us as soon as possible.

12 MR. MOELLER: Questions for Mr. Keaton? Mr. Ward?

13 MR. WARD: Mr. Keaton, you mentioned something to
14 measure the reactor inventory several times. What do you
15 have in mind there?

16 MR. KEATON: Well, I don't have a system sitting
17 in my back pocket right now. The right kind of a delta P
18 system under quiescent conditions, I think. My concern is
19 with the force flow condition. In principle, it could
20 probably be done with a heated thermocouple system, provided
21 that the data from the reactor vessel were appropriately
22 processed. It would be more than just looking at which
23 thermocouple was covered and providing that some additional
24 data processing was done with respect to what's going on in
25 the loads. And I don't know how that's done. So getting a

1 good level of mass inventory strikes me as being a more
2 complicated problem than measuring the level, and we're
3 still trying to consider how we would do it.

4 MR. WARD: Thank you.

5 MR. MOELLER: Any other questions? Thank you, Mr.
6 Keaton. Let's turn to the staff and simply ask for a
7 response or comments that you may have at this time.

8 MR. NOVAK: Larry Phillips of the staff will make
9 some comments.

10 MR. MOELLER: Thank you.

11 MR. PHILLIPS: Good morning, gentlemen, I'm Larry
12 Phillips.

13 (Slide.)

14 There seems to be several questions concerning the
15 staff requirements and criteria. As indicated on the next
16 page of your handout, the criteria, we feel, are well
17 spelled-out in the referenced documents; 0660, 0737 and
18 1.97. We are prepared to make it -- some more definitive
19 statements concerning the conceptual designs which we had
20 been involved rather deeply in the review of. And this
21 staff has taken some positions concerning what is acceptable
22 conceptually.

23 Minimum instrumentation system. We would require
24 saturation meter for PWR's. It's not required for BWR's.
25 We would require coolant inventory or level above the core,

1 and we are using those rather synonomously. We don't think
2 it's a great problem to get from one to the other, since
3 we're looking for trending. We are not looking for very
4 precise inventory information.

5 The illustration of Westinghouse, GE and B&W and
6 CE plants are generally put in the perspective of what had
7 been proposed by the vendors for those particular reactors.
8 That is, Westinghouse has proposed a delta P system; CE has
9 proposed a heated junction thermocouple system; B&W has no
10 firm proposal as of yet. However, this does not preclude
11 interchange systems. For instance, a CE system could be put
12 on a Westinghouse reactor or vice versa.

13 We required -- the next point I think is a rather
14 important position we have taken actually within the last
15 week. In NUREG-0737 we indicated that we might accept core-
16 exit thermocouples as an indication below the core, provided
17 that it was processed in terms of level. CE, in their
18 heated junction thermocouple system, had proposed tying it
19 in with above core level processing, but actually using it
20 as an inversed temperature relationship rather than
21 attempting a direct level display.

22 They have indicated that level can be backed out
23 of it with more time, but they don't want to do that
24 online. The staff does agree with that approach, and our
25 position at this time is that conceptually, we do accept

1 that with a good processing system which will accomplish the
2 objectives that they have indicated. So we would not
3 require a direct level readout below the core.

4 Now, carrying that a step further, the same
5 situation would be true of a B&W reactor where, if they had
6 a level monitoring system or inventory monitoring above the
7 core and up into the candy cane, and with the existence of
8 their core exit thermocouples, they, too, could get by
9 without actually going into level below the core if they
10 properly interpreted their core exit thermocouple
11 temperature and tied that in with their above core level
12 display.

13 And, of course, core exit thermocouples are
14 required for all PWR's, and the staff position at present is
15 that thermocouples are also required for BWR's. And that
16 position is being appealed, but that is the current staff
17 position.

18 (Slide.)

19 The next slide that I mentioned just gives the
20 basis of the NUREG documents. We think there is nothing
21 greatly new in this. This was presented at the clarifica-
22 tion meetings over a year ago, and we indicated at least at
23 that time that we felt that the Westinghouse delta P and the
24 heated junction thermocouple concepts could be made
25 acceptable, and the staff position has not changed. We are

1 more confident today than we were then. We believe that
2 those systems can be made acceptable, and we expect to take
3 a rather definite -- to complete our review of these
4 systems, the generic systems, by the end of the year.

5 (Slide.)

6 Our position on TMI-1 restart is that existing
7 instrumentation with commitment to upgrade for NUREG-0737 is
8 acceptable for restart. We feel that we need evidence of
9 reasonable progress on additional instrumentation before we
10 would agree to restart.

11 Now, why do we feel there has not been reasonable
12 progress? Well, as I say, over a year ago the staff
13 indicated that here are two systems that have been proposed
14 in the industry that we put a number like over 95% or 99%
15 confidence in that they could be made into acceptable
16 systems. We see no evidence that the licensee in this case
17 has really made any indepth study of those systems. They
18 have given us no submittal with any details as to why either
19 of those systems could not be incorporated onto their
20 particular reactor.

21 In fact, some of the cases we heard indicated a
22 great deal of misinformation about the systems, and it's our
23 understanding that they have had no real contact or indepth
24 discussions with the vendors of the systems.

25 If we saw evidence, a good strong argument, that

1 hey, there is something unique about this reactor that makes
2 either of these systems no good per the application, then at
3 that point perhaps we would consider an alternate approach,
4 which is not far enough down the line in development with a
5 less-definitive design while they carry out this development.

6 At the present time, we feel that we would require
7 them to pick a system and just set out to install that
8 system, unless they can show us reasons why, as I say, those
9 particular systems cannot be used.

10 (Slide.)

11 MR. MOELLER: We have a question.

12 MR. KERR: Do I understand that there now exist
13 two systems which have been tested and demonstrated workable
14 and which the staff would approve today?

15 MR. PHILLIPS: There are two systems which have
16 been tested to a great extent and which the staff has under
17 review at the present time, and to which that review has
18 progressed to the point that the staff feels that something
19 like -- I guess we would put something like 99% confidence
20 on it; that when our review is complete and with any minor
21 modifications that we might require, that those systems will
22 be acceptable.

23 MR. KERR: So your answer to my question is no,
24 that there are not existing systems today which are approved
25 by the staff?

1 MR. PHILLIPS: We have not approved any systems.

2 MR. KERR: Now, what is it you want this licensee
3 to do?

4 MR. PHILLIPS: We want this licensee to evaluate
5 those systems in detail and to provide us with -- either
6 choose one of the systems or tell us why they cannot be
7 chosen, or to choose an alternate system which is in a
8 progressive stage of design.

9 MR. KERR: What do you mean by choose?

10 MR. PHILLIPS: By choose?

11 MR. KERR: Yes. Do you mean install?

12 MR. PHILLIPS: We want them to select a system,
13 proceed to procure it and lay out a schedule for
14 installation. Basically, everything that is on this
15 particular slide.

16 MR. MARK: Is anyone quite clear what, let's say,
17 the delta P system, in fact, will measure?

18 MR. PLESSET: I think that the delta P system is a
19 little more straightforward.

20 MR. MARK: I think it's the heated thermocouple
21 that a lot of people have some reservations about.

22 MR. KERR: It's straightforward if the system is
23 static.

24 MR. PLESSET: But I think they have been looking
25 at the dynamic effects. But I thought that there was some

1 question about the heated thermocouple system still that
2 might be serious.

3 MR. PHILLIPS: I think most of the serious
4 questions have pretty well been resolved. The design
5 currently essentially has the heated thermocouple enclosed
6 in a manner that what they're monitoring at the last level
7 is actually what they are measuring. It's on/off, it has
8 been well tested.

9 MR. KERR: But these tests have not been in
10 reactors, have they?

11 MR. PHILLIPS: They have been under reactor
12 conditions.

13 MR. PLESSET: I was aware of the enclosed feature
14 that you mentioned. I thought there were still questions
15 about them; what they would really measure. But there's no
16 point in pursuing it here.

17 MR. KERR: Certainly, in the minds of our
18 consultants there are questions about what they will measure.

19 MR. MOELLER: Mr. Bender?

20 MR. BENDER: Larry, how many operating plants have
21 been more responsive than this applicant or this licensee?

22 MR. PHILLIPS: In my opinion, all but one.

23 MR. BENDER: What have they done differently than
24 this applicant?

25 MR. PHILLIPS: Well, up to this point at least,

1 this applicant has taken the position that they don't --
2 essentially, to be blunt, that they don't need a system and
3 they're not going to install one. And this is inspite of
4 staff indication, oh, at least a year and a half ago that
5 that position was totally unacceptable.

6 I think we've seen more recently a little more
7 movement towards at least indication that well, we are
8 looking at systems harder now; we really are studying the
9 systems. I'm surprised that the emphasis is on the
10 procedures before they get the system or how it's going to
11 be used and the actions and so forth.

12 MR. CLARK: At some point I would like to comment.

13 MR. BENDER: I think we would like to know just
14 what GPU's position is on this.

15 MR. CLARK: GPU's position is that we have been
16 and are seriously evaluating the NUREG requirement to
17 provide improved instrumentation for detection of inadequate
18 core cooling. We feel in a very difficult position on this
19 item because one of the Lessons Learned from the TMI-2
20 accident, which we fully endorse, is that the utility
21 uniquely has the role of having themselves the competence to
22 balance and design operational characteristics, that we
23 cannot rely on the NSS supplier. And, in effect, say, if he
24 tells us it's okay, that we'll do it, that we have the
25 responsibility and we felt compelled to carry it out, and

1 that in this particular case, the question of how the
2 operator will use whatever instruments and what instruments
3 will, in fact, give him or others the needed information.
4 We feel that that question has to be decided before we add
5 complexity and possible confusion to the plant.

6 In particular, we feel that the reactor vessel
7 delta P for B&W plants is not shown to be adequate and
8 proper instrumentation. I think we heard today, I for the
9 first time, that apparently, the staff has agreed that
10 reactor vessel delta P is not required in the case of CE if
11 they make a combination of heated core thermocouples and
12 what I will call looped delta P. That's one of the things
13 we have been looking at.

14 It would be very easy for us to say we commit to
15 put in the system because somebody else says it works. But
16 we don't feel we should do that until we are satisfied that
17 it will work and that we know how to use it. So it is not
18 our position that we will not install instrumentation. I
19 don't believe we have ever said that. I think we have said
20 we are not prepared to commit to reactor vessel delta P
21 because we are not satisfied that that will do the job.

22 MR. BENDER: Mr. Clark, do you believe something
23 more is needed to determine whether there is adequate core
24 cooling or not in a plant?

25 MR. CLARK: From everything we have seen, we

1 believe that you can get -- and we will get -- the operator
2 adequate information to deal with LOCA's or other events,
3 with the existing and planned events including saturation
4 meter in the core thermocouples.

5 I think, however, we agree that additional informa-
6 tion would be desirable if there is a way to obtain it and
7 display it to the operator so that, in fact, assists him and
8 doesn't confuse him.

9 MR. BENDER: Do you believe the regulations
10 require something more than is there now?

11 MR. CLARK: I believe the regulation requires --
12 0737 requires evaluation of additional information, and I
13 believe the staff position is pretty clear up to this point
14 that they require reactor vessel water level. They have
15 defined some criteria for the instrumentation which, for
16 example, says full range.

17 I think that the continuing dialogue between us
18 and the staff and others is helping improve the
19 understanding of what is needed, and perhaps narrow the
20 difference and lead us to a selection of instrumentation
21 which would, in fact, be more helpful than the initial
22 concepts.

23 MR. BENDER: Well, this committee is on record I
24 think as saying that there are number of questions that need
25 to be resolved concerning the use of whatever instrumenta-

1 tion is provided. And I'm not aware that the staff has
2 responded to the committee's interest. It offered to meet
3 with the staff and discuss these matters.

4 Does the staff have a position on the fact that
5 the committee has raised questions?

6 MR. PHILLIPS: Yes, the staff prepared a response
7 to that very shortly after it came, and I think that -- I
8 don't know why it hasn't gone out yet. I think it got lost
9 somewhere in the general administrative passing through.

10 MR. BENDER: May I interpret that as meaning that
11 the staff really isn't very much interested in what the
12 committee's opinion is?

13 MR. PHILLIPS: No, absolutely not. We indicated
14 in the response that we would be happy to meet with the
15 committee and suggested -- we suggested that it be done in
16 the framework of the meeting on operating guidelines and
17 procedures, since most of the questions seemed to be
18 directed in that context.

19 MR. BENDER: Well, wouldn't it be fair to conclude
20 from the committee's commentary that it doesn't have the
21 same 99% confidence that the staff does that the two systems
22 that have been discussed are well enough understood to make
23 them usable at this time?

24 MR. PHILLIPS: Yes, I think you probably could
25 conclude that.

1 MR. BENDER: In view of that doubt, do you believe
2 the committee should sanction the staff's position that one
3 of these systems should be selected by this licensee and
4 plan for installation immediately?

5 MR. PHILLIPS. I think you should sanction the
6 staff's position that this licensee should get all the
7 available information on the systems and evaluate them for
8 installation in this plant, and at least provide us a
9 complete and accurate story of why he feels that they can or
10 cannot be used in his plant; as evidence that he is making
11 an honest effort and showing real progress towards doing
12 what he can to install an acceptable system.

13 MR. BENDER: Let's get back to the question I
14 asked sometime ago. What is it that you have gotten from
15 the other operating plants that's more complete than this?
16 What type of information are you getting?

17 MR. PHILLIPS: Well, there's a large number of
18 plants. I believe 27 or something like that who are
19 installing Westinghouse delta P systems and have committed
20 to have those installed by January. And there are some
21 other plants who have committed to the heated junction
22 thermocouple system.

23 There are other plants who have indicated that
24 they are studying -- .

25 MR. KERR: Do you think these will be installed by

1 January 1?

2 MR. PHILLIPS: I think they would have been
3 installed by January 1. Right now I would say there's
4 probably enough question concerning schedule that -- .

5 MR. KERR: I'm not sure what you mean by they
6 would have been. My question is do you think they will be.

7 MR. PHILLIPS: What I mean by would have been is
8 they could be installed by January 1.

9 MR. KERR: I guess I don't know how to make my
10 question -- .

11 MR. PHILLIPS: The systems are available, they
12 will be delivered and are able to be installed by January.

13 MR. BENDER: Well, the fact that all those
14 licensees have agreed to put something in could be
15 interpreted as blind response to regulatory demands without
16 adequate information. I think the licensee here is raising
17 a question as to whether he doesn't have a responsibility to
18 make sure that the device is a usable one before he commits
19 to it.

20 MR. PHILLIPS: Why did the licensee here make mis-
21 representations concerning the staff position, things that
22 were made very clear, I believe some of them, in NUREG-0737
23 and certainly, in the presentations at the clarification
24 meetings over a year ago.

25 As I said, what is indicated is just becoming

1 known today; that same thing was said over a year ago at the
2 clarification meetings concerning the use of thermocouples
3 to supplement the above-core monitoring of the heated
4 junction thermocouple -- of core-exit thermocouples, to
5 supplement.

6 I have heard them say things concerning the heated
7 junction thermocouple system in the Westinghouse delta P
8 systems that make it very clear that they have not studied
9 these systems in any detail or have not conferred with the
10 vendors on this system.

11 How can you say if the two systems which the staff
12 feels certainly have progressed the furthest and have the
13 best chance, that the licensee has not evaluated these
14 systems in any detail or made any submittals concerning that
15 evaluation; how can we say it's an honest effort?

16 MR. BENDER: Mr. Clark, could you tell us what you
17 have done?

18 MR. CLARK: Yes, I think I would like to say first
19 that if we have misrepresented the staff's position, if I
20 have, I apologize. I don't recognize where we have done
21 that, but I think part of the problem perhaps is that there
22 has been a fair bit of dialogue without reducing it to
23 writing, and clarifications provided in meetings are subject
24 to misunderstanding.

25 I think similarly, on our side, while we feel we

1 have been talking to the staff both directly and in these
2 meetings about what we are doing, we concluded at the sub-
3 committee meeting that we ought to reduce that to writing.
4 And in fact, I have here a draft we are unable to complete
5 to submit to the staff outlining more definitively what we
6 have done, are planning to do, the kind of thing we have
7 been presenting orally. And I think we have an obligation
8 and intend to fulfill it to go put that on the record to
9 attempt to clear up some of the misunderstanding or lack of
10 effective communication which appears to have existed.

11 I think importantly from our standpoint it is an
12 underlying question of whether one should commit to do
13 something until he understands how to use it or not. And it
14 has been our feeling that we should not commit to add some-
15 thing until we have thought out and understood how it would
16 be used. And I gather that we perhaps feel more strongly on
17 that point than the staff does.

18 MR. BENDER: How much time have you spent with the
19 two potential suppliers of this type of equipment?

20 MR. CLARK: I'll have to talk to someone to
21 determine that.

22 MR. MOELLER: While they're getting that
23 information, Mr. Okrent?

24 MR. OKRENT: No, I don't want to interrupt the
25 flow of discussion.

1 MR. MOELLER: Okay. Well, let's get this answer
2 and then have Mr. Okrent's question and then take a break.

3 MR. OKRENT: Again, I think Mr. Bender should
4 pursue his line until he feels he's completed the thought.

5 MR. MOELLER: Right.

6 MR. CLARK: We are having some trouble quantifying
7 that. I think maybe -- .

8 MR. BENDER: I don't need to know it to the
9 nearest hour. Have you been with them for a day?

10 MR. CLARK: This is Bob Keaton.

11 MR. KEATON: Maybe I can answer that. We have not
12 spent a lot of time in contact with Westinghouse and
13 Combustion Engineering. I agree with Mr. Phillips on that
14 subject.

15 We have been concentrating our attention on what
16 to do with information and what information we wanted,
17 rather than concentration on systems that were developed and
18 trying to figure out how to use those systems.

19 MR. BENDER: Well look, one of the lessons from
20 TMI was that discussions with the nuclear steam system
21 supplier and equipment suppliers is part of the learning
22 process, and there seems to be more introspection in this
23 thing than there is dialogue. And I guess I don't expect
24 this premise that you stated that you're looking at it very
25 carefully, if all you're doing is just cogitating your navel.

1 MR. KEATON: We have spent a great deal of time
2 with B&W on this question. You had asked me about
3 Westinghouse and Combustion.

4 MR. BENDER: I'm talking about Westinghouse and
5 Combustion as equipment suppliers. When you go to buy a
6 turbine that matches the B&W equipment, you don't go only to
7 B&W to discuss the equipment; you go to the turbine
8 manufacturer to see what he's going to provide you and you
9 try to match it up with the system. I don't see that kind
10 of discussion going on here.

11 MR. KEATON: Our initial approach to this, as I
12 think I tried to say, was to approach this through B&W in
13 the same way that the Westinghouse owners worked through
14 Westinghouse and the Combustion Engineering owners worked
15 through CE. And we have had extensive dialogue with B&W and
16 they have not come up with a system that meets the staff
17 requirements and frankly, that meets our requirements.
18 Perhaps we are some derelict in getting together with
19 Westinghouse and Combustion Engineering, and frankly, we do
20 intend to do that, but our initial approach was to work
21 through our own vendor.

22 MR. CLARK: I would like to add two things to
23 that. First, in terms of equipment capability, we do have
24 the Oyster Creek plant and as a boiling water reactor it
25 does have instrumentation for water level, two-phase flow,

1 et cetera. Mr. Keaton is aware of this instrumentation and
2 its capabilities, and in that sense, we have the CE input.

3 Second, recognizing that we were not satisfied
4 with our evaluations of the systems, we have already
5 contracted with the man at UCLA to perform for us an
6 evaluation of the equipment systems that are available. So
7 I have no problem with agreeing that we will -- and Mr.
8 Keaton says that he had intended to -- meet with the
9 Westinghouse and CE people. But I think we have been
10 pursuing these other points that I have mentioned and have
11 been addressing the problem, and are not just avoiding it.

12 MR. BENDER: Well, I know this committee is not
13 totally satisfied that it understands all the capabilities
14 that are needed for such a system, but I have some discom-
15 fort with the progress that's been made. I think I have to
16 agree that the staff may have reason for raising questions.

17 MR. CKRENT: Well, I guess I would like to follow
18 on Mr. Bender's last point. Does the licensee have a
19 proposed schedule for arriving at resolution of the issue?
20 I can be sympathetic with the point of view that they need
21 to know what's in their plant. I can also be sympathetic
22 with the point of view that says at some point, you need to
23 arrive at an answer.

24 And so, I guess what I would like to know is do
25 they have a time by which they, in fact, expect to come up

1 with some specific recommendation for what they think, (a)
2 is practical; namely, that they can get it; (b) represents
3 the necessary advance beyond the saturation meter; and (c)
4 by when will they do that and why is that a suitable time
5 period.

6 MR. CLARK: The final step on Mr. Keaton's chart
7 was to perform an evaluation and either select an available
8 concept or decide what further development to pursue. I
9 think that was the choice. The UCLA study is scheduled for
10 completion at the end of this summer. I think we would
11 foresee evaluating that.

12 The other ongoing work that we have, the
13 information obtained from contacts with the vendors which we
14 intend to make and have been urged here to do and come to a
15 conclusion this fall as to whether there's a system we would
16 pick to install, or what further development we would intend
17 to pursue.

18 MR. MOELLER: Any other questions on this topic?
19 Well, Mr. Chairman, I would suggest a break until 11:00.

20 MR. MARK: So be it.

21 (A short recess was taken.)

22 MR. MARK: The meeting will resume.

23 MR. MOELLER: Thank you, Mr. Chairman. The next
24 item on the agenda is a discussion of additional studies to
25 identify possible events which might lead to the loss of

1 both battery trains, and this will be a presentation by the
2 licensee, followed by comment on other studies that the
3 licensee has underway.

4 MR. CLARK: Mr. Chisholm, the Manager of
5 Electrical Power and Instrumentation, will make that
6 presentation.

7 (Slide.)

8 MR. CHISHOLM: We have had an ongoing study at TMI
9 looking at reliability and long-term planning for
10 improvements on the system. For purposes of this report, we
11 focused on responding to NUREG-0666, which was a staff
12 report presented to a subcommittee meeting in January.

13 The conclusions in that report involve the
14 consequences of common mode failures which could lead to a
15 loss of both batteries. Just to briefly summarize that
16 report, it divided the type of failures into two types. One
17 failure is the kind of failure wherein the batteries become
18 unavailable after you have lost power.

19 MR. MOELLER: We can't hear you, and go back and
20 repeat, if you will, the last statement.

21 MR. CHISHOLM: The Type 1 failures are those that
22 become evident after a loss of offsite power, when the power
23 from batteries is demanded and not available. A Type 2
24 failure is failure of the DC system, which are directly
25 attributable to mistakes in operational maintenance that
directly relate to loss of DC power. They are about equal

1 in probability.

2 The first one depends directly on the particular
3 reliability of the AC offsite power at the plant. The
4 combination of the two has the probability of 6 times 10⁻⁵
5 per reactor year which is a very large number, and in fact,
6 represents half of the probability of all accident sequences
7 studies which would lead to core damage.

8 The report further makes some recommendations,
9 stating that this could be reduced by a factor of 50 if
10 certain things were done such as prohibiting bus ties and
11 improving maintenance test procedures.

12 (Slide.)

13 In response to this report, we did make certain
14 improvements, certain changes at Three Mile Island. We have
15 locked open disconnect switches, the main bus tie switches
16 are going to be locked open, the disconnect switches will be
17 locked closed. We have put into place procedures to
18 restrict the use of these switches to cold shutdown.

19 We found one bus tie in the plant which we studied
20 and decided was not justifiable and that is being removed.
21 We have put in recovery procedures for the electrical system
22 to give the plant people guidance as to when they lose one
23 battery, how they can proceed without jeopardizing the
24 second one.

25 And we have reviewed the maintenance and test

1 procedures to make sure that there were no precautions in
2 them to preclude these common mode events.

3 (Slide.)

4 Going over and using the same kind of approach
5 that was done in NUREG-0666, and using some of their numbers
6 we tried to put a quantitative evaluation of how our
7 improvements would improve the reliability which was
8 included in 0666. And also, we have looked at several
9 things in the TMI-1 plant which were different than the
10 plant studied in NUREG-0666.

11 And we have concluded that whereas the report had
12 stated that a factor of 50 could be achieved, we think that
13 our plant with its differences and with the changes we are
14 making, we get a reduction of about .003, which is an
15 improvement of about 100. So we feel that we have
16 established the fact that the reliability is much better
17 than that which is concluded by that report and much better
18 than the prediction that could be achieved by the
19 recommendations of the report.

20 MR. KERR: Before you begin this, did you go
21 through 0666 and see if you agreed with its conclusions?
22 Did you do a detailed review of that analysis?

23 MR. CHISHOLM: Well, we have not done a
24 quantitative assessment of TMI-1 yet, and as Mr. Keaton -- .

25 MR. KERR: I'm not making my question clear. Did

1 you go through the report in detail and see if you would
2 draw the same conclusions about reliability of the system
3 analyzed in that report, that the NRC staff drew?

4 MR. CHISHOLM: Yes, I guess in a general way I
5 would agree with the conclusions of that report.

6 MR. KERR: How about in a detailed way?

7 MR. CHISHOLM: The closest I can get to that is we
8 did a quantitative analysis on Oyster Creek on that system,
9 and if we compare the quantitative results of that against
10 not the initial figures of NUREG-0666 of 6 times 10⁻⁵
11 events per reactor year where you lost both batteries, but
12 the improvement that we think shows up in the specific
13 differences in the system, I think within an order of
14 magnitude or so we would agree with it.

15 In other words, the Oyster Creek study -- .

16 MR. KERR: I'm sorry, I don't understand. I'm
17 either not making my question clear or -- what I'm trying to
18 find out is whether you followed in detail the analysis that
19 they used to get their results and whether you agreed with
20 their results.

21 MR. CHISHOLM: Yes, we do. If you start out with
22 the system they studied and the assumptions they made, yes,
23 we would agree with it.

24 MR. KERR: Okay.

25 MR. MOELLER: Mr. Ray?

1 MR. RAY: Could you tell me the basis on which you
2 conclude that this plant has more reliable offsite power?

3 MR. CHISHOLM: Yes. I think there are really two
4 parts to that. First of all, I think that TMI-1's location
5 is close to a major center of the local distribution where
6 the PJM system ties, and right within a mile of the plant is
7 the Middletown Junction Substation, which is the major point
8 in that system. And without going into the details of the
9 number of lines and so forth, PJM at one point did a
10 quantitative study of the reliability of that point and its
11 susceptibility to failure and so forth.

12 I don't have the number offhand as to what it was,
13 but it was an extremely reliable point.

14 The other point that should be made is that in
15 NUREG-0666, a large part of the type of failures that they
16 postulate are switching failures after a generator trip.
17 The configuration of the TMI-1 plant is such that the
18 auxiliary transformers are fed directly from the grid, and
19 we do not challenge any switching systems when we trip the
20 generator.

21 The power is available at all times without
22 switching from auxiliaries to startup transformers. So we
23 feel that the improvement in numbers they used was not quite
24 arbitrary but it was based on some data in the report. They
25 had a five to one uncertainty between the main system which

1 they used and the best system that existed, and I think what
2 we have is close to being about the best system around.

3 MR. RAY: I'd like to make sure I understand your
4 second point. The fact that the auxiliary power is fed from
5 offsite sources, you mean there's no bank, and therefore,
6 when you lose a unit, you don't have to shut down your
7 auxiliaries in sequence and then come back in to service
8 them? They just continue to run, supplied by offsite power?

9 MR. CHISHOLM: Yes.

10 (Slide.)

11 The aux transformers come directly from the 230 kV
12 bus; whereas, the generator feeds the bus separately, so on
13 a generator trip, it leaves the aux transformers running
14 continuously.

15 MR. OKRENT: If my arithmetic is right, if I take,
16 say, 6×10^{-5} and divide it by 300 I get 2 times
17 10^{-7} . And the other way, I would get 3 times 10^{-7} .
18 Anyway, I would get a small number.

19 MR. CHISHOLM: Yes.

20 MR. OKRENT: When numbers get that small, you have
21 to ask yourself are there scenarios that I haven't included
22 in my earlier thinking because I already had so big a number
23 I didn't need to think about them. Have you gone through
24 that kind of a thought process to see whether you really
25 believe what you have put on these slides?

MR. CHISHOLM: Well, I think we have to the extent

1 that -- the approach we took was to try to just respond to
2 the factors that were pointed out in NUREG-0666. I guess in
3 the future we intend to do a specific analysis of TMI-1 and
4 a quantitative analysis, and we have not done that.

5 What I did here was to try to show specific
6 improvements in the areas that were pointed out in 666.

7 MR. KERR: I would judge that he didn't understand
8 your question. Why don't you try again?

9 MR. OKRENT: I don't know that he didn't
10 understand the question. I'll let you try to explore it if
11 you want.

12 MR. KERR: My impression was that you were being
13 asked whether there were low probability contributors which
14 would contribute on the level of 10^{-7} or so but wouldn't
15 contribute it at a level of 10^{-4} , which you maybe didn't
16 consider after having bridged this very low number. I
17 didn't hear the response to that.

18 MR. CHISHOLM: I guess that's true. We did not
19 try to reconsider those things. For example, this study
20 only looked at common mode failures which were the dominant
21 contributors when you had a large number. There may be non-
22 common mode effects that now become significant in
23 addressing that and that was not looked at.

24 MR. KERR: There might even be low probability
25 common mode effects which haven't been considered.

1 MR. CHISHOLM: That's possible, yes.

2 MR. MOELLER: Other questions on this topic? Mr.
3 Ray.

4 MR. RAY: I don't see in the handout the slide you
5 had that showed the changes in practices and so on. Is
6 there any reason for that?

7 MR. CHISHOLM: Yes, the reason was I was asked to
8 make this presentation in ten minutes and I wanted to keep
9 the number of --.

10 MR. RAY: Could you make that available to us?

11 MR. CHISHOLM: I certainly could, yes.

12 MR. RAY: The other question is among the
13 recommendations in 0666 NUREG, I saw many tests and
14 maintenance activities. Either I wasn't listening hard
15 enough or you didn't mention that.

16 (Slide.)

17 MR. CHISHOLM: I went over it very briefly, but I
18 will be glad to expand on it.

19 Some of the things that we have initiated are
20 periodic surveillance of the terminal connections on the
21 batteries, and we are doing that in two ways. One is
22 checking, doing a periodic talk test on the connections.
23 The other is we are trying out a thermal surveillance
24 technique that hasn't been put into procedure yet but it's
25 being used.

1 The other things in terms of procedures, we have
2 written some new procedures, recovery procedures, where if
3 one battery is degraded we have a specific procedure about
4 what the plant people should do to avoid jeopardizing the
5 second one.

6 As far as the maintenance procedures, they have
7 been reviewed and in cases where there was a possibility of
8 those procedures leading to some kind of damage to the
9 batteries, we tried to put precautions in the procedures so
10 the person that was doing them would be aware of these
11 things and would avoid them.

12 MR. RAY: How about training the people who are
13 going to do that? Are you going to change your training
14 practices?

15 MR. CHISHOLM: I'm not responsible for training so
16 I really can't respond to that directly.

17 MR. RAY: Certainly, the maintenance of the heat
18 of the system, if I could put it that way, should be --
19 proper maintenance of that and techniques and so on,
20 procedures -- should be a major portion of your training
21 program.

22 MR. CLARK: Mr. Ross who is the next speaker will
23 try to address that. While we can't address it
24 specifically, I can tell you that we have much increased the
25 level and amount of maintenance training, recognizing just

1 what you say. I can't specifically say whether this point
2 is in it or not.

3 MR. RAY: But you recognize the need for it.

4 MR. CLARK: Absolutely.

5 MR. RAY: How about an inspection of the DC
6 system? Are you going to change your policies and make that
7 more frequent?

8 MR. CHISHOLM: I think the frequency of our test
9 is -- it's more frequent than the assumptions that were made
10 in NUREG-0666. I don't know the exact numbers, but our
11 testing is more frequent than that.

12 MR. RAY: Thank you.

13 MR. MOELLER: Any other questions? Thank you, Mr.
14 Chisholm. Do we have questions or comments by the staff on
15 this topic?

16 MR. STOLZ: John Stolz speaking. We believe that
17 in general, the TMI-1 DC battery system meets the minimum
18 requirements of 0666 with respect to reliability, and
19 certainly meets three out of four of the recommendations of
20 that report. So we believe that accordingly, it is
21 acceptable.

22 MR. CKRENT: Excuse me. What do you mean when you
23 say it meets the minimum requirements of 0666?

24 MR. STOLZ: That is that it met the objective of
25 increasing the reliability to the level stated in that

1 report.

2 MR. OKRENT: Okay.

3 MR. KERR: Is there a maximum requirement of 0666
4 or just one requirement?

5 MR. STOLZ: I'm not aware of a maximum requirement.

6 MR. KERR: So it really met the requirement, then.

7 MR. STOLZ: Yes, sir.

8 MR. MOELLER: The next topic is the licensee to
9 discuss other studies underway.

10 MR. CLARK: Mr. Ross as the Manager of Plant
11 Operations will address this.

12 MR. MOELLER: Thank you. Mr. Ross?

13 MR. CLARK: I want to address that. He will
14 address the ECCS outage questions. Some of the other
15 questions will be addressed later, by someone filling in for
16 Mr. Wilson.

17 MR. MOELLER: Fine.

18 MR. CLARK: In the interest of time, can I suggest
19 we move to the next item? We have a point under discussion
20 here on this.

21 MR. MOELLER: Fine, let's go into the discussion
22 of additional SCRAM versus PORV actuation.

23 MR. CLARK: That's Mr. Keaton.

24 MR. MOELLER: Mr. Keaton, we have listed 20
25 minutes for this side. I think we will go with the licensee

1 first and then ask the staff for any comments.

2 MR. KEATON: I don't have any viewgraphs for this
3 portion of the presentation because my answer on this is
4 very quick to give.

5 We have not done a quantitative evaluation of the
6 change in probability and the associated change in risks
7 associated with the switch and the setpoints of the PORV in
8 the high pressure trip. It was our qualitative evaluation
9 that given the present hardware performances we have seen
10 throughout the industry, that to make the change so that the
11 trip on high pressure occurred before the PORV would be
12 actuated, was qualitatively a direction in the direction of
13 improved safety. And so we concurred with the staff that
14 that change should be made and we have made it.

15 As a result of the overall plant risk assessment
16 study which I described earlier, we feel that once those
17 numbers are available, that we would be able to use them as
18 a basis for doing something quantitative, but we do not have
19 them at the present time.

20 MR. MOELLER: Okay. Why don't we move to the
21 staff, then, and ask for their comments on this subject? Of
22 course, the committee has commented on the need for quantifi-
23 cation of the risks, or whether this does lead to diminished
24 risk.

25 MR. CHOW: My name is Ed Chow, I'm with the

1 Reliability and Risk Assessment Branch in NRC. Today, I
2 would like to talk about operating data on PORV and reactor
3 trips at B&W plants. Basically, I will break down my talk
4 into two parts; one is a comparison of the PORV openings
5 with reactor trips pre-TMI and post-TMI; and my second one
6 covers the number of trips pre-TMI and post-TMI.

7 So the post part would be the number of PORV
8 openings and the information I will be using is based on
9 NUREG-0667. That's the transient response of B&W designed
10 reactors.

11 If you just look at it pre-TMI, the number of
12 openings is 149. So the average number of PORV openings per
13 reactor year is estimated to be about five. And if you
14 compare that with post-TMI, as far as we know there are two
15 incidents where the PORV opens with reactor trip. So if we
16 estimate the average number of PORV openings per reactor
17 year, it's about 11.

18

19

20

21

22

23

24

25

1 The second part I wanted to talk about is the
2 number of reactor trips.

3 MR. KERR: I didn't understand the point you were
4 making. Are you saying that there are simply fewer trips
5 now than there were before, or fewer trips per year or per
6 plant?

7 MR. MOELLER: As I understood he, included here
8 both the PORV opening and a trip. Is that correct?

9 MR. CHOW: That is correct. I am talking about a
10 challenge to PORVs. I am talking about a reduction in
11 number of PORV trips after TMI.

12 MR. KERR: At TMI?

13 MR. CHOW: After TMI.

14 MR. KERR: Would you mind repeating what you said,
15 and maybe I will understand it this time. I won't ask for a
16 third time.

17 MR. CHOW: Just briefly, the number of PORV
18 openings per reactor trips. We were talking about
19 transients where the pressure in the primary coolant system
20 goes up so high so they actuate PORV. It also goes further
21 up to cause reactor trips, and pre-TMI the number is 149.

22 MR. MOELLER: And that 149 equals five per year for
23 all of our reactors or for what?

24 MR. CHOW: Five per reactor year. That is for all
25 the B&W reactors.

1 MR. KERR: And this is an event in which one got
2 both a PORV opening --

3 MR. CHOW: Both PORV openings and reactor trips.

4 MR. MOELLER: And that is before the change in the
5 settings.

6 MR. KERR: Right.

7 MR. CHOW: And when we compared that with the
8 post-TMI situation where we have a difference in terms of
9 the PORV setpoints and reactor high pressure trips, we have
10 a reduction in the number of PORV openings with reactor
11 trips, and as a matter of fact we have two PORV openings
12 with reactor trips after TMI.

13 MR. KERR: Okay. I think I understand what you
14 are saying. What I would have been interested in, but maybe
15 you are going to tell me, is the number of times one got
16 PORV openings without reactor trips, and the number of
17 additional trips that have been caused by the resetting. I
18 assume earlier one would have gotten PORV openings which
19 didn't produce reactor trips and now one is getting reactor
20 trips that would have previously been PORV openings.

21 Are you going to give me data on that?

22 MR. CHOW: Yes, sir. In the second part I will
23 address the number of trips.

24 When we look at the number of trips pre-TMI
25 according to NUREG-0667, we have 232 number of trips. So

1 keeping in mind these trips include the number of PORV
2 openings with reactor trips plus other trips, so if we just
3 estimate using the average number of reactor trips per
4 reactor year, it's about 7 or 8, somewhere between 7 and 8.

5 When we look at the post-TMI data in the year of
6 1979, the number of reactor trips actually is 45, and if we
7 go further, in 1980 the number of reactor trips is 34. And
8 for this year since we only have data for the first six
9 months, we have 13 reactor trips.

10 So as far as comparing the number of trips after
11 TMI, we believe there is not a significant increase in terms
12 of reactor trips. Obviously in '79 there were more trips
13 than there were in '80. The reason is due to larger number
14 of startup and shutdowns and also due to the operator
15 lacking experience in using the setpoints.

16 So based upon our conclusion, we say that with the
17 new setpoints the average number of PORV openings with
18 reactor trips has been reduced, and with the new setpoints
19 the number of reactor trips does not indicate that it has
20 increased in a considerable manner.

21 MR. BENDER: Aren't you a little skeptical of
22 drawing conclusions from those data? I would be a bit
23 skeptical because I can't see why, unless the conditions for
24 operation have changed, that one wouldn't be getting more
25 trips now, because previously when you wouldn't have gotten

1 a trip and would have gotten a PORV opening, you now should
2 get a trip. I just don't see why if conditions were similar
3 you wouldn't be getting more trips, but I must be missing
4 something.

5 MR. CHOW: The conditions are different not just
6 in terms of setpoint of change. Also you have in terms of
7 the modification upgrading of other systems involved.

8 MR. TADANI: Dr. Kerr, I would tend to agree with
9 you. Yes, indeed one would be skeptical to increase the
10 number of setpoints to trip the reactor. You would expect
11 more trips. I don't think we have had enough experience yet
12 to determine. I think we have confidence that the trip
13 frequency hasn't gone up significantly.

14 I think what Ed is trying to say is on one hand
15 you do see a dramatic reduction in challenges to PORVs, and
16 on the other hand you do not see a significant increase in
17 trips. Only time can tell us.

18 MR. KERR: If I didn't know any better, I might
19 conclude that was because the reactors were operating only
20 half the time and so you wouldn't get either trips or PORVs
21 opening.

22 MR. TADANI: You are absolutely right. Other
23 considerations would come in to play. But even if there
24 were a factor of 2 in there, you do see significant
25 reductions of PORV challenges. I think that is the key

1 point.

2 The other point is, of course, even if you did not
3 trip the reactor, you would need to challenge other systems
4 such as PORV.

5 MR. KERR: Well, the question that I raised and
6 perhaps others was whether there is greater risk associated
7 with the PORV opening than there is with the trip, and I
8 don't see that one necessarily has to know how many trips
9 occur per year in order to answer that question, but maybe
10 you do.

11 MR. TADANI: I think there are two ways one could
12 look at that. It is obviously a fairly complex question.
13 One way would be to go to structural people and ask them if
14 the frequency is going up by a certain factor, if you will,
15 would you be concerned? The general response from
16 mechanical engineering people has been they are not
17 concerned about the frequencies that they are seeing.

18 MR. KERR: I don't think either one of us should
19 try to answer the question here this morning. I just wanted
20 to make certain that you understood the question I was
21 raising.

22 MR. TADANI: I think I understand it.

23 MR. KERR: I think qualitatively people have
24 concluded that there is less risk in tripping than PORV
25 opening, and that is the reason for changing setting, isn't

1 it?

2 MR. TADANI: Yes. Because of the significant
3 reduction, that is to me critical. It is a factor of 50 or
4 so reduction in challenge frequency.

5 MR. BENDER: When I listened to the statistics,
6 the number I heard only identified PORV openings that led to
7 trip. Now, do we know anything about PORV openings that
8 didn't lead to trip?

9 MR. TADANI: I think I am not aware of any such
10 situation since the TMI-2 event. Now, I believe there were
11 events like that prior to TMI-2.

12 MR. BENDER: Are you saying you are not aware of
13 them and therefore there were none, or that there just is no
14 record of any?

15 MR. KERR: Under the present setting this couldn't
16 occur unless something went wrong because you trip at a
17 lower pressure, don't you?

18 MR. TADANI: I suppose it is possible, depending
19 on the logic for scram. You may need two out of four
20 pressure channels to trip the reactor, but you only need one
21 failure channel in the pressure channel to open the PORV. I
22 would still expect the reactor would scram even if the
23 initiating event is in the PORV.

24 MR. BENDER: Well, if the answer is every time the
25 PORV opens now there is a scram, or let's say 95 percent of

1 the cases --

2 MR. TADANI: That would be my expectation, yes.

3 MR. BENDER: Okay, fine.

4 MR. MOELLER: Other questions or comments?

5 Have you finished your presentation or do you have
6 more?

7 MR. CHOW: Yes, that pretty much summarizes what I
8 have said.

9 MR. MOELLER: All right.

10 Any other questions for Mr. Chow?

11 Well, thank you.

12 We will move on, then. Do you want to pick up the
13 item we just skipped?

14 MR. CLARK: Either way.

15 MR. MOELLER: Okay, let's pick it up, and that is
16 the ECCS outages. That is, as I recall, primarily simply a
17 reporting of the frequency of occurrences; is that right?

18 MR. CLARK: We believed it was on the agenda
19 because it was still an open item. Mr. Ross is going to
20 give the status of where we are in closing it out.

21 MR. MOELLER: Fine.

22 MR. ROSS: My name is Mike Ross. I will just
23 pretty much give you the same type report I gave to the
24 subcommittee last week, our status in closing out this open
25 item with the staff, and the item is ECCS outage of

1 reporting.

2 It is pretty much the same as we had reported.
3 Basically we sent a letter to the staff outlining our
4 approach to closing this out. We will go through and review
5 all licensee event reports, tabulate the time that the
6 ECCS-type equipment was involved in this and the amount of
7 time it was out of service. In addition, we will go through
8 and tabulate the amount of time the ECCS equipment is out of
9 service for surveillances.

10 This time we reported to the staff, and in the
11 report by the end of this month, July, we feel that the
12 staff will accept this as our final submittal and we will
13 close the item.

14 MR. MOELLER: Have you looked at LERs to see how
15 easily you can pick out this information?

16 MR. CLARK: Roy Harding from Licensing.

17 MR. HARDING: My name is Roy Harding. I have been
18 involved in part of the review of the LERs. Some that I
19 have looked at of the LERs from approximately 1975 to 1980
20 -- some of the LERs have the exact time frames. Others do
21 not but it can be easily inferred., A very good guesstimate
22 can be given as to what that time frame was.

23 We also have some maintenance record printouts
24 that we can use. Using the date from the LER, we can bounce
25 that against the date of the LER and determine time

1 frames from that.

2 MR. PLESSET: Could the staff tell me what is
3 involved on this point, what is the concern?

4 MR. NOVAK: The staff's concern is to identify if
5 in fact a tech spec which permits ECCS equipment to be taken
6 out of service could then be returned and taken out without
7 any concern for the integrated availability of that system.

8 MR. PLESSET: What does that mean, Tom?

9 MR. NOVAK: Well, what we are looking at is the
10 following. We are wondering if in fact a tech spec
11 shouldn't be developed so that in fact it says as you go
12 through an operating year, there should be an assurance that
13 the availability of that system is high enough that it is
14 there most of the time. The way a tech spec is written on
15 ECCS is that if something goes out, you have 72 hours that
16 it may be out, and if you can't fix it, then you have to do
17 something, and then next week that same thing can happen
18 again and there is no history affected, there is no history
19 penalty.

20 Our approach is there should be some sort of
21 bookkeeping that says the system should not be going out
22 every week and considered to be reliable even though they
23 restore it. So the concern is look at the history of the
24 outage of that system and see if there isn't a criteria that
25 should be established to assure that over a long period of

1 time it is more available than unavailable.

2 MR. PLESSET: So here is a safety system which you
3 allow to be out and the plant continues to operate.

4 MR. NOVAK: Where, there is a limiting condition
5 of operation. In other words, there is a restoration time
6 permitted. It isn't automatic. You may have a shift, you
7 may have a day, you may have three days, depending on the
8 equipment, to bring it back into an available status.

9 MR. PLESSET: During which the plant operates?

10 MR. NOVAK: That is correct.

11 MR. PLESSET: Are there any special procedures
12 applied?

13 MR. NOVAK: Generally yes. You check out the
14 remaining systems to make sure they are available.

15 MR. PLESSET: How careful are they to follow
16 this? That is an important point because this is really not
17 a good situation.

18 MR. NOVAK: By technical specifications they are
19 required to, and if they fail to perform surveillance test
20 of the sister train, so to speak --

21 MR. PLESSET: Okay. That is what I wanted to be
22 sure that they had good procedures for this.

23 MR. MOELLER: Now, the LER that is being done is a
24 generic study. Is it only for B&W plants?

25 MR. NOVAK: No, it would apply to all plants.

1 MR. MOELLER: Okay. Any other questions or
2 comments? Fine.

3 We will move on to the next item, which is a
4 discussion of the effectiveness of the 4 psig containment
5 isolation setpoint, and this is with regard to the 30 degree
6 setting on purge valves.

7 Why don't we go with the staff first and ask for
8 comments on that?

9 MR. NOVAK: Peter Hearne of the Containment Systems
10 B h will make a short presentation.

11 MR. HEARNE: With the first valve the licensee is
12 required to meet the first parameters for his isolation
13 signals. He is to sense at least two parameters over a
14 spectrum of LOCA breaks. That is to assure that he senses
15 one parameter for each individual break.

16 The licensee has chosen 4 psig containment
17 pressure trip as one parameter. That would be mainly used
18 for the large LOCA breaks. He has also chosen the reactor
19 pressure parameter and the reactor trip signal and that
20 would cover all breaks. Each of these isolation signals are
21 redundant. With those two parameters TMI satisfies the
22 requirements for the purge valves.

23 MR. MOELLER: But is the 4 psig meaningful? Would
24 it ever take place? That is our question.

25 MR. HEARNE: For the large breaks it would.

1 MR. MOELLER: For the large breaks it would.

2 MR. NOVAK: I understand the licensee in their
3 presentation will indicate some more information about
4 pressure versus break size.

5 MR. MOELLER: How did you conclude that it would
6 reach 4 psig and in what time frame for a large break?

7 MR. HEARNE: It is based on other plants using a
8 single parameter, and it is based on a qualitative judgment
9 that you have an event which will have a maximum of a 4 psi
10 pressure drop across the purge line which is 48 inches in
11 diameter versus a 38 inch source in the reactor coolant.
12 You will have a pressure drop, and if you think about it too
13 long it will not take very long before --

14 MR. CLARK: We have some analytical results.

15 MR. MOELLER: Fine. I think that is fine. That
16 is what I was looking for.

17 Does that complete your remarks?

18 MR. HEARNE: Yes.

19 MR. MOELLER: Okay, let's go on.

20 MR. CLARK: Mr. Broughton, Systems Analysis
21 Director, will make this presentation.

22 MR. MOELLER: Fine.

23 (Slide)

24 MR. BROUGHTON: Before we go into the effect of
25 the open purge valves on pressure, I want to indicate that

1 in the handout there is the isolation signals that are used
2 in TMI-1. For each of the lines to be isolated there are at
3 least two different signals, and in some cases there are
4 three different signals which could cause the valve to shut
5 or a line to be isolated.

6 The original isolation system on TMI-1 prior to
7 these revisions for restart was basically in isolation on
8 the 4 psig building pressure, and all the items on this list
9 would have isolated on 4 psig pressure with the exception of
10 the purge valve, which would isolate not only at 4 psig but
11 also at high radiation level.

12 So the areas that are blocked in indicate where
13 diversity has been added to the system as a result of
14 modifications.

15 (Slide)

16 In response to the question of what effects did
17 the open purge valves have on containment pressure, during
18 the past two weeks we have made some computer analyses using
19 the CONTEMPT code, which was a code normally used to predict
20 containment response for licensing design basis events.
21 This chart here presents a summary of that information.

22

23

24

25

1 The upper line that says "purge valves closed"
2 indicates the maximum containment pressure you would expect
3 to see for a given break size using standard FSAR
4 assumptions for loss of coolant action. The lower line,
5 which is labeled "purge valve open," represents the
6 additional information that we developed during the past two
7 weeks.

8 I would like to point out that there are three
9 main regions to consider here in discussing the effect of
10 purge valve opening. The first is the region over to the
11 right, in which even with the purge valves open the
12 containment pressure reaches four pounds and continues to
13 rise, so this would be for large break LOCAS, that is,
14 anything greater than .5 square feet. And it is also for a
15 considerable number of small break LOCAS.

16 The next region to look at is this region here,
17 which is less than about .005 square feet, which are usually
18 termed very small breaks, in which 4 psi is not reached
19 regardless of whether the purge valves are open or shut, and
20 the reason is there is enough containment coolant to be able
21 to remove the energy that is being released.

22 The third region is the one in the middle, which
23 would be small breaks, which if the purge valves were shut,
24 would cause 4 psig to be reached, but with the purge valves
25 open would not. The maximum break size that falls into that

1 category is on the order of .1 square feet. It actually
2 comes down to about .85 square feet.

3 MR. MOELLER: Where is the pressure reading taken
4 to actuate these things?

5 MR. BROUGHTON: This containment pressure refers
6 to the average pressure within the containment.

7 MR. MOELLER: Are there three or four pressure
8 gauges or how many?

9 MR. BROUGHTON: I believe there are three pressure
10 sensors inside the building. I believe they are physically
11 located outside the building. But they are part of the
12 safeguard system which has been installed in the plant.

13 MR. MOELLER: But there are three in there in
14 three different places, presumably -- or the sensors are.

15 MR. BROUGHTON: They are in three different
16 places. I'm not sure whether they are on different levels
17 or around the building at different radial locations.

18 MR. MOELLER: And was their location considered in
19 the CONTEMPT code?

20 MR. BROUGHTON: The CONTEMPT is a homogeneous
21 model so it computes the average pressure that you would see
22 in the system, and in general these transients are slow
23 enough that that is reasonable. That is especially true for
24 the small breaks in which it may take 60 seconds or so to
25 reach 4 pounds.

1 MR. MOELLER: I was thinking of the small breaks,
2 that's true. I was just wondering if in the larger breaks
3 the pressure gauge was down somewhere where it might sense
4 the pressure increase a little earlier, or at least one of
5 them being where they would sense it as early as possible.

6 MR. BROUGHTON: The significance of the break at
7 which 4 psi is reached is roughly as follows. For small
8 breaks that are on the order of .08 to .1 square feet, the
9 core remains covered throughout the scenario so the
10 likelihood of gross fuel damage is small.

11 It is only for breaks on the order of .08 or .1
12 square feet or larger in which uncovering would be expected to
13 occur and therefore the likelihood of damage in high
14 radiation releases would be greater.

15 (Slide)

16 The assumptions that we have used are ones that
17 are pertinent to TMI-1. There are two 48-inch purge lines.
18 In each line, one valve is limited to 30 degrees open, and
19 that produces equivalent line size of about 17 inches.

20 MR. MOELLER: At the time of the TMI-2 accident,
21 what was the situation? Were the purge valves open at 30
22 degrees then?

23 MR. BROUGHTON: At TMI-2 the purge valves were
24 shut at the time of the accident. At TMI-1 the limitation
25 of 30 degrees open has just recently been -- we did not have

1 that restriction prior.

2 MR. MOELLER: Okay.

3 MR. BROUGHTON: We have assumed in the analysis I
4 have shown you that the purge valves did not close on any of
5 the other signals that would cause them to. Therefore, the
6 pressure increases that you saw were pressure increases
7 which would exist even with the valves open, and we also
8 assumed that maximum heat removal from other sources was
9 present, which would tend to decrease the pressure estimate.

10 The results, as we have discussed, are that for
11 large breaks and even small breaks at the larger end of that
12 spectrum, 4 psig is still reached. For the small breaks, 4
13 psig is not reached, regardless of whether the valves are
14 open or shut. And the conclusion we drew from this is that
15 the 4 psi signal is still valid if the purge valves are
16 limited to 30 degrees open.

17 The reactor trip isolation signal, which is the
18 primary containment isolation signal, anticipates both the
19 building pressure condition and the safety systems injection
20 for Three Mile Island.

21 MR. MOELLER: Thank you.

22 Any questions on this topic, further questions?

23 There being none, let's move on to Item I on our
24 agenda, which is the control room design review, and that
25 will be a presentation by the licensee.

1 MR. CLARK: Mr. Broughton will make that as well.

2 MR. MOELLER: Fine.

3 (Slide)

4 MR. BROUGHTON: In reviewing the ACRS Subcommittee
5 transcripts, we felt there were two items we should provide
6 additional comment on. Those items are included in the
7 handout. Dr. Moeller's comments this morning included two
8 additional items which I will also address.

9 An item brought up at the subcommittee meeting was
10 the concern of the use of dual meter scale markings to aid
11 the operator in determining saturation conditions in the
12 primary. We have reviewed how we will be providing this
13 information to the operator and what we believe the
14 requirements are. We have tried to summarize those on this
15 slide.

16 Since the TMI-2 accident, saturation margin has
17 now become a basis for operator action. Prior to the TMI-2
18 accident that was not the case. Therefore, since we are
19 requiring an operator to be aware of this and take actions
20 based on it, it is prudent to provide him with a continuous
21 indication of that particular parameter.

22 If the operator needs to look at both temperature
23 and pressure separately to evaluate the saturation margin,
24 there are several problems with that which might preclude
25 him from acting in a timely manner. First of all, that is

1 not a continuous display; that says he chooses to look at it
2 and go through the process of evaluating.

3 There are several steps involved in determining
4 what the saturation margin is. That involves that the
5 operator do more than simply look at a value and understand
6 it, and the whole process is subject to some error under
7 stress, which is the time in which an understanding of what
8 this parameter is is the most important. If the choice were
9 between using steam tables to do this and a dual scale
10 meter, it is probably the dual scale meters that would be
11 the preferable choice. However, we believe the preferred
12 method is the direct reading instrument.

13 At TMI-2 we have two direct reading instruments.
14 One monitors each of the two loops. We have an alarm which
15 would enunciate if the saturation margin reached a
16 predetermined low value, another indication to the operator
17 of what this parameter is. We also calculate saturation
18 margins in the process computer as a backup to the alarms
19 and hardware instrumentation, and in addition we provide a
20 graphic display of temperature and pressure to also allow
21 evaluation.

22 MR. RAY: You say TMI-2. You mean TMI-1.

23 MR. BROUGHTON: I'm sorry. I meant TMI-1.

24 (Slide)

25 MR. PLESSET: You don't have a graphic display

1 that indicates whether you are in the subcooled region or
2 not. In other words, there is a saturation line, and the
3 condition of the plant could either be above or below it.
4 You don't have that. You will have it?

5 MR. BROUGHTON: Yes, we will have a graphic
6 display of pressure versus temperature. It will show the
7 saturation line and the minimum subcooling margin line, and
8 then it will show the plant status with respect to that.

9 MR. PLESSET: Okay. I wanted it clear. Fine.

10 MR. BROUGHTON: The second item which was
11 discussed concerns midscale meter failures. I have broken
12 this up into two pieces because the way in which they are
13 being identified to the operator is dependent upon what the
14 real cause of the meter failure is. First of all, in our
15 control room review we have guidelines which say that if a
16 meter fails, that that failure should be evident to the
17 operator without predefining how to make that evident, so
18 there may be several different acceptable ways to identify
19 to an operator that he has a malfunctioning meter.

20 The concern with midscale meter failures is that
21 if the failure point is near the normal operating point,
22 then it may not be evident to the operator that failure
23 occurred. One of the concerns with the midscale meter
24 failures was evident through the Crystal River 3 event in
25 which the failure of power supplies caused several different

1 key meters to fail in position and provided erroneous
2 information.

3 With regard to how we would be dealing with that,
4 the Crystal River 3 changes that were made to the plant are
5 the type that will identify to the operator that he has had
6 the power supply loss. He will have meters which are
7 powered separately from the lost buss so he can still
8 monitor the plant properly. He now has procedures which
9 tell him which meters to use, given these power supply
10 losses, and those will be meters that are powered and
11 active.

12 And finally, the individual meters will have
13 failure points indicated on them which will show where the
14 meter would fail, and it is also keyed to the power supply
15 to drive the meter. So we feel in the case of power supply
16 losses that that is well covered by the changes we have made
17 to the plant.

18 The individual meter failures -- this could be a
19 failure of either the meter itself or the sensing circuit
20 that would be providing information to the meter. We have
21 two types in use. The first type is the analog meter, which
22 was the real subject of this comment in the control room.
23 In general the analog meters fail at a midpoint on the
24 scale. We will be adding the failure point to those meters
25 so it is evident where the meter failure point is.

1 The second type of meters -- and the bulk of these
2 have been added since the TMI-2 accident -- are digital
3 meters. They would fail dark or off if the meter power was
4 lost, and if the meter power was still available but the
5 sensor was malfunctioning, it would fail to a reading of
6 zero.

7 In looking at the analog meters, most of the
8 failure points, even though they are midscale, do fall out
9 of normal operating, so the operator would be alerted to
10 something abnormal by that meter. And in those cases the
11 marking of the failure points should be adequate to indicate
12 that the meter should be checked for operability.

13 The ones which were of concern are the analog
14 meter failure points which fall in the normal band.

15 We have evaluated those and considered several
16 things. For example, if there are redundant meters to
17 measure that parameter in close proximity to that failed
18 meter, that is a viable method for the operator to use to
19 see if his meter really is functioning or malfunctioning.

20 MR. MOELLER: How does he know which one is
21 working?

22 MR. BROUGHTON: Well, he has, for example, the
23 failure point marked on one. But in the case of one of the
24 redundant ones, an example I have given you is the midscale
25 point on it was 500 pounds, which is the normal setpoint.

1 So from that you can't tell if that meter is working, but
2 the redundant meter was a wider scale meter so its midpoint
3 was 600 pounds. So in that case, if it failed at 900 pounds
4 the other one reads at 900 pounds but not its failure point.

5 MR. CKRENT: Is there only one unique failure
6 point for a meter?

7 MR. BROUGHTON: There is one unique failure point
8 on loss of power for the meter. If there is a malfunction
9 in the sensing circuit somewhere, the failure could be
10 anywhere. But the most common are loss of power related
11 either to the meter or the sensing circuit.

12 MR. OKRENT: I appreciate that, but I am just
13 wondering whether in this discussion about the failure point
14 you have asked yourself are there situations that in fact
15 lead to something else. I don't know whether this is the
16 right one, but maybe before you lose power you have a surge
17 in power, and as I have had a surge in temperature in my car
18 and now the meter that reads temperature in my car no longer
19 sits at zero, the failure -- the operator -- I'm just
20 wondering if you had thought it all through.

21 MR. BROUGHTON: When we say failure points here we
22 specifically mean failure points on loss of power, not out
23 of calibration conditions or malfunctions.

24 Another consideration --

25 MR. KEERR: It is impossible for the sequence

1 described by Dr. Okrent to occur just before a loss of
2 power, for the meter to come back to the failure point even
3 though it had just been up?

4 MR. BROUGHTON: It certainly would be possible for
5 a mechanical meter to bind at any point even if it lost
6 power, but those are very unlikely failures. Normally the
7 meter is designed such that even with surges in the measured
8 parameter it is adequately protected against physical
9 damage.

10 So the use of redundant parameters is one way of
11 providing us information in the case of midscale failure.

12 Another consideration is the length of time
13 required for the operator to identify that he has a failed
14 meter before he gets into some sort of a problem. For
15 example, one of the flow meters in the decay heat removal
16 system may fail near the normal operating point, but that is
17 not one of the primary parameters monitored in that mode,
18 and there are other parameters that would indicate it.

19 The third item we looked at in evaluating this is
20 the fact that we have added these new digital meters for key
21 plant parameters. Even though they were added for a
22 different purpose, those meters are added to aid the
23 operator in manual control, primarily when the plant is shut
24 down, and it is important if there is some meter failure
25 when he is in manual that that is not known; it is less

1 important if he knows about that in automatic.

2 So we look at the key process parameters for which
3 he needs good information. In those cases we now have dual
4 displays and they have different failure modes, and
5 therefore our review concludes that while we still have
6 midscale meter failures, the consequence is not one that we
7 need to be concerned about.

8 MR. MOELLER: What does a digital meter read upon
9 failure?

10 MR. BROUGHTON: The lights would go out on it if
11 it lost power. If the sensing circuit itself failed and
12 there was an opening in the transmitter, it then sees a low
13 range value, which would cause a zero reading on the meter,
14 which is different than a measured zero on the parameter.

15 There were two other items which were mentioned
16 this morning in the summary concerning the auto-manual
17 positions on multiple rotary controls. This is an item
18 which was discovered during the NRC walk-through of our
19 control room, and we had also identified it during our
20 walk-through.

21 The switches in question amounted to four
22 initially, and in further reviewing the way they were marked
23 and what the convention was, it turns out that two of those
24 do meet the auto-manual conventions.

25 The other two which are different from the normal

1 convention are ones which we have addressed in our response
2 to the control room review, and our conclusion was that the
3 probability of error while operating these is very low
4 because of the marking of the switch, the function of the
5 switch, the fact that it is very frequently operated and
6 there is very positive feedback to the operator when he goes
7 to operate the switch.

8 The last item that was mentioned this morning had
9 to do with control of temporary labels, and perhaps our
10 explanation of this during the subcommittee was not clear. 1
11 The concern was that in many control because of inadequate
12 labeling, operators tend to provide temporary labels so that
13 they can understand the function of various indicators and
14 controls.

15 Currently we have had no policy at TMI against
16 such temporary labels. There hasn't been any overall plan
17 for the control room to label. As a result of work we are
18 doing, there will be such a plan. The labeling in the
19 system and in the control room will be controlled just like
20 the other aspects of the plant design are controlled, and
21 there will be a prohibition against temporary labels. If a
22 label needs to be changed, it will be changed on the plant
23 as any other engineering change would be made.

24 These are administrative controls but I think they
25 are adequate in this case, and we don't know of any other

1 approach to take rather than use such administrative
2 approach.

3 MR. MOELLER: Questions or comments on this
4 presentation?

5 MR. OKRENT: I have a related question. Could you
6 remind me? Is the computer capability at TMI-1 similar or
7 better or less capable than that you had at TMI-2?

8 MR. BROUGHTON: The answer is that at the time of
9 restart there will be much greater capability.

10 (Slide)

11 I have got one slide here which is not part of
12 your halldout which indicates what will be available in terms
13 of the computer at the time of restart. There is a new
14 process computer which will be operable which is a state of
15 the art machine which updates the existing computer at the
16 plant, and there will be additional output devices for the
17 operator in terms of both CRT displays and additional video
18 output devices which will greatly increase the capability in
19 getting information from the computer.

20 MR. OKRENT: That is enough.

21 MR. MOELLER: Would the staff comment on the
22 control room and human factors aspects? Do you have any
23 comments?

24 MR. PLESSET: Or on the previous item, the
25 containment setpoint.

1 MR. MOELLER: All right. They had commented
2 earlier on that. Go ahead.,

3 MR. RAMIREZ: Ray Ramirez from the Human Factors
4 Engineering Branch.

5 We have pretty much accepted the proposals that
6 have been given to us by TMI people as an interim corrective
7 actio . We have to be published in the near future
8 NUREG-0700, which will address all of these items for the
9 longer term. What they have done in the interim is make at
10 least as good as some other plants that are operating.

11 MR. KERR: So that there is a possibility that
12 within a couple of years they will have to redo the control
13 room?

14 MR. RAMIREZ: Not the control room entirely, but
15 those items which were discussed during the last half-hour.

16 MR. MOELLER: So you are developing a manual or a
17 guide on this, and you say at the moment they are as good as
18 the other plants. Could they have been better than the
19 other plants? I mean with all the effort they are putting
20 into it, why don't have them be better?

21 MR. RAMIREZ: I guess to make it clear, it would
22 make them better than similar plants operating with similar
23 equipment.

24 MR. MOELLER: They will be better? Okay. That is
25 good to hear.

1 Mr. Kerr.

2 MR. KERR: I have no additional questions.

3 MR. MOELLER: Thank you.

4 Then we will move on to Item J, which is the
5 startup test program, a presentation by the licensee on
6 their objectives.

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. CLARK: Mr. Behrle will make the presentation.

2 MR. BEHRLE: The handout you are receiving is the
3 one I presented to the ACRS Subcommittee on June 26th, and
4 based on the material in that handout, the subcommittee
5 requested I present a discussion on the objectives of the
6 test program and a comparison of low power and natural
7 circulation program with Sequoyah.

8 At TMI we do our test program consistent with
9 testing to verify proper installation modifications,
10 functional testing to verify design adequacy, and integrated
11 testing to verify proper core performance and plant response.

12 The basis for test selection that we used is to
13 consider various programs and requirements. We looked at
14 normal reviewing test requirements, at modifications that
15 were made to the plants.

16 (Slide)

17 We looked at the initial TMI-1 test program. We
18 looked at the natural circulation testing that is being
19 performed in other NTOL plants. We took a look at Reg Guide
20 1.68. We also then considered various aspects of plant
21 re-initialization, operator training, procedure
22 verification, surveillance testing, and we looked at plant
23 transient analysis verification.

24 Some of the key documents that we used to come up
25 with our test requirements are listed on this slide, and

1 they are basically centered around the commitments made in
2 the TMI-1 restart report.

3 (Slide)

4 NUREG-0680, which is the safety evaluation to that
5 restart report, NUREG-0737, the clarification of TMI Action
6 Plan requirements, and then the draft Reg Guide for
7 light-water refueling startup test, which we normally adhere
8 to following a shutdown.

9 (Slide)

10 Our integrated test program consists of hot
11 functional testing where we verify some aspects of
12 modifications at normal operating temperature and pressure
13 prior to taking the reactor critical. It consists of zero
14 power physics testing where we verify core performance at
15 zero power, zero nuclear power. It consists of the low
16 power natural circulation test program that we have employed
17 for operator training, and the power installation test
18 program that we used to verify adequate plant steady state
19 and transient events.

20 In comparison with the Sequoyah program, Sequoyah
21 was initially required to perform ten tests using simulated
22 decay heat, which is basically keeping the reactor critical
23 at about 3 percent power, and then subsequent NTOL plants
24 were required to perform eight of these tests using
25 simulated decay heat, and then one, which was the boron

1 mixing test, was permitted with real decay heat following
2 some period of core exposure.

3 In looking at our program compared to Sequoyah,
4 the first test item is to establish stable, natural
5 circulation. That is included in our program and each shift
6 will participate in or witness a transition to natural
7 circulation.

8 The second item was to establish natural
9 circulation with simulated loss of off-site power. This is
10 not included in the restart program because we did do this
11 verification during the original startup in 1974. We did
12 perform a full-fledged loss of off-site power test.

13 MR. MOELLER: Is that particular item -- you say
14 it has already occurred so there is no need to repeat it,
15 but it seems to me you test both equipment and people. Will
16 your people know how to respond?

17 MR. BEHRLE: That type of situation is one that we
18 do conduct operator training on at the B&W simulator in
19 Lynchburg, so all the operators are exposed to that type
20 training.

21 MR. MOELLER: Go ahead.

22 MR. BEHRLE: And in this case we will need to
23 repeat it for each shift and repeat it a number of times,
24 anyway.

25 MR. CARBON: What is the difference between 1 and

1 2, actually?

2 MR. BEHRLE: You mean item 1 and item 2? In item
3 1 where you establish natural circulation conditions, we
4 trip the reactor coolant pumps and then go to
5 predetermined level, which is 50 percent of the operating
6 range in the steam generator with your emergency feedwater
7 system. And you will see your flow decaying, you will see
8 your hot leg temperature go up probably about 25 or 30
9 degrees, and your cold leg temperature drop to saturation
10 conditions in the secondary side of the steam generator, and
11 the operator will watch and verify this transition from a
12 forced flow situation into natural circulation condition.

13 Now, on a total loss of off-site power, again your
14 reactor coolant pumps would trip but your diesels would come
15 on and load the emergency feed pumps on.

16 MR. CARBON: Fine.

17 MR. BEHRLE: I guess to answer your question, I
18 don't really see that much difference in terms of what
19 really happens in the plant.

20 Item 3 was natural circulation with loss of
21 pressurizer heaters, and we have included that in our
22 program. We will shut off the pressurizer heaters under
23 natural circulation flow and verify that for at least a
24 two-hour time period. We can maintain adequate saturation
25 margin.

1 Item 4 was the effect of secondary side isolation
2 on reactor coolant flow, and although we have not included
3 that in the restart program, that was more or less verified
4 on the B&W nuclear steam supply system during the TMI-2
5 accident.

6 The fifth item is natural circulation flow at
7 reduced reactor coolant system pressure, and we really don't
8 have an auxiliary spray that operates under high pressure
9 conditions. So to determine effects on natural circulation
10 flow and reduce pressure, we just extend item 3 for some
11 period of time until we get the reactor coolant system
12 pressure at about 1800 pounds.

13 Item 6 is the cooldown capability of makeup and
14 letdown systems, and we do have that included in our
15 program. Item 7 is simulated loss of all on-site and
16 off-site AC power. We have part of that item in our
17 program, and the part that we do perform is to verify the
18 independence of the heat sink: in other words, the emergency
19 feedwater system, the independence from AC power. We do not
20 shut off all AC power on the primary side because we want to
21 maintain the reactor coolant pump seals, and this will not
22 cause damage to the seals.

23 (Slide)

24 Item 8 was to establish natural circulation from
25 stagnant conditions, and the NRC has deleted this

1 requirement from all the NTOL plants subsequent to Sequoyah,
2 so it is not in the TMI-1 restart program.

3 Item 9(a) was forced circulation cooldown, and we
4 do incorporate this into our program.

5 Item 9(b) was boron mixing and cooldown, and we
6 have not included boron mixing in the restart program
7 because that was verified on the E&W NSSS following the Unit
8 1 accident.

9 Two additional items were added that were not
10 included in the Sequoyah program. The first of those is to
11 verify plant natural circulation procedures by adequate
12 operator guidance to prevent overcooling as the steam
13 generator level increases from 30 inches to 50 percent in
14 the operating range.

15 The second test is to determine the lowest level
16 in the steam generator that sustains natural circulation
17 without emergency feedwater flow, so the way we do this is
18 to use main feedwater flow to provide a certain inventory of
19 water in the steam generator. We trip the reactor coolant
20 pump and block the emergency feedwater from entering the
21 steam generator and just maintain main feedwater to see how
22 low we can get in the steam generator level and still
23 sustain natural circulation.

24 Are there any questions?

25 MR. MOELLER: Questions for Mr. Behrle on this?

1 Yes, Mr. Shewmon.

2 MR. SHEWMON: I would like to bring up one matter
3 and I am not at all sure you are the one to answer it, but
4 it seems to me about two years ago you were the people to
5 first discover what I would refer to as stagnant line
6 cracking, where you had a splurge of things of that sort.
7 First there was a question of whether you had 100 of them,
8 and then after the NDP procedures got in better shape, it
9 turned out to be only dozens of them or something.

10 Could you tell me where that situation is and what
11 has been done?

12 MR. BEHRLE: I don't believe I can respond to that.

13 MR. CLARK: Mr. Kronberger will respond to that
14 question.

15 MR. SHEWMON: Okay, thank you.

16 MR. CLARK: He is scheduled to make the next
17 presentation. Perhaps he could just incorporate that. You
18 don't see it on the agenda. It is the one we skipped.

19 MR. MOELLER: Is that okay, Paul?

20 MR. SHEWMON: Thank you.

21 MR. MOELLER: Let me quickly ask if the staff had
22 any comments on the startup program.

23 MR. NOVAK: I would like to say we have not
24 completed our review of the licensee's startup program. It
25 is in process and we will be getting together with the

1 licensee in the very near future to discuss the comments
2 that we have.

3 MR. MOELLER: Do you see any real problems in this
4 area?

5 MR. NOVAK: Nothing I think that cannot be
6 resolved, but we do indeed have some questions.

7 MR. MOELLER: Surely.

8 Okay, go ahead with the next presentation.

9 MR. CLARK: The next item, which is the status of
10 some ongoing studies, we ask a little bit of forbearance.
11 Mr. Wilson was going to make that presentation and he got
12 food poisoning last night, and we have tried to put together
13 a presentation by Mr. Kronberger.

14 MR. KRONBERGER: What I would like to do is cover
15 quickly three different areas that were raised during the
16 subcommittee meeting two weeks ago. One was how we are
17 involved in general technical problems from industry's
18 standpoint, specifically what if anything we are doing in
19 the area of hydrogen control and filtered vented
20 containment, and what our activities are in some of the
21 other generic licensing issues.

22 What I would like to do very quickly is discuss
23 how we see the various technical problems being categorized
24 and what our involvement is. Basically we see three general
25 areas of technical problems: those which are industry

1 generic, those which are generic to the B&W 177 size plants,
2 which is TMI-1, and those which apply to TMI-1 as
3 plant-specific problems.

4 (Slide)

5 Organizationally if you take those three
6 categories you have the industry-generic issues which are
7 being handled as industry tasks, which are licensing and
8 regulatory affairs. The degraded core rulemaking would be an
9 example of that.

10 Our other areas of involvement are those which are
11 being worked, whether industry-generic or B&W-specific,
12 through the EPRI activities. Likewise B&W owners group
13 activities following the same two basic types of categories
14 with some examples down here, which isn't intended to be
15 all-inclusive of certain technical issues which are being
16 addressed organizationally through these.

17 And then the other ones, which are GPU tasks which
18 are being handled by our engineering projects group and fall
19 in the categories are shown there.

20 (Slide)

21 First the extent of our involvement, again trying
22 to run through this quickly. This represents GPUN direct
23 membership on the various EPRI and B&W owners group
24 activities. This indicates the numbers of people and in
25 certain cases chairmanship of certain committees which our

1 people are involved with. I show that simply to indicate
2 that we are involved not necessarily more than everyone else
3 but we do have some substantial involvement on those various
4 industry-wide activities.

5 (Slide)

6 Now what I would like to do is jump in this slide
7 -- I'm afraid you don't have it in your handout although the
8 first portion of the slide is on the last page -- to what
9 our activities are on hydrogen control and vented
10 containment. As I am sure you are aware, in TMI-1 we have a
11 large, dry containment which is very analogous to the
12 containment configuration being studied for Zion.

13 So among the various activities that we are
14 involved with we are trying to keep tabs on what is being
15 done on the studies relative to Zion, relative to the
16 studies that were being done by Sol Levy for EPRI, relative
17 to the studies I know that the NRC has been involved more
18 directly with. We do not have any in-house program directly
19 involved on filtered vented containment.

20 We have had some studies on the whole area of
21 hydrogen development, which were touched upon in the
22 subcommittee meeting, and such issues as trying to
23 understand more completely the TMI-2 hydrogen burn episode,
24 trying to understand more about hydrogen mixing, trying to
25 understand more about dry containment capability and

1 capacity. But that is the type of activities we have going
2 on in house. We do not have any major program analogous to
3 the one for Zion.

4 As far as some of the other general areas that
5 were touched upon at the last subcommittee meeting, we did
6 address how we were proceeding on a general problem such as
7 the block wall issue.

8 On the seismic interaction question. We indicated
9 last time that we were not specifically proceeding for TMI-1
10 at this time on reevaluating the acceptability of the
11 original design as far as seismic interaction, and at that
12 time it was indicated that this was being done for Diablo
13 Canyon. Basically what our posture is, although we
14 recognize this is an issue to address, recognizing that we
15 are in a relatively low seismic area at TMI-1, we consider
16 it to be a problem although not necessarily the highest
17 priority problem to address right now.

18 As far as containment flooding, we may have given
19 the wrong impression as to what we have done on the problem
20 that did crop up at Indian Point Unit 2. We did thoroughly
21 evaluate our design vis-a-vis the Indian Point situation.
22 There are some major differences on our plant as contrasted
23 with Indian Point. We have no raw river lines. We only
24 have one raw river line which enters the containment, and
25 that is only actuated when we have an ES signal, and we are

1 worrying about post-accident air cooling.

2 So we have raw water going to the containment for
3 post-accident cooling, but that is the only one. We have
4 studied deeply other flooding problems outside containment
5 as it relates to river water lines. We have thoroughly
6 studied flooding in containment as a result of our
7 experience in TMI-2 as it involves such issues as the
8 7901(d) environmental qualification of equipment, so I do
9 think that in the area of flooding we have done more.

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. OKRENT: With regard to what is sometimes
2 called internally induced flooding, have you looked at the
3 rest of your plant, meaning what is not in containment, to
4 see whether there are important functions which are
5 vulnerable to flooding of this kind, and whether such
6 flooding is physically possible from breaks in equipment?
7 And if so, has there been some kind of evaluation of the
8 chance of a serious accident being caused via this mechanism?

9 MR. CRONEBERGER: If I could, I'll just try to
10 describe the various types of things we have looked at. As
11 a result of the work we did on high energy line breaks, the
12 concern about potential flooding was very thoroughly
13 analyzed and we satisfied ourselves that we didn't have any
14 detrimental effects associated with those lines.

15 We have, as a result of the Indian Point issue,
16 investigated where we have river water lines entering the
17 auxiliary structures, and have concluded that essentially
18 the only area where those lines entered the building, which
19 is an isolated heat exchanger vault, that we have very
20 substantial floodable volume which represents what the most
21 severe -- the highest flow rate line, in fact, should break
22 approximately 30 minutes for operation action to terminate
23 those services.

24 We have looked at large tanks such as -- .

25 MR. OKRENT: Is that the cooling water? The main

1 cooling water?

2 MR. CRONEBERGER: No, it's a number of cooling
3 water services which are the open cycle cooling water
4 services for decay heat removal, nuclear services cooling,
5 secondary services lines.

6 MR. OKRENT: How about condenser cooling?

7 MR. CRONEBERGER: That had been looked at before
8 as a separate issue which is a possible flooding problem in
9 the turbine building. The turbine building in TMI-1 --
10 there is provision for basically, the turbine building
11 essentially discharge the water out.

12 MR. OKRENT: Are you telling me, then, that there
13 is no way that internally-caused flooding could lead to a
14 serious accident? What is it you're telling me?

15 MR. CRONEBERGER: I'm trying to say that as far as
16 what might be major volumes of water which could enter the
17 plant, these have been looked at in the past. I cannot say
18 that in fact we've done a detailed investigation of the
19 plant and identified all the water sources for the plant and
20 assured ourselves that in fact there is no problem. We've
21 looked at what we consider to be the worst cases.

22 MR. OKRENT: Well, on one plant that was looked at
23 via some research study, it turned out there was one drum
24 where there was a lot of electrical supplies centralized,
25 and it would have been very awkward to have it flooded. And

1 in fact, it turned out there were at least physically
2 possible mechanisms for doing this. So I don't know whether
3 you have that situation or not, but -- well, a different
4 question.

5 Earlier, there was a brief discussion by Mr.
6 Keaton concerning plants doing a reliability study on TMI-1
7 in the coming months or years. Was it contemplated that
8 this study would encompass a look at whether there were
9 safety improvements that met some kind of a cost-benefit
10 effectiveness criterion to see whether, in fact, there might
11 be some things worthwhile doing on TMI-1?

12 MR. KEATON: Yes, we would try to pick up that
13 type of thing. And I meant to imply that in saying that we
14 would address external hazards which would include things
15 like flooding. And we would expect to look, for example,
16 for the type of thing where there was one area in a plant
17 where, because of all the different types of equipment that
18 are there, that it was a particularly vulnerable area.

19 MR. OKRENT: My question was quite general.
20 Flooding would only be one aspect that one might consider.
21 I don't want to pursue it now.

22 MR. KEATON: I think, though, that our general
23 answer is that as part of the study we do intend to look for
24 risks associated with the common location of equipment, in
25 addition to just looking at random failures.

1 MR. MOELLER: Any other questions for Mr.
2 Croneberger?

3 MR. SHEWMON: He hasn't gotten to the last point
4 yet. Let me ask a question to bring it up. It seems to me
5 one of the more distressing things about Indian Point was
6 the fact that pipes ran for a lot longer than 30 minutes
7 before anybody thought it was worth going inside to look.
8 And I would be interested in having you reassure me by
9 telling me what procedures you have instituted to make sure
10 that water won't run into the sump for a day or two
11 unbothered or molested.

12 MR. CRONEBERGER: Are you referring to the Indian
13 Point situation of water inside the containment? We have
14 installed now both the new sump level detection systems plus
15 the building level indication and alarms. So within the
16 plant as modified, the operator should be getting indication
17 which I believe was not available to the Indian Point
18 operators.

19 MR. SHEWMON: As I understand, they had some
20 indicators like that but the operators knew they didn't work
21 or weren't reliable anyway, so they just ignored them when
22 they alarmed.

23 MR. CLARK: We would like Mr. Ross from the plant
24 operations staff to address how they would respond.

25 MR. ROSS: In addition to the changed parts of

1 increased instrumentation Mr. Croneberger talked about, we
2 have reviewed in detail this incident with all operators.
3 We have changed some operating procedures to initiate such
4 things as checks of sump level indicators on a weekly basis
5 to make sure the operators have faith in them.

6 MR. SHEWMON: If they didn't work, then what
7 happens?

8 MR. ROSS: At that time, we increase our
9 surveillance time and take action to get something done with
10 it. We recognize the importance of that sump.

11 In addition to training, I would say our increased
12 surveillance is a major item, and operator awareness.

13 MR. SHEWMON: Okay. Now let's go back to the last
14 item.

15 MR. CRONEBERGER: You're talking about pipe
16 cracking?

17 MR. SHEWMON: Yes.

18 MR. CRONEBERGER: As a result of improved UT
19 standards that were used, the amount of indications which
20 were identified as inter-granular stress corrosion was
21 substantially reduced from what the first identified number
22 was. To my knowledge, we have now completely repaired all
23 of the indications which we have identified as requiring
24 that.

25 MR. SHEWMON: So you have no particular idea of

1 why you had this spate of things, but you are sure you have
2 replaced all the things, so hopefully it won't come back for
3 a couple of years, with luck. Is that it?

4 MR. CRONEBERGER: We have entered into an
5 agreement with EPRI on some testing of the system which had
6 most of the indications, which was one of the spent fuel
7 cooling systems. I'm really not prepared technically to
8 address what that testing program is.

9 There is some instrumentaton installed; I am just
10 not sufficiently aware of the nature of what that program is.

11 MR. SHEWMON: My impression is that there were
12 sensitized welds which I guess meet specs in these
13 non-safety grade systems. But there was also more active
14 corrosion in those than most other plants had. And I
15 appreciate the fact that you don't know. My impression is
16 no one else did; at least, the last time I asked about this
17 so I was curious.

18 MR. CRONEBERGER: The major number of indications
19 occurred in one of the redundant spent fuel cooling lines
20 which happened to be stagnant since the plant went into
21 service. One of the outcomes of such an evaluation
22 obviously, were there, in fact, systems to initiate a
23 practice to move the water through that system periodically,
24 which is being addressed.

25 MR. MOELLER: Does that complete your presentation?

1 MR. CRONEBERGER: Yes, sir.

2 MR. MOELLER: Thank you. Are there any other
3 questions for Mr. Croneberger? If there are none, why don't
4 we ask the licensee if there are any additional remarks or
5 comments that you have at this time.

6 MR. CLARK: No.

7 MR. MOELLER: Then could we ask the staff to sort
8 of give us a summary statement on where you stand with
9 respect to the TMI-1 restart?

10 MR. NOVAK: As the committee knows, we have
11 summarized our review in a series of SER's, NUREG-0680 and
12 its supplements and a variety of others, which I didn't
13 present to the subcommittee at that time. There are still
14 some matters outstanding; among them, the startup test
15 review which I mentioned a little while ago and several
16 other relatively minor matters which will be resolved prior
17 to restart.

18 For the information of the committee, the
19 evidentiary hearing has concluded yesterday I believe, in
20 fact, and that process is, of course, continuing in proposed
21 findings and presumably, in September, at least that's the
22 current schedule, a recommendation or an initial decision by
23 the Board to the Commission is to establish a general
24 schedule for future events.

25 I don't think we have any further comments on

1 specific items discussed here today, but of course, we are
2 prepared to answer any further questions the committee may
3 have.

4 MR. MOELLER: Are there any additional questions
5 for the staff? Max Carbon?

6 MR. CARBON: I'd like to go back to the emergency
7 preparedness discussion for just a moment. In an emergency,
8 is there anyplace where the NRC resident inspector is now
9 permitted to go? Is he limited in his movement?

10 MR. ARNOLD: I think I could answer from us that
11 there is no area that he would be restricted from because of
12 him being an NRC employee. He can go in the control room or
13 wherever he wishes, and that is, in fact, where we would
14 expect him to be. The only restriction would be those that
15 apply from the radiological controls program.

16 MR. CARBON: Thank you.

17 MR. MOELLER: Any other questions? There being
18 none, Mr. Chairman, I think that concludes the items that
19 the full committee had on the agenda to review at this time,
20 and the remaining item is to poll the committee in terms of
21 their thoughts on this particular implication.

22 MR. MARK: Are you making a proposal that a letter
23 should be prepared on this?

24 MR. MOELLER: I would propose that the committee
25 consider writing a letter. Of course, it will contain a

1 number of items that we would want to comment on, so what we
2 would need to know from the members would be, one, do they
3 agree that we are in a position to attempt to write a
4 letter; and secondly, if they agree to that, what should we
5 cover in the letter, what are the key items that we should
6 mention.

7 MR. MARK: Is there an opinion that we are not
8 prepared or should not attempt to compose the letter on the
9 restart? Plus, I think it depends a little bit on what the
10 letter say.

11 MR. MOELLER: Certainly.

12 MR. PLESSET: And I guess that's obvious, and
13 depending on what the letter says I may have some additional
14 comments along the lines that I mentioned in the opening
15 statement.

16 MR. MARK: It sounds as if the letter could be
17 undertaken. There will be a fair number of items on which
18 comments will be called for. Perhaps including -- .

19 MR. PLESSET: My additional comments might be
20 entirely unnecessary.

21 MR. MOELLER: Right. Certainly, we request from
22 Mr. Plesset his thoughts, and we will first attempt to put
23 them in the letter itself, and where we are unable to do so,
24 then he is certainly free to add them as remarks.

25 MR. KERR: And if they are entirely unnecessary we

1 will try to dissuade him.

2 (Laughter.)

3 MR. MARK: I guess that's as far as we can take
4 this at the moment. In spite of the fact that we're all
5 starving to death, I believe we should ask Mr. Tedesco, who
6 has come to address us an hour ago, to tell us a little bit
7 about the staff's picture of the future program. That may
8 not take very long.

9 MR. KERR: You wouldn't consider a five-minute
10 break?

11 (Laughter.)

12 MR. MARK: I would like to thank the delegation
13 from TMI who has given us a pretty good picture.

14 MR. ARNOLD: We thank the committee very much for
15 the opportunity to meet before you.

16 (Slide.)

17 MR. TEDESCO: What we wanted to do was share with
18 the committee where we are on the SER's that we had talked
19 about last month. And this is a very brief summary on the
20 five plants, Susquehanna, Shoreham, Waterford, and Comanche
21 Peak.

22 What we have here is the date that we contemplate
23 issuance. Now you have Susquehanna, with 40. Shoreham,
24 because of a large number of open items that we and the
25 applicant have decided to defer issuing the SER. Waterford

1 should be down to you today, and Comanche Peak we will issue
2 next week. However, there are also a large number of items
3 on that.

4 Fermi should be out today, and that has about 23
5 items. But just to give you a very brief overview of the
6 statements on this SER --.

7 MR. KERR: What is meant by 25 (staff position 3)?

8 MR. TEDESCO: Here are a number of open issues
9 that we have identified in our SER. These are the ones that
10 presently exist in the SER; 14 on Susquehanna, 41 on
11 Shoreham, 25, 42 and 23. Here is an expectation that by the
12 time the August ACRS comes around, we will have reduced this
13 14 by 7. That's an expectation that we would have. And
14 here, in addition to open items, there are positions that we
15 have taken in the SER on a number of items.

16 That gives you kind of an overview. There are two
17 positions here, and that would give you an analysis of the
18 contents of the SER.

19 (Slide.)

20 What we have decided to do is make a
21 recommendation to the committee as follows: that with regard
22 to the SER's that we have published, we would request that
23 the committee consider at its August meeting Waterford,
24 Fermi, Susquehanna, and we've decided to defer Shoreham and
25 Comanche Peak reviews until we are in a position to more

1 precisely close out the open items that we have identified.

2 MR. SHEWMON: Would it be warping your position
3 too much if you said there were around two dozen or fewer
4 issues at this point in time and you think they will clear
5 up by next month? And if there is over three dozen, you are
6 unwilling to project that?

7 MR. TEDESCO: I wouldn't want to make that a hard
8 rule, but if you felt that way -- .

9 MR. KEPR: Well, unless I misinterpret these, he's
10 anticipating 23 open items at the time of the August meeting
11 for Fermi-2. Am I misinterpreting that number -- 21?

12 MR. TEDESCO: Fermi would come out to be something
13 like 21. Actually, Fermi-2 now has 22 items.

14 MR. SHEWMON: No, he says there's 22 now and he
15 thinks there will be on the order of 2 next month.

16 MR. TEDESCO: No. Two of them will be reduced by
17 next month.

18 MR. SHEWMON: Oh. Thank you.

19 MR. MARK: That's the number that will get covered.

20 MR. SHEWMON. The last column, just out of
21 curiosity, means what?

22 MR. TEDESCO: Those are positions we have taken.
23 In other words, we have resolved an issue by showing this
24 requirement. This is our requirement.

25 MR. PLESSET: So this is not on the list anymore?

1 MR. TEDESCO: No, sir.

2 MR. SIESS: You stopped arguing?

3 MR. TEDESCO: Yes, sir.

4 MR. PLESSET: So those could be taken out, too?

5 Oh, those are already out.

6 MR. TEDESCO: So that's the picture we would

7 present to you for next month.

8 Now, there's also one other item. This afternoon
9 you will be hearing the story about Pilgrim, which is the
10 first construction permit application to come to the
11 committee in some time. The information you will receive is
12 based primarily on the TMI requirements that have been
13 established.

14 Next month, it would be our plan, if the committee
15 so desires, to also present Allens Creek. Now, the
16 committee may feel that perhaps it is not necessary to go
17 through all these issues with all the plants because we
18 would really feel, from the feedback, whether or not you
19 want to continue to see CP's after they have their review.

20 Basically, Allens Creek would be very much like
21 Pilgrim except Allens Creek is a boiler, and perhaps the
22 most unique thing there is the size of containment. We have
23 gone through dialogue before with the committee on the
24 requirements, so we're going to leave it to you on how you'd
25 like to handle it; whether or not you want to continue to

1 see the CP's.

2 MR. KERR: While the committee is deciding that
3 question, can you tell me why there are going to be 20 or so
4 open items on Fermi when we are considering it? That still
5 strikes me as being a fairly large number.

6 MR. TEDESCO: Ideally, we would all like to see
7 zero, but we are working very hard on these reviews.

8 MR. KERR: Well, even non-ideally, I'd like to see
9 about five or so.

10 MR. SIESS: This number game bothers me. Are all
11 the items equally significant, equally important? Maybe you
12 can answer that in two parts. One, are they equally
13 important to you, and do you think they are equally
14 important to us.

15 MR. TEDESCO: There are a number of items that are
16 common to all these plants that are in the long-term review,
17 like equipment qualification, fire protection, emergency
18 preparedness, some on the control room design, some on
19 emergency operating procedures just by virtue of the nature
20 of review. The plants for construction have not gone far
21 enough for us to -- in other words, you still may have them
22 in the control room panel. We just can't really say it's
23 all finished.

24 MR. SIESS: Some of those are things that there's
25 no argument about? You just haven't had a chance to know

1 what they're doing, but you suspect that they will be done
2 and you expect that you will see that they are done.

3 MR. TEDESCO: Yes, sir, before licensing.

4 MR. SIESS: Some of those would stay open right
5 down to the hearing stage, wouldn't they?

6 MR. TEDESCO: And they may indeed become license
7 conditions and we may say look, before you go above fuel
8 loading or criticality, you must do this.

9 MR. SIESS: So what would be the chances on, let's
10 take something like Fermi, and take Dr. Kerr's criterion
11 that he would like to see five. How long do you think we
12 might have to wait until you got it down to five?

13 MR. TEDESCO: Okay, I can tell you on that, we
14 have asked the applicant when he would be able to provide us
15 the necessary information that we would need to write off on
16 these residual items, and as far as Fermi goes 9 of them
17 should start to come into us around August 1st, and then the
18 balance of them start to come in next year.

19 MR. SIESS: Want to wait that long, Bill?

20 MR. TEDESCO: No, they haven't started going
21 through the hearing, but this is the type of review going on.

22 MR. KERR: Well, this is sort of a committee
23 decision. I don't know -- .

24 MR. SHEWMON: These are coming in because they are
25 contested and we know there are going to be hearings, is

1 that right?

2 MR. TEDESCO: Yes, sir, and we're minimizing the
3 impact on the availability.

4 MR. SHEWMON: I appreciate the political pressure
5 for that. What criteria have you used to say yes, I think
6 these are far enough along so that things will be revised.
7 Or, sorry, everything will be accommodated by the time the
8 hearing is over, which I presume is something you have
9 approximated.

10 MR. TEDESCO: We have to satisfy all these issues
11 to satisfy the regulations.

12 MR. SHEWMON: The question is what criteria have
13 you used to say these are now ready to move on?

14 MR. TEDESCO: These have been 96 or 97% reviewed
15 with that point. When you say the SER today, you're talking
16 about 800 pages of material that represents a rather
17 significant amount of review effort on our part. And the
18 items I'm identifying here are not going to be doubling
19 that. There will be a number of items of a residual nature,
20 and we're confident that we can handle them, that we have
21 enough experience on these matters to deal with them.

22 MR. KERR: And the Fermi SER will be available
23 tomorrow?

24 MR. TEDESCO: I got it last night, it went into
25 final correction typing this morning. It should be run off

1 either late this afternoon or tomorrow you should have it.

2 MR. SIESS: Bob, you've been in this business a
3 long time. I've got a suspicion that we are seeing SER's
4 now with lists of open items that three or four years ago we
5 would never have seen listed as open items. Is that right?

6 MR. TEDESCO: Yes, you are. You're also seeing --
7 I have experienced a much greater depth of review; depth and
8 breadth, than we have seen in the past. The items after TMI
9 have opened up.

10 MR. SIESS: I'm saying what we used to be
11 concerned about, what I would call open controversial items
12 where there was still considerable discussion going on
13 between the staff and the applicant with questions as to how
14 and whether they were going to get resolved. But now we are
15 getting these long lists of things that are just not yet
16 resolved, although there is every expectation they will be.
17 And we have written letters in the past and said we expect
18 it to be resolved in a manner satisfactory to the regulatory
19 staff. And I suspect there were items never called to our
20 attention because you didn't write SER's that way.

21 So I think we need to keep our perspective on what
22 we're doing when we review and maybe write a letter or on 23
23 "open" issues. I don't think it's any departure.

24 MR. MARK: I think it would really meet your point
25 and help us size this up a little better if one knew of

1 those 23 whether there are 18 of them that are just not
2 ready for discussion but there is no debate or any expecta-
3 tion that there will be a difference of opinion by the time
4 the last documents are written.

5 MR. KERR: Bob, is there anybody in the review
6 process who looks at the questions that go out to an
7 applicant to see if some of them are patently ridiculous and
8 ought to be squelched? Or does anybody who thinks he has a
9 question in the review process get to send it out to an
10 applicant?

11 MR. TEDESCO: We try to screen the questions as
12 much as we are able to. It's an imperfect system but we do
13 try to do that.

14 MR. KERR: But there is some effort?

15 MR. TEDESCO: Yes.

16 MR. KERR: Some of the questions I have been
17 seeing lately have just influenced me to ask that, because
18 at least from my limited perspective, I couldn't see why
19 some of them were being asked.

20 MR. TEDESCO: We are trying to present to the
21 committee on the reports that we see -- you will notice that
22 we have cut Shoreham, realizing that there were too many
23 open items to deal with it.

24 MR. SHEWMON: Would you try to go back to follow
25 up on Mr. Siess's question and rank these with regard to

1 those that you feel are controversial and how many of them
2 still involve an active argument, or whatever words you want
3 to use to paraphrase what he was saying?

4 MR. TEDESCO: All of them will involve discussions
5 with the applicants. None of them will come out clean
6 because there is a lot of subjective judgment how and when
7 to demonstrate qualifications.

8 Fire protection is another. Fire barriers,
9 sprinkler system and manual versus automatic; you're bound
10 to get involved in discussions that are not necessarily of
11 complete agreement initially.

12 Emergency preparedness -- we are involved with
13 FEMA now. That adds another dimension to our whole review.
14 The I&E bulletin, 79 bulletin, dealing with the consequences
15 of failure, control room design, staffing and management.
16 In many instances we are dealing with new organizations who
17 have not even gone into the whole context of providing an
18 adequate operating staff. They are very subjective issues
19 that we're dealing with.

20 MR. SIESC: Mr. Chairman, one thing I guess that's
21 bothering me is the emphasis on the open items in almost a
22 legalistic fashion. I suspect that there are many items
23 that are closed items already reviewed by the staff that we
24 probably ought to devote as much attention to or more in an
25 ACRS review as there are open items. Just because an item

1 is closed it doesn't mean that the ACRS doesn't need to look
2 at it.

3 So the emphasis on the open items I think is
4 obscuring what we should do.

5 MR. KERR: I would say on the contrary, I want the
6 items to be closed so we will look at all of them equally,
7 because we don't look at the open items at all, in a sense,
8 because we don't know what position the staff is going to
9 take on them. It's that that causes me concern.

10 MR. SIESS: In the previous review -- I don't know
11 what we're doing now because we haven't done one in a
12 while. We used to focus a fair amount of attention on open
13 items so we know what to say about them later.

14 MR. KERR: We don't know what the staff's position
15 is going to be on them.

16 MR. BENDER: I think it makes a difference whether
17 we're reviewing the plant at the construction of the
18 operating stage. I think a construction license in general
19 tended to focus on the things as to what was going to be
20 designed into the plant, and we started out at the construc-
21 tion permit stage.

22 At the operating stage it seems to me that what's
23 important is to be sure we have an understanding that the
24 operational commitments of the licensee are sorted out. And
25 I think we need a pattern. I believe that's what the real

1 problem is right now; that each one of these guys is coming
2 in and trying to establish his own precedent and we don't
3 have any pattern of agreement to work from. And I think
4 that's why we can't get them all through at one time.

5 Once an issue has been resolved for one guy,
6 everybody knows that well, the staff has now established its
7 position and they'll all conform to it, because what one
8 agrees to, they all have to agree to.

9 But it's going to take a while to get these first
10 two or three through the mill, and then I think the others
11 will move much faster.

12 I don't know when the fire protection system will
13 get sorted out. The lawyers will take care of that. But
14 some of the others will get sorted out.

15 MR. MARK: What's your pleasure?

16 MR. OKRENT: My pleasure is lunch.

17 (Laughter.)

18 MR. SHEWMON: Why don't we go ahead and try to
19 take them unless one of the subcommittee chairmen feels
20 strongly that we shouldn't?

21 MR. PLESSET: I agree.

22 MR. MARK: I agree.

23 MR. OKRENT: Does that mean a three-day meeting
24 instead of a four-day meeting?

25 MR. SIESS: That's what I want decided.

1 MR. TEDESCO: We'd also appreciate your comments.

2 MR. PLESSET: Let me ask about that. Is that the
3 Allen's Creek containment question or more than that?

4 MR. TEDESCO: It's the first boiler for a CP and
5 they're obligated to provide a hydrogen control system.

6 MR. PLESSET: So it's more than a Mark III contain-
7 ment.

8 MR. OKRENT: It's more than the question of loads
9 and blowdowns.

10 MR. PLESSET: We're going to have to hear it
11 sometimes because there are some others down the line.

12 MR. TEDESCO: We will be issuing an SER on Allen's
13 Creek within the next few days, so that might be another
14 item for your agenda.

15 MR. OKRENT: Has the Commission adopted a role in
16 the NTCP business?

17 MR. TEDESCO: No. They have Revision 1 to
18 represent the staff requirements.

19 MR. OKRENT: And it's like what you represented to
20 the Commission?

21 MR. TEDESCO: Yes, sir.

22 MR. MARK: Well, I would suggest that we adjourn
23 until five after 2:00.

24 (Whereupon, at 1:05 p.m. the meeting recessed for
25 lunch, to reconvene at 2:05 p.m. the same day.)

1 MR. MARK: Let's reconvene.

2 MR. BENDER: As has been discussed previously at
3 this meeting, the committee has been asked to evaluate
4 whether it wants to write out a separate report on the
5 Pilgrim Unit 2 Construction Permit, which the committee
6 reported on sometime ago, in November of 1975 and October of
7 1977.

8 Since that time, of course, the TMI II accident
9 occurred, and as a result of that accident the staff has
10 generated some new requirements for construction permits,
11 and they are outlined in NUREG-0718 Revision 1.

12 The subcommittee, consisting of Jerry Ray and
13 myself, met with the applicant here in Washington on July 8,
14 and at that time we heard a preview of what is being planned
15 in response to the NUREG and post-TMI requirements. I think
16 Jerry and I were favorably impressed by the plans for
17 Pilgrim 2. On the off-chance that the committee might find
18 it desirable to write a report, Dave Bessette, who was the
19 Designated Federal Employee at the subcommittee meeting,
20 prepared a draft statement which the committee might want to
21 look at and decide whether it wants to act upon it.

22 The applicant and the staff are here to make a
23 presentation. What I can say about the post-accident
24 actions is that they have resulted in the Pilgrim 2
25 organization beefing its quality assurance capability

1 somewhat. Its organizational plan as previously established
2 was in conformance with what the staff was expecting
3 already. It is instituting a PRA program. It has responded
4 to a number of review requirements concerning TMI II types
5 of accidents.

6 I think you will learn more by the presentation
7 that has been planned by the staff and the applicant. So I
8 suggest that we begin right away with that part of the
9 presentation.

10 MS. ADENSAM: Gentlemen, and the staff and the
11 applicant, as the chairman has indicated, met with the
12 Pilgrim 2 Subcommittee on July 8 to discuss the TMI related
13 requirements for the Pilgrim 2 construction permit
14 application. During our introduction, the staff really
15 outlined how we had been handling the near term construction
16 permit and manufacturing license review of TMI related
17 requirements. The subcommittee asked that we briefly
18 address this review approach to the full committee.

19 On March 30th, 1981, Mr. Denton established a near
20 term construction and manufacturing license dedicated review
21 team to review the applicants' responses to TMI related
22 requirements, published it for comment in the Federal
23 Register as a proposed rule on March 23rd, 1981, along the
24 organizational lines shown here in the first vugraph.

25 I would like to point out that the dedicated

1 review team did include members from I&E, and the Emergency
2 Preparedness staff. They remained in their respective
3 branches, where they had access to total branch expertise,
4 and the usual technical and management review of their
5 work.

6 The team's first assignment was to develop
7 detailed criteria for their review of applicants' responses
8 to the requirements of the proposed rule. Most of these
9 were presented to the applicant at a meeting on April 8,
10 1981.

11 The review schedule that is being used is shown
12 here. The meetings in the third week are extremely
13 intensive, and to work require a total cooperative
14 commitment from the applicant as well as the staff. The
15 applicant made available not only technical expertise, but
16 individuals empowered to speak for the utility, and to sign
17 written commitments to amend the PSAR.

18 We are happy to report today that there has been
19 excellent cooperation on both sides, and few issues have had
20 to be resolved after the SSER input was provided to the
21 Division of Licensing.

22 We are currently into our third review with the
23 dedicated review team. We are going to be issuing the
24 Allens Creed SER supplement. Technical review is expected
25 to be completed on the floating nuclear plant application by

1 mid-July, with the supplement to be issued about a month
2 later.

3 As you see from this vugraph, we can keep the
4 dedicated team busy through August. If Black Fox does not
5 insist on deferring their submittal until November 3, and
6 submits earlier, we should be able to use those services up
7 to October.

8 The dedicated review team is also committed to
9 review issues related to their hearing efforts, otherwise it
10 will probably be disbanded by the end of the year or
11 earlier, if they are not needed for TMI reviews.

12 The subcommittee also asked that the staff address
13 the following question on the applicant's organizational
14 changes. One word is important and the change was the new
15 organization that the staff wants to see.

16 Mr. Dominic Vassalo, Chief of the Licensee
17 Qualifications, will address these questions.

18 MR. VASSALO: In response, the first question was,
19 were there any important changes from the previous
20 organizational plan? The only important change that we are
21 aware of was in the area of nuclear operations. Previously
22 they had one organization. They have now split that into
23 Nuclear Operations, and Nuclear Operations Support, but that
24 is primarily concerned with the operational activities.
25 Other than that, there were no other organizational

1 changes.

2 We reviewed this previously, and as a matter of
3 fact, it was a contention in the hearing, and we had
4 previously prepared testimony on it. The same vice
5 president is in charge. The same project manager for the
6 Pilgrim 2 Project. So we have not seen any drastic
7 changes. I think they have had some staff changes, but the
8 organization is appropriate for this activity.

9 Primarily because they have a nuclear oriented
10 organization, that is the organization with a high level
11 manager responsible solely for nuclear activities. As a
12 matter of fact, Pilgrim did this early on, I guess, in 1975
13 and 1976, when we reviewed it. I might say that they were
14 very early because now, in reviewing operating licenses and
15 other construction permit applications, we look to that as
16 being right type of organization.

17 In other words, that there be an organization
18 which is responsible and dedicated to nuclear activities,
19 and not diluted by having other responsibilities. So,
20 therefore, we think this is the organization that is
21 appropriate and will be capable of undertaking the design
22 and construction activities.

23 MR. BENDER: Thank you.

24 Ms. Adensam, do you have anything further?

25 MS. ADENSAM: We had not planned any other

1 presentation.

2 MR. BENDER: If not, why don't we proceed with the
3 applicant's presentation.

4 MR. BUTLER: I am Robert Butler, the Pilgrim 2
5 Project Manager for Boston Edison. I have been in this
6 capacity since projection inception in 1972. We are pleased
7 to appear before ACRS today.

8 This slide shows that the subcommittee has
9 requested that we briefly present information on the more
10 important topics shown on the vugraph, which were contained
11 in our PSAR amendment, and address the NTCP requirements,
12 which has now been reviewed by the staff. We plan to follow
13 this agenda.

14 May I have the next slide please?

15 A brief history and current status of the project
16 is shown on this vugraph. The major points to focus on are
17 the CP licensing process, which has been underway since
18 December 1973, the advanced status of design and equipment
19 deliveries, and the post-TMI licensing progress with a date
20 in 1981.

21 The Atomic Safety and Licensing Board's partial
22 initial decision of February of this year identified TMI
23 requirements and emergency planning as the only remaining
24 issues for Pilgrim 2. It is Boston Edison's desire to
25 proceed expeditiously to now obtain ACRS concurrence, and

1 proceed with final hearings.

2 Boston Edison and our contractors are currently
3 evaluating the schedule and cost for Pilgrim 2. Key factors
4 in the evaluation include the impact on schedule and cost of
5 changes resulting from the TMI requirements and recent
6 industry experience.

7 The major uncertainty in the schedule for issuance
8 of a construction permit is the lack of a final rule on TMI
9 regulated requirements, and the uncertain effects this could
10 have on the duration of the Pilgrim 2 hearings, and
11 subsequent adjudicatory actions.

12 However, we anticipate the earlier schedule for
13 issuance of a CP is the spring of 1982. Beyond that,
14 typically nuclear construction durations are running between
15 six and eight years.

16 I have with me today members of the Boston Edison
17 nuclear organization, as well as nuclear engineering staff,
18 as well as our contractors, Bechtel and Combustion
19 Engineering.

20 On organization, the subcommittee has requested
21 that this presentation be brief since our current
22 organization, as Mr. Vassalo said, has essentially been in
23 place since 1975, and has been presented to ACRS
24 previously.

25 Boston Edison has established a separate nuclear

1 organization reporting at the executive level to the Vice
2 President Nuclear. The organization has responsibility for
3 the company's nuclear activities, which include operation of
4 Pilgrim 1 and the Pilgrim 2 Project.

5 Within the organization, I as the Pilgrim 2
6 Project manager have the full time management responsibility
7 for Pilgrim 2 design, licensing, procurement, and
8 construction. As seen on the vugraph, other Boston Edison
9 organizational elements, QA, Nuclear Engineering, and
10 Nuclear Operations Support, report independently to the Vice
11 President and provide services to both Pilgrim 1 and Pilgrim
12 2. Nuclear Operations is responsible now for Pilgrim 1
13 operations, and later for Pilgrim 2 operations.

14 Prior to the start of construction, the nuclear
15 organization has maintained an in-house staff equivalent of
16 about 20 full-time engineers and managers on Pilgrim 2
17 work. Consultants have been and continue to be utilized to
18 supplement the Boston Edison staff.

19 Currently the nuclear organization in support of
20 Pilgrim 1 and 2 has about 100 personnel on the management
21 and technical staff, having an average level of nuclear
22 experience of about eight years. This does not include 41
23 currently approved help requisitions, indicating growth in
24 this organization.

25 MR. KERR: What fraction of the nuclear experience

1 came from employment with Boston Edison?

2 MR. BUTLER: What percentage?

3 MR. KERR: Yes, or what fraction, roughly, half of
4 it, two-thirds, 20 percent?

5 MR. BUTLER: I would guess between 25 and 50
6 percent.

7 MR. KERR: Thank you.

8 MR. BUTLER: During the construction, the nuclear
9 organization staff on Pilgrim 2 is estimated to increase
10 from approximately 39 to 244. The vugraph indicates the
11 breakdown of this complement.

The next slide, please.

12 The division of responsibility of Boston Edison,
13 Bechtel, CE, and GE is defined in contractual and procedural
14 documents. Boston Edison is responsible for the overall
15 design and construction operations of Pilgrim 2, including
16 conformance to regulatory requirements.

17 Boston Edison's nuclear organizational meets these
18 responsibilities by providing management oversight to
19 principal contractor activities, obtaining Federal licenses
20 and permits, approving basic design criteria, releasing
21 selected design documents, and authorizing the expenditure
22 of funds.

23 Combustion Engineering is responsible for design
24 and fabrication of the nuclear steam supply system. General
25

1 Electric is responsible for the design and fabrication of
2 the turbine/generator. Fitting between these, Bechtel is
3 responsible for the balance of plant, including engineering,
4 procurement, construction, and QA/QC for their scope.

5 Additionally, Bechtel is responsible for design
6 interface control among Bechtel, CE, and GE, and between
7 Bechtel and its subcontractors.

8 Boston Edison manages and evaluates the
9 performance of its contractors by review and approval of
10 design criteria, design and procurement documents prior to
11 purchase or construction. All these activities are
12 performed under written procedural control and periodic
13 audit.

14 MR. KERR: Excuse me, but is there anything that
15 has changed relative to that slide as a result of TMI-II?

16 MR. BUTLER: Not directly as a result of TMI-II.

17 MR. KERR: I am not looking for changes if they
18 are not there.

19 MR. BUTLER: No, there are none.

20 The Quality Assurance Manager reports directly to
21 the Vice President-Nuclear, and with his staff is
22 responsible for establishing and maintaining adequate QA
23 controls. Construction oversight of contractor performance
24 will provided by the Pilgrim 2 Project staff and the
25 construction QA group.

1 The Project Construction Manager will report to
2 the Pilgrim 2 Project Manager. Boston Edison QA provides
3 construction oversight to the construction QA group which is
4 responsible for monitoring the QA aspects of sight
5 construction. The construction QA group will interact
6 directly with the principal contractors' sight organization
7 and with Boston Edison home office QA organization.

8 Boston Edison QA staffing on Pilgrim 2 is
9 estimated to increase from four at the start of construction
10 to a peak of nine. Bechtel on-sight planned staffing levels
11 are 56 in the QC group and six in the QA group at the peak
12 of construction. These estimated staffing levels will be
13 continuously reviewed to insure adequate project coverage.

14 Procedures for construction management and control
15 will be approved for use prior to the start of each
16 construction activity.

17 Since project inception, operations oriented
18 personnel have been utilized to review design. Nuclear
19 Operations Support provides this function.

20 An important operations aspect is the feedback of
21 industry operating experience which was covered in some
22 detail at the subcommittee meeting.

23 Boston Edison's single nuclear organization will
24 greatly facilitate the transition from construction to
25 Pilgrim 2 operation by maintaining continuity of personnel

1 in the development of operating procedures, review of test
2 results, training, and technical support.

3 Engineering and management personnel involved in
4 the design and construction phases will be encouraged to
5 transfer to available positions in operations or in support
6 of operations.

7 Plant pre-operation and start-up testing will be
8 accomplished by an integrated start-up organization of
9 Edison, Bechtel and CE personnel, to be managed by Boston
10 Edison.

11 The Boston Edison Executive Office exercises top
12 level management oversight by approval of operating budgets,
13 capital authorizations, periodic project status reviews,
14 including quarterly QA status reports, and reports of the
15 quality assurance review committee, a committee of QA
16 project operations and engineering personnel to determine
17 the adequacy of the QA program and its implementation.

18 Further executive oversight will include setting
19 policy for future activities, and participating in Pilgrim 2
20 executive review meetings on approximately a semi-annual
21 basis. Executive review meetings are attended also by top
22 level management of the principal contractors, enabling the
23 executives of all three companies to be periodically
24 informed of project planning, status, and problems.

25 This concludes my presentation on organization and

1 management. Are there any questions?

2 MR. WARD: Would you show that again? Where did
3 you say the operations review committee fits in?

4 MR. BUTLER: The quality assurance review
5 committee?

6 MR. WARD: Okay, the quality assurance review
7 committee.

8 MR. BUTLER: The quality assurance review
9 committee is a committee chaired by the Quality Assurance
10 Manager, but with representatives of the QA organizations
11 reporting to him, representatives of the project reporting
12 to me, representatives of engineering reporting to the
13 engineering manager, and representatives of Operations
14 Support. So it is a committee which has multi-discipline
15 and organizational orientation.

16 MR. WARD: It reports to the Vice President?

17 MR. BUTLER: That reports to actually to the Vice
18 President and to myself. They provide their reports for us
19 as management advisory reports. We are not members of that
20 committee.

21 MR. BENDER: Are there further questions?

22 (No response.)

23 MR. BENDER: Why don't we go to Mr. Ashkar. Thank
24 you, Mr. Butler.

25 MR. BUTLER: The next speaker is Mr. Ashkar of the

1 Nuclear Engineering Department, who is responsible for PRA.
2 Mr. Ashkar will also cover briefly ATWS.

3 MR. ASHKAR: My name is Jim Ashkar, and I am with
4 the Nuclear Engineering Department. I am responsible for
5 the PRA Program.

6 Boston Edison will perform a plant/site specific
7 probabilistic risk assessment, and submit a PRA report to
8 the NRC delineating the results within two years after the
9 CP. The PRA report will present the site/plant specific
10 risks in terms of probability of frequency curves for
11 various health effects for both the base plant design
12 submitted in the PSAR, and for the revised design as
13 modified by the PRA Program.

14 Boston Edison will utilize intermediate products
15 from the PRA to allow early identification and investigation
16 of potential improvements in order to facilitate
17 coordination with construction schedules.

18 From the following slides, I will cover the
19 program objectives, organization, program flow, the program
20 elements, and the PRA Report.

21 MR. MOELLER: Can you tell us who is doing this,
22 are you doing it in-house, or a certain contractor?

23 MR. ASHKAR: I have a slide for that area.

24 The objectives of our PRA Program are to seek
25 design improvements in systems affecting the reliability of

1 accomplishing core and containment heat removal which, (1)
2 contribute to significant risk reduction, (2) represent
3 practical applications of demonstrated engineering
4 technology, and (3) do not excessively impact on the plant
5 construction, start-up schedule, or upon plant cost.

6 MR. KERR: Mr. Ashkar, what are you going to
7 reduce? What significant risk reduction compared to what?

8 MR. ASHKAR: What we intend to do is to look at
9 our base plant design as it is described in the PSAR as a
10 basis, and look at improvements that we may incorporate
11 compared to our base plant design.

12 MR. KERR: How do you decide how much improvement
13 you need?

14 MR. ASHKAR: What we will be using are other
15 reports, industry standards, and guidelines that are
16 available to us to facilitate our judgment in making those
17 improvements.

18 MR. KERR: I don't know of any industry standard
19 that tells you how much risk is acceptable.

20 MR. ASHKAR: That's right. I meant other reports
21 that have been made, other probabilistic risk assessments to
22 determine how risk is for operating plants currently, and
23 other guidelines, such as the ACRS Safety Code. AIF has
24 similar documents, and I think EPRI has similar documents
25 also, although they are far from final.

1 MR. KERR: Thank you.

2 MR. ASHKAR: Secondly, we would seek to quantify
3 the merit of design improvements that we would incorporate.
4 The PRA Program, like other project programs, will be
5 managed by Boston Edison Company. PRA activities will be
6 performed and reviewed by engineers who are experienced and
7 highly qualified in risk assessment methodology. Boston
8 Edison, Bechtel, and CE resources will be supplemented by
9 consulting organizations in this regard.

10 Design alternatives will be developed by Engineers
11 in the qualified design groups presently responsible for
12 design, primarily at Bechtel and Combustion Engineering.

13 High level independent review of the entire PRA
14 program will be performed by separate senior level oversight
15 groups. The design decisions will be made by the current
16 project management team, who will have the added benefit of
17 risk quantification provided by the PRA Program.

18 The next slide summarizes major activities of our
19 PRA Program and show the interrelationships. Results of
20 other PRA programs will be used to identify issues which
21 have the potential to compromise the expected reliability of
22 core and containment heat removal systems. We will develop
23 practical resolutions to those issues.

24 For issue resolutions requiring design or other
25 modifications, alternative modifications will be developed,

1 including alternate core and containment heat removal system
2 designs.

3 We will use the results of generic safety studies
4 and PRA studies of other plants in conjunction with
5 operating experience feedback to establish a revised
6 design.

7 The plant/site risk assessment will be performed
8 on the revised design, and will include an expression of
9 risk reduction over the base plant design as documented
10 currently in the PSAR.

11 MR. KERR: When you refer to the base plant, I
12 think you say it is the one described in your PSAR.

13 MR. ASHKAR: That is right.

14 MR. KERR: So it was a plant that was designed X
15 years ago, where X is equal to what?

16 MR. ASHKAR: Up to 1974, 1975.

17 MR. KERR: And you have concluded that the risk
18 associated with the operation of that plant is too great,
19 and that it needs to be reduced?

20 MR. ASHKAR: I don't know that we have come to
21 that conclusion since we have not conducted a risk study on
22 the base plant. We think that by doing a risk evaluation,
23 we may be able to identify areas for improvement.

24 MR. KERR: I guess we will learn as your program
25 develops how you decide what improvements are needed.

1 MR. ASHKAR: The next slide shows our PRA Program
2 plan and schedule, and the establishment of our organization
3 responsibilities and management control. The schedule will
4 reflect use of intermediate PRA results coordinated with the
5 construction schedule. This will insure that the beneficial
6 changes resulting from intermediate PRA products can be
7 implemented early in construction, without an excessive
8 impact on project cost.

9 In my next slide I will address the key elements
10 of our plant/site risk assessment, which will feed back as
11 intermediate products in the design process. In general,
12 the approach taken will reflect contemporary methodologies.

13 In the preliminary analysis, we will assure
14 completeness of scope of initiating events by developing a
15 master logic tree to identify the range and nature of
16 initiating events, which could lead to unacceptable
17 consequences. We will also select the most significant
18 primary and support systems for further analysis at this
19 time.

20 Next, in developing plant event sequences, we will
21 consider system responses and interactions during allowable
22 plant operating modes. For example, failure during cold
23 shutdown operation will be considered an initiating event of
24 our study. We will establish a plant specific data base
25 covering component failure rates, test and maintenance data,

1 and the frequency of initiating events.

2 Because we will not have detailed designs
3 available, we will necessarily need to make design
4 assumptions, and select appropriate corresponding component
5 failure characteristic data. We will subsequently verify
6 agreement between the final design and these design
7 assumptions. These verifications will insure that the
8 assumptions in developing the data base and used in the
9 analysis are consistent with the final design.

10 This documentation step will also contribute to
11 configuration and control, and in turn provide reliable
12 information for developing surveillance and the maintenance
13 program.

14 In the analysis of external caused failure, we
15 will estimate the frequency and consequences of significant
16 failures, which are externally initiated by earthquakes,
17 fires, and the like.

18 In the analysis of system failures, we will
19 compare key system fault trees and event trees, which will
20 reveal intra-system and inter-system failure mechanisms.
21 This will not be limited to primary safety systems, but will
22 include support systems as well.

23 Based on operating experience feedback and other
24 PRA results, we know that problems in the support system may
25 also result in common cause failures. These potential

1 problems would be revealed through key system fault trees
2 and event trees, and related analysis. Problems identified
3 would be intermediate products fed back into the design
4 process.

5 We will also assess how human interaction and the
6 environmental conditions affect the availability of
7 systems. This will be done utilizing the best available
8 technologies consistent with contemporary PRA methods.
9 Environmental effects will include radiation, and other
10 adverse environmental conditions, especially for those
11 components that must be operable for long period of time,
12 and maybe inaccessible for maintenance under accident
13 conditions.

14 The uncertainty in input data used in quantifying
15 plant event sequences and other analyses will be carried
16 through the analyses and expressed as part of the final
17 results. By establishing the basis for the uncertainty, we
18 will determine how the uncertainty affects the final results
19 and document this in the PRA report.

20 MR. KERR: I am trying to understand how these
21 generalizations, which sound reasonable, are going to be
22 applied to your specific plant. For example, are you going
23 to include the containment system in this study?

24 MR. ASHKAR: What we hope to do, as I mentioned
25 earlier, is to review other PRA reports that are

1 particularly applicable to our plant type, and identify
2 systems and assumptions procedures that we feel those
3 results would indicate may be beneficial.

4 MR. KERR: Let me take you through a couple of
5 examples. Suppose you look at your containment system, and
6 decide that by doing something or other to it you can reduce
7 the risk by a certain amount. You have to make a decision
8 on the containment, I assume, fairly early on if it is going
9 to be built into the system. On the other hand, maybe you
10 can do something to some other part of the system which is
11 pretty far down the line, and would reduce the risk a lot
12 more.

13 How do you decide whether to make the change in
14 the containment, which you have now looked at, or wait and
15 look at something else, or are you going to improve
16 everything?

17 MR. ASHKAR: In each case, when we are considering
18 an alternative that may reduce risk, we will also develop
19 cost information.

20 MR. KERR: But you have to do some of the studies
21 first. It seems to me the containment one has to be done
22 and completed fairly soon, otherwise you can't start
23 construction.

24 MR. ASHKAR: Right.

25 MR. KERR: Indeed, I think you might start

1 construction before you finish the total study, the total
2 PRA study.

3 MR. ASHKAR: That is correct.

4 MR. KERR: How are you going to know whether it
5 would be better to improve the containment or to improve
6 something else? What sort of decision process are you going
7 to use? I am trying to understand the decision process that
8 you are going to use.

9 MR. ASHKAR: In addition to the decision process,
10 we are scheduled to do the PRA activities within the
11 intended construction schedule. The way we have at this
12 point planned to conduct the PRA would be to first utilize
13 the benefits of other studies that are available
14 immediately.

15 Secondly, it would be to go through and identify
16 outliers, which we are going to discuss, very early in our
17 program, and get through the event sequence analysis as
18 early as we can to try and identify the issues we are
19 talking about.

20 We think that in the first few months of the study
21 we can get to that phase, and give substantial clarity to
22 the rest of the process.

23 MR. KERR: I don't understand how you are going to
24 make your decision, but perhaps I will understand better
25 after you get to the end of the process.

1 MR. ASHKAR: To continue, outliers indentified in
2 the plant and containment event sequence analysis phases
3 will be intermediate products fed back into the design
4 process. When outliers have been dispositioned, we will
5 develop a list of critical items which delineate the
6 relative importance of components to reliability of core and
7 containment cooling.

8 The results of the PRA study will contribute --

9 MR. KERR: How does one identify an outlier?

10 MR. ASHKAR: What we have tried to do at this
11 point would be to quantify event sequence frequencies, and
12 compare those with other reports that are expected for those
13 frequencies to see how some event sequences are particularly
14 unusual.

15 The results of the PRA study will contribute to
16 defining importance to safety as required by 10 CFR 50
17 Appendix B, criteria 2. At this point, those multiple
18 failure sequences which should be considered in the control
19 room design review will also be identified.

20 MR. WARD: Jim, do you expect that that critical
21 items list is going to correlate with what you call your Q
22 list? Is it going to be the same as the Q list, do you
23 think?

24 MR. ASHKAR: We expect that it will be a larger
25 list, and better guidance not only in safety systems, but in

1 other typical non-safety systems.

2 MR. WARD: So you are looking for -- When you say,
3 identify outliers, for example, you are looking at things
4 not only the safety items, but reliability items.

5 MR. ASHKAR: The balance of plant, things that
6 would contribute to initiating events.

7 MR. WARD: But just from the safety standpoint, or
8 any economic standpoint?

9 MR. ASHKAR: In the scope of the study, we are
10 only going to be looking at safety issues, event sequences
11 that would lead to unacceptable off-site doses.

12 MR. RAY: I think that it would be clearer for us
13 if you defined what an outlier is. What do you consider an
14 outlier?

15 MR. ASHKAR: What I would consider an outlier is
16 the frequency for an event sequence, frequency of occurrence
17 which is unusually high compared to those we expect from
18 other studies, such as WASH-1400, Indian Point, etc. I
19 think we are beginning to see some level of convergence with
20 respect to frequencies of some of these events, something on
21 the order of a half order of magnitude, or an order of
22 magnitude different would be something that would raise a
23 red flag to me, anyway.

24 MR. RAY: Something that is so significant and
25 important, has such widespread effect that it warrants early

1 attention, and possibly action, and that kind of thing?

2 MR. ASHKAR: Yes.

3 MR. RAY: The criticality you are talking about is
4 not so much, the way I interpret your remarks, and I could
5 be corrected if I am wrong, not so much with respect to
6 operation of a plant, so much as reducing the risk that is
7 inherently built into the plant.

8 MR. ASHKAR: Correct.

9 The next slide please.

10 The PRA report will be prepared documenting the
11 PRA activities, including methods used, important
12 assumptions to be verified, data sources, typical analyses,
13 and treatment of uncertainty. It will include results such
14 as expected core melt frequencies, containment failure
15 frequencies, both of which we used to identify outliers,
16 identification of those dominant sequences contributing to
17 risk, and risk curves for both the base plant design, that
18 is the PSAR design, and the revised design that we will
19 ultimately end up with.

20 The relative contribution of individual design
21 improvements of core and containment heat removal
22 reliability will also be presented in the report at that
23 time.

24 Our report will describe applications of the PRA
25 results which are planned in subsequent phases of the

1 project, such as development of a preventative maintenance
2 program, development of surveillance testing programs, and
3 the development of emergency procedures, and operator
4 training.

5 MR. WARD: Do you know about what this program is
6 going to cost?

7 MR. ASHKAR: I know what others have cost,
8 somewhere between one and two million dollars, closer to two
9 I would say.

10 MR. SHEWMON: You have said earlier, and I missed
11 it, you were asked who was going to conduct this, and I
12 missed the answer.

13 MR. ASHKAR: What we have already initiated is a
14 project team made up of representatives from our prime
15 contractors, Bechtel and Combustion Engineering. Also we
16 will solicit the aid of a risk contractor consultant to
17 provide the preparation of the detailed plans and procedures
18 for control, and will also do major portions of the
19 reliability and quantification phases. Boston Edison will
20 also be involved in program guidance, direction, and
21 control, and also will provide operations review input. Our
22 approach will be a team approach, utilizing a variety of
23 contractors.

24 MR. SHEWMON: Could you tell me how or whether
25 your system might respond to or include possibilities of

1 in-house sabotage or fire?

2 MR. ASHKAR: We are planning to utilize the
3 available technologies for including fire analysis. We have
4 not well developed this part, or our approach to sabotage
5 with regard to PRA. That is the best answer I can give you
6 at this point.

7 MR. SHEWMON: Are there well developed
8 technologies that you gone into for treating fires?

9 MR. BENDER: There are methods. There are areas
10 that are a threat, and how they might involve safety. I
11 don't know that it has been done probabilistically, but I
12 don't see any reason why it couldn't.

13 MR. ASHKAR: There are some techniques that we
14 have investigated, and they are not well developed or
15 sophisticated, but they are approaches. We will try to get
16 a handle on sabotage.

17 MR. SHEWMON: I guess in both of those you are
18 likely to end up with physical distribution of flames, and I
19 don't know whether that comes into PRA at this point or
20 not. That is part of my question.

21 MR. BENDER: I think it would be unfair to ask Mr.
22 Ashkar to be too explicit on how he is going to do this
23 thing. The plan is not all that well developed.

24 MR. ASHKAR: I have a brief statement that I would
25 like to make with regard to ATWS. Even though this is not a

1 particularly post-TMI issue, I would like to bring you up to
2 date on where we stand and our intention to include
3 treatment in the PRA program.

4 Pilgrim 2 probabilistic risk assessment program
5 will include anticipated transients without scram events.
6 Boston Edison and its principal contractors have been
7 actively participating in various activities related to
8 ATWS.

9 Although ATWS was not a design basis event for
10 Pilgrim 2, the Pilgrim 2 has been included among the designs
11 considered in the generic ATWS analysis performed by
12 Combustion Engineering, and on behalf of NSSS owners
13 groups. These analyses demonstrated the capability of the
14 existing program to designs to mitigate the consequences of
15 an ATWS event.

16 Boston Edison is involved in, and closely follows
17 the rulemaking process for the resolution of the ATWS
18 issue. The Pilgrim 2 does not preclude future incorporation
19 of any of the ATWS plant modifications which have been
20 addressed thus far in the various proposed rules for ATWS
21 resolution.

22 This concludes my presentation.

23 MR. KERR: Have your efforts or considerations had
24 any influence on the pressure relieving capability of your
25 primary system?

1 MR. ASHKAR: The generic studies that have been
2 done by Combustion, which we reviewed, would indicate that
3 some advantage would be provided by the addition of
4 relieving capability to the system. We have not
5 incorporated it in our PRA program as we initiated it.

6 MR. KERR: You will incorporate into your plant
7 additional pressure relieving capability?

8 MR. ASHKAR: We have not conducted our PRA program
9 and made conclusions with regard to that yet.

10 MR. BENDER: As I understood from our previous
11 conversation, the plant design does not preclude the use of
12 additional relief valves. You have not made a decision yet
13 on whether they are needed, and you are waiting for the PRA
14 study to do that.

15 MR. ASHKAR: That is right.

16 MR. KERR: I think you would make a considerable
17 contribution to the industry, because the ACRS tried to do
18 that a long time ago and failed. So I am looking eagerly
19 forward to your results.

20 MR. BENDER: Can we move to the next subject?

21 MR. BUTLER: The next speaker is Mr. Ron Jagels,
22 the Bechtel Project Engineer, who will cover the topics of
23 hydrogen control and degraded core rulemaking activities.

24 MR. JAGELS: I am Ron Jagels, the Bechtel Project
25 Engineering for Pilgrim 2.

1 This afternoon, I will discuss the agenda items
2 dealing with hydrogen control, and degraded core
3 rulemaking.

4 The Pilgrim 2 containment is a pre-stressed,
5 closed-tension, steel-lined, concrete structure with a free
6 volume of approximately 2.5 million cubic feet. The Pilgrim
7 2 design will satisfy the requirements for degraded core
8 hydrogen prescribed in NUREG-0718, and summarized on this
9 slide.

10 First, a hydrogen control system will be provided
11 which is capable of handling hydrogen generated by the
12 equivalent of 100 percent fuel clad metal water reaction.
13 The containment and associated systems will provide
14 reasonable assurance that uniformly distributed hydrogen
15 concentration will not exceed 10 percent.

16 The existing containment design exceeds the
17 requirement of a minimum containment design pressure of 45
18 pounds gauge.

19 Pilgrim has performed analyses on the containment
20 pressure effects due to hydrogen. Results of these analyses
21 were presented to Dr. Okrent's subcommittee in February of
22 this year, and we have recently revised and updated these
23 analyses to include the effects of the distributed ignition
24 system.

25 The more analyses used flammability data which

1 account for steam dilution effects, and also take credit for
2 containment heat sinks, such as structural steel, and the
3 steel liner. The analyses also assume that one containment
4 spray train was available for containment heat removal.

5 The results of the analyses based on these
6 previous assumptions show that for an initial hydrogen
7 concentration of 10 percent, the peak containment pressure
8 is less than 69 pounds, the containment test pressure, and
9 also that the containment liner temperature will not exceed
10 the design value.

11 Pilgrim 2 has also committed in PSAR Amendment 43
12 to incorporate the results of industry and NRC research and
13 testing into the final selection and design of a hydrogen
14 control system.

15 Additional analyses will also be conducted which
16 will include a consideration of various accident scenarios
17 that have different steam and hydrogen release rates.

18 Within two years after issuance of the
19 construction permit, Pilgrim will submit to the NRC for
20 review the design details of the hydrogen control system
21 that has been selected.

22 In summary, Pilgrim 2 has a large, dry containment
23 that has considerable margin to withstand accidents that
24 generate large quantities of hydrogen. The preliminary
25 analyses show that the containment pressure from the

1 degraded core hydrogen can be controlled to less than the
2 test pressure of 69 pounds.

3 Are there any questions on hydrogen control?

4 (No response.)

5 MR. BENDER: Why don't you go on to the next
6 agenda item.

7 MR. JAGELS: The next agenda item is the degraded
8 core rulemaking activities.

9 The Pilgrim 2 has been monitoring and
10 participating in the degraded core rulemaking activities.
11 We believe that these are generic rulemakings and should not
12 be litigated in individual proceedings. At the conclusion
13 of the rulemaking activities, the Pilgrim 2 project will be
14 subject and will comply with the outcome of the rulemaking.

15 The resolution of these rulemakings is not
16 imminent, and it is likely that it will be several years
17 before they are resolved. Pilgrim 2 has made commitments,
18 and we have planned activities which we feel will
19 significantly reduce the potential effect of these
20 rulemakings on the project.

21 First, as I have just described, we have committed
22 to install a hydrogen control system capable of handling 100
23 percent of the fuel clad metal water reaction. This
24 requirement is more stringent than the 75 percent metal
25 water reaction included in the interim rule on hydrogen.

1 We have committed to the installation of a
2 three-foot diameter spare containment penetration which
3 could be used for a containment filter vent system, if the
4 requirement to install such a vent is the outcome of the
5 rulemaking.

6 A plant specific risk assessment will be
7 performed. This objectives of this assessment include
8 seeking design improvements in both the core and containment
9 heat removal systems.

10 In addition, the project will continue to monitor
11 and participate in the on-going rulemaking activities.

12 The effect of these commitments, we feel, will
13 increase the likelihood that the Pilgrim 2 design can
14 accommodate the outcome of the degraded core rulemaking.

15 MR. KERR: Mr. Jagels, when you refer to a 100
16 percent metal water reaction, is the metal to which you
17 refer just the cladding?

18 MR. JAGELS: That is correct.

19 MR. OKRENT: As a point of information, the
20 containment as it is currently designed can take what
21 negative pressure?

22 MR. JAGELS: I do not recall that from my memory,
23 Dr. Okrent. I have the figure with me in the PSAR.

24 MR. BENDER: Can you get somewhere within a few
25 pounds of it?

1 MR. OKRENT: We will take a full vacuum.

2 MR. BENDER: Will take a full vacuum, or a half.

3 MR. OKRENT: We will take 14.7 p.s.i.

4 MR. JAGELS: I prefer checking it, if I might
5 furnish it later.

6 MR. BENDER: Why don't you do that, and we will
7 move on.

8 MR. BUTLER: The next speaker is Mr. George
9 McHugh, Boston Edison Project Engineer, who will take the
10 topic of the control room design approach.

11 MR. McHUGH: My name is George McHugh, Boston
12 Edison Project Engineer responsible for balance of plant
13 activities, which include the development of the control
14 design.

15 Our approach to control room design has changed
16 substantially since the accident at Three Mile Island. I
17 intend to advise you today of our current status, explain
18 our pre-TMI work, and our current approach as outlined in
19 Amendment 43.

20 First, our current status. We have not yet
21 fabricated or purchased our main control boards. In fact,
22 in Amendment 43 we have committed to provide control board
23 layouts for NRC staff review prior to fabrication or
24 revision from the board.

25 We are currently formulating the details of our

1 program, which will involve state-of-the-art analytical
2 techniques, the application of accepted human factor
3 principles, and the use of mock-ups to verify the
4 effectiveness of the layouts, using operations oriented
5 analyses.

6 My next slide outlines the work we did before the
7 accident at Three Mile Island. We did develop a preliminary
8 control room design, including preliminary control board
9 layouts, well prior to the TMI II accident.

10 The design was developed and reviewed by personnel
11 who were involved in our then state-of-the-art safety
12 sequence analysis, which identified information and devices
13 required in the main control room to respond to the
14 transient and accident conditions analyzed.

15 The results of the safety sequence analysis was
16 documented on Safety Sequence Diagrams, SSDs. Even though
17 it was a specific objective of the SSD program to identify
18 control room inventory, the analysis did impact the design.

19 Starting with Bechtel-CE proposed control board
20 layouts, a preliminary allocation for function, indications,
21 enunciations, and controls was established based on a review
22 of the operation of plant systems.

23 Using P and ID, preliminary system descriptions,
24 and control logic diagrams, this review was performed with
25 operations personnel who had actual PWR operating

1 experience, and we used human factors guidelines available
2 at that time, 1976-1977 such as Dr. Allen Swain's Zion work
3 in 1975, and the EPRI-Lockheed study in 1976. Although
4 there was no direct use of a human factors consultant, we
5 did use available guidelines.

6 This resulted in a preliminary control board
7 layout based on an operating cost to be formulated during
8 the design process.

9 Our pre-TMI effort provided valuable insight into
10 the development of our post-TMI approach. In other words,
11 we were able to focus more sharply on TMI experience. Since
12 TMI, we have collected enough information to recognize the
13 need for an improved approach, and are formulating the
14 details of our program.

15 As outlined in Amendment 43, our program calls
16 for an update of the safety sequence analysis to reflect
17 changes in design since 1973, advances in design
18 development, use of the latest SSG methodology, and analysis
19 of the more comprehensive scope of initiating events.

20 This analysis will establish the inventory of
21 information required in the control room to respond to
22 transients and accident conditions analyzed. As stated
23 earlier today, our PRA Program will provide a master logic
24 tree to establish the scope of events requiring analysis.
25 The PRA will also be used to determine the multiple failures

1 that must be considered in the control room information
2 format for inventory.

3 Even more important than the quantity of
4 information required is the manner, configuration and format
5 in which it is presented. In that regard, our program calls
6 for developing a new preliminary design based on the direct
7 input of human factors principles and data, which I will
8 discuss in a minute in more detail on the next slide.

9 Once the new preliminary design is developed, we
10 will conduct an operations oriented analysis to determine
11 operational efficiency.

12 The design process which results will of necessity
13 be iterative, and will involve a team approach in program
14 development analysis, revised design development and review,
15 involving individuals experienced in operations, systems
16 analysis, human factors engineering, architectural
17 engineering, and control room design.

18 The results of our program will be submitted to
19 the NRC staff prior to fabrication of the main control
20 boards, and the plant specific simulator.

21 My final slide shows the program flow I have just
22 described. I have highlighted on the left the human factors
23 input, which we intend to obtain from expert consultants,
24 and have also separated analytical tasks from the design
25 flow shown on the right.

1 Shown on the left is the direct human factors
2 input in three phases. First, in the initial program
3 establishment, including early control and design, and
4 planning activities. Human factors input to the program
5 establishment will improve development of two types of
6 guidelines:

7 (a) guidelines to perform activities in
8 subsequent phases, for example, functional allocation
9 analysis, analysis of operator tasks versus capability, and
10 how to determine the information required for assigned
11 tasks;

12 (b) design guidelines which will include
13 development of color, lighting and acoustical environmental
14 design criteria, criteria for information display, hardwires
15 versus CRT displays, the board profile establishment, and a
16 preliminary control room configuration plan.

17 The next phase involves the safety sequence
18 analysis with PRA input, and the human factors guidance
19 functional analysis.

20 Human factors input will also be obtained in the
21 identification, selection, and arrangement of the
22 indications, enunciations, and control on the main control
23 boards to accomplish the functions allocated. This will
24 accomplished through a risk analysis at the major subsystem
25 level to allocate areas in the overall layout, without

1 addressing hardware.

2 Hardware selection will be made considering the
3 human machine interface. Enunciation philosophy will define
4 the use of hardwires versus CRT displays. The resulting new
5 preliminary design will be reviewed against the
6 configuration plan resulting in preliminary control board
7 layout.

8 In preparation for the next phase, human factors
9 criteria for operational procedure will be developed.
10 Draft procedures will be written, and control room work
11 stations will be designed.

12 Finally, operational sequence diagrams will be
13 prepared for tasks to be analyzed in phase three.

14 The third phase will involve details reviews of
15 specific groupings of devices as the operations oriented
16 analysis proceeds using full-scale mock-ups. This analysis
17 will be performed by individuals experienced in systems
18 analysis, operations, human factors engineering, and control
19 room designs.

20 The output will be a finalized set of main control
21 board layouts and a report, both of which will be submitted
22 to the NRC staff for review. Following staff review, we
23 will fabricate both the main control boards and the plant
24 specific simulator.

25 It is our overall intent to obtain a

1 state-of-the-art control room which will assure that ability
2 of the control room operations personnel to prevent
3 anticipated transients from developing into accidents, and
4 to cope with accidents should they occur.

5 Are there any questions?

6 MR. BENDER: Are there any questions?

7 MR. WARD: George, you said that in the part of
8 the analysis you are going to have operations people take
9 part in that. Are those people who would be in the Pilgrim
10 organization, or have experience there? Who are those
11 people?

12 MR. McHUGH: As Mr. Butler said, we have the
13 Nuclear Operations organization responsible for the
14 operation of Pilgrim 1, and there is a Nuclear Operations
15 Support Department, which supports both Pilgrim 1 and
16 Pilgrim 2, and includes seasoned operators with the PWRs and
17 the BWRs experience. We will be drawing on them, and
18 additional consultants from other utilities as necessary to
19 meet our judgment of what is adequate experience base.

20 MR. BENDER: Are there other questions.

21 (No response.)

22 MR. BENDER: Thank you, Mr. McHugh.

23 Let's go to the last two items.

24 MR. BUTLER: The last speaker we have is Mr. David
25 Bryant, the Boston Edison Project Engineer, who will cover

1 the topics on inadequate core cooling instrumentation, and
2 safety/relief valve testing.

3 MR. BRYANT: Ladies, and gentlemen, as Mr. Butler
4 said, I am David Bryant, and I am the Project Engineer at
5 Boston Edison for the NSSS.

6 With respect to the instrumentation to detect
7 inadequate core cooling, the commitment we have made has two
8 key elements.

9 First, we will install a primary coolant
10 saturation meter. This type of device is being installed in
11 operating plants and provides a continuous read-out of the
12 margins of saturation conditions.

13 Second, we are going to perform a study to
14 determine what additional instrumentations will be included
15 in the Pilgrim 2 to detect inadequate core cooling. This
16 type will include both reactor water level instruments and
17 core exit thermal-couples. We have committed not to
18 preclude either of these devices from the design.

19 We will submit the results of our study to NRC
20 after prototype testing, and before we procure the hardware
21 for Pilgrim 2.

22 I might add that the operating plants and the
23 near-term operating license applicants are installing such
24 systems, and I expect that we will have feedback from actual
25 operating experience from these systems before we have to

1 install the hardware in Pilgrim 2.

2 This is all I intended to say on this subject.

3 Are there any questions?

4 MR. BENDER: Go ahead.

5 MR. BRYANT: The testing of primary safety valves
6 and relief valves, and design of the piping and support.

7 Go to the next slide.

8 The next slides summarizes the commitments made by
9 Pilgrim 2 in the PSAR. First Pilgrim 2 will implement the
10 results of the testing being performed on behalf of the
11 industry by the Electric Power Research Institute, EPRI.

12 Just for clarity, when I say relief valves, I mean
13 power operated relief valves, PORVs.

14 Also Pilgrim 2 will design the discharge piping
15 and the supports for these valves for the loads from the
16 design basis transients, and accidents.

17 These commitments meet the NRC's requirements in
18 NUREG-0718.

19 The next slide please.

20 This slide summarizes the program being run by
21 EPRI. First, it is designed to comply with NUREG-0737,
22 which is the task action plan for the operating plants and
23 near-term operating license applicants. The program
24 involves testing 10 PORVs and nine safety valves. It
25 happens that the specific PORV and safety valve being

1 supplied by Combustion for Pilgrim 2 are included in the
2 test program.

3 The program is designed to envelope the operating
4 conditions on all the plants that are represented by the
5 program. Testing is currently underway and the final output
6 of the program is scheduled for July of 1982.

7 The block valve portion of the program is still
8 under development. Testing has not begun on block valves.

9 The next slide.

10 This is an EPRI slide that summarizes the major
11 outputs from the valve test program. First, there will be
12 reports on each of the valve tests which are being done at
13 three facilities. The tests will demonstrate the valve's
14 performance under the design basis conditions.

15 Second, there will be a report to document the
16 selection of which valve were tested, and adjusted by the
17 applicability of the test results to all the various
18 plants.

19 Third, reports will be provided to substantiate
20 the test conditions and to show how these conditions
21 envelope the various plants.

22 These reports will also deal with the effects of
23 as-built piping. In the case of Pilgrim 2, of course, our
24 piping exists only on paper, so that we can redesign our
25 piping, if necessary, to utilize the conclusions from the

1 tests.

2 Fourth, there will be a report documenting the
3 recommended computer programs to calculate the hydro-dynamic
4 loads used for design of piping and supports under the
5 design basis conditions. This code is expected to be
6 suitable for use on new projects such as Pilgrim 2.

7 Thus, the EPRI valve test program is expected to
8 provide us all that we need to meet our commitments in the
9 PSAR on valve testing, except that it will not provide the
10 specific calculations of the piping loads. We will do those
11 calculations ourselves on the project, utilizing the outputs
12 from the EPRI program, and utilizing information on our own
13 plant transients.

14 Furthermore, all the EPRI effort is currently
15 scheduled to be completed in late 1981 or early 1982, which
16 is well before the needs of Pilgrim 2 for this information.

17 The last slide please.

18 In summary, the EPRI program is currently underway
19 on power operated relief valves and on safety valves. The
20 Pilgrim 2 valves are included in the EPRI program. Pilgrim
21 2 will utilize the results of the EPRI program as they
22 become available, which will allow us to meet our
23 commitments.

24 The block valve program is currently under
25 development.

1 Ladies, and gentlemen, that concludes my
2 presentation. Are there any questions?

3 MR. BENDER: Are there questions?

4 (No response.)

5 MR. BENDER: Thank you, Mr. Bryant.

6 MR. BUTLER: This concludes the applicant's
7 presentation. We do have an answer to Dr. Okrent's
8 question, and Ron Jagels will give it.

9 MR. JAGELS: Dr. Okrent's question was the design
10 pressure of the containment on the other end of the
11 spectrum. The answer is, the containment is designed for a
12 minus 3 p.s.i.g., or 11.7 p.s.i.a. on the low end.

13 MR. BUTLER: I would like to thank the committee
14 for your attention to our presentation, and for interrupting
15 your unfinished business to let us in pretty much on
16 schedule.

17 MR. BENDER: Does the staff have anything further
18 comments to make?

19 MS. ADENSAM: No, we haven't.

20 MR. BENDER: Mr. Chairman, we have a couple of
21 alternatives that we can follow here. At one time, we
22 thought that we might write a letter on this subject, but it
23 doesn't seem that the content of the presentation indicates
24 any great need for a letter specifically on this plant.

25 I suspect that we have heard the picture of what

1 will be done on most construction permits, and how the staff
2 will review. They have a pretty effective program. I would
3 suggest that we reflect in the minutes of the committee's
4 the further story on Pilgrim 2.

5 Does that sound adequate for a construction permit
6 purposes, taking into account the TMI 2 considerations. We
7 could notify Mr. Dircks in some way that this is what has
8 been done, and not prescribe a formal letter at this time.

9 MR. MARK: I think that sounds appropriate for the
10 case. What we have learned is that the Pilgrim 2 group has
11 taken a very forceful look at the TMI 2 action plans and
12 consequences, and adjusting their thoughts to them, and is
13 committed meet, I guess, all of the major technical
14 requirements of the staff. Just how they will meet them,
15 they have time to go into that.

16 I think what you suggest is right. The minutes
17 should reflect that we have seen. The old CP letter of the
18 committee, those things never depreciate. The comment is
19 that the new requirements are being followed with good
20 intention.

21 Are there any differences, or opinions from other
22 committee members?

23 (No response.)

24 MR. MARK: If not, I suggest that we stop the
25 recording at this point of the record.

1 I would like to thank the Boston Edison people for
2 putting this together for us.

3 (Whereupon, at 5:40 p.m., recording of the meeting
4 was discontinued.)

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/255th General Meeting

Date of Proceeding: July 10, 1981

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

ANN RILEY

Official Reporter (Typed)

Ann Riley
Official Reporter (Signature)

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/255th General Meeting

Date of Proceeding: July 10, 1981

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Patricia A. Minson

Official Reporter (Typed)

Patricia A. Minson

Official Reporter (Signature)

GPU NUCLEAR
MAJOR ELEMENTS :

- **FULL TIME ORGANIZATION DEDICATED SOLELY TO NUCLEAR GENERATION**
- **INCREASED ON-SITE TECHNICAL AND MANAGEMENT RESOURCES**
- **STRONG CENTRAL TECHNICAL CONTROL**
- **FULL TIME ON-SITE MANAGEMENT FOR PLANT OPERATION AND MAINTENANCE - -
WITH SUPPORT IN ADMINISTRATION, ENGINEERING, RADIATION PROTECTION,
AND OTHER AREAS BEING PROVIDED SEPARATELY**
- **INDEPENDENT NUCLEAR ASSURANCE DIVISION - ENCOMPASSING TRAINING,
QUALITY ASSURANCE AND A NUCLEAR SAFETY ASSESSMENT DEPARTMENT**
- **POOLING OF RESOURCES FOR SUPPORT OF SEVERAL GENERATING STATIONS**
- **PERSONNEL POLICIES AND PROCEDURES APPROPRIATE FOR NUCLEAR GENERATION**


GPU NUCLEAR GROUP

PURPOSE


MANAGE AND DIRECT THE NUCLEAR ACTIVITIES OF THE GPU SYSTEM TO PROVIDE THE REQUIRED HIGH LEVEL OF PROTECTION FOR THE HEALTH AND SAFETY OF THE PUBLIC AND THE EMPLOYEES.

CONSISTENT WITH THE ABOVE, GENERATE ELECTRICITY FROM THE GPU NUCLEAR STATIONS IN A RELIABLE AND EFFICIENT MANNER IN CONFORMANCE WITH ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND OTHER REQUIREMENTS AND THE DIRECTIONS AND INTERESTS OF THE OWNERS.

GPU NUCLEAR




NEW TO ORGANIZATION
SINCE ACCIDENT



SHIFT FROM CONSTRUCTION
TO OPERATIONAL ACTIVITIES




SCOPE NARROWED TO
NUCLEAR ACTIVITIES ONLY




GPU NUCLEAR

SUMMARY

A- TECHNICAL PROFESSIONALS	416
B- PROFESSIONAL EXPERIENCE	5039
C- NUCLEAR EXPERIENCE	3153
D- SENIOR REACTOR OPERATOR LICENSES OR EQUIV.	119
E- TOTAL STAFF LEVEL	1947



GPU NUCLEAR



PURPOSE


- SUMMARIZE CONTAINMENT ISOLATION SIGNALS
- DISCUSS EFFECT OF OPEN PURGE VALVES ON CONTAINMENT PRESSURE

TMI-1 CONTAINMENT ISOLATION SIGNALS

	LINES	REACTOR TRIP	1600 PSIG SFAS	4 PSIG BLDG. PRESSURE	30 PSIG BLDG. PRESSURE	1600 PSIG STAS & LINE BRK	HIGH RADIATION LEVEL
PREVENT TRANSFER OF RADIATION OUTSIDE CONTAINMENT	R.B. SUMP						
	RCDT						
	RCS SAMPLE						
	R.B. PURGE						
	RCS LETDOWN	MU-V3	MU-V2A, B	MU-V2A, B, MU-V3			ALARM
	OTSG SAMPLE						
	DEMIN WATER						
FACILITATE STABLE SHUTDOWN	CORE FLOOD SAMPLE & N. LINES						
	R.B. AIR COOLERS						
	RC MAKEUP						
MAINTAIN REACTOR COOLANT PUMP SERVICES	CONTAINMENT AIR SAMPLE						
	R.C. PUMP SEAL RETURN						ALARM
	NSCCW						
	ICCW						

*IN ACCORDANCE WITH GDC-55

EFFECT OF BUILDING PURGE VALVES ON PEAK PRESSURE



- RX TRIP —————
- 1600 PSIG - - - - -
- 4 PSIG - - - - -
- 30 PSIG _____
- LINE BREAK + 1600 PSIG - - - - -
- SFAS
- HIGH RAD —————

CONTAINMENT PURGE VALVE EFFECTS ON BUILDING PRESSURE

ASSUMPTIONS:

- o 2 48" PURGE VALVES LIMITED TO 30⁰ OPEN (17" EQU. DIA.)
- o PURGE VALVE CLOSURE ON REACTOR TRIP FAILS
- o PURGE VALVE CLOSURE ON HIGH RADIATION FAILS
- o MAXIMUM HEAT REMOVAL FROM FAN COOLERS & HEAT SINKS

RESULTS: (CONTEMPT)

- o 4 PSIG IS REACHED FOR LOCA'S CAUSING CORE UNCOVERY (>.085 FT²)
- o 4 PSIG IS NOT REACHED FOR VERY SMALL LOCA'S WITH PURGE VALVES ~~OPEN~~ CLOSED.

CONCLUSIONS:

- o 4 PSIG SIGNAL IS VALID WITH PURGE VALVES LIMITED TO 30⁰ OPEN
- o REACTOR TRIP ISOLATION SIGNAL ANTICIPATES ESAS AND BUILDING PRESSURE SIGNALS FOR LOCA.

DUAL PRESSURE/TEMPERATURE SCALES

- o SATURATION MARGIN IS NOW THE BASIS FOR OPERATOR ACTION
- o INDICATION SHOULD BE CONTINUOUSLY MONITORED AND DISPLAYED
- o EVALUATION OF T + P BY OPERATOR TO DETERMINE SATURATION MARGIN
 - o IS NOT CONTINUOUS
 - o INVOLVES SEVERAL STEPS
 - o INVOLVES MENTAL PROCESSING
 - o SUBJECT TO ERROR UNDER STRESS
- o DUAL SCALE METER APPEARS PREFERABLE TO STEAM TABLE
- o PREFERRED METHOD IS DIRECT READING INDICATION
- o TMI-1 USES
 - o 2 SATURATION MARGIN METERS
 - o LOW SATURATION MARGIN ALARM FROM EITHER LOOP
 - o PROCESS COMPUTER CALCULATION OF SATURATION MARGIN
 - o GRAPHIC DISPLAY OF PRESSURE-TEMPERATURE PLOT

MIDSCALE METER FAILURES

- POWER SUPPLY LOSS (CRYSTAL RIVER 3 EVENT)

LOSS OF POWER ALARMS & INDICATIONS

PARAMETERS INDEPENDENT OF ICS/NNI

PLANT CONTROL PROCEDURES

METER FAILURE POINTS INDICATED & KEYED TO
POWER SUPPLY

- INDIVIDUAL METER FAILURES

ANALOG METERS: FAILURE POINTS NOTED ON METER

DIGITAL METERS: FAIL DARK OR ZERO

MOST ANALOG METER FAILURE POINTS OUTSIDE NORMAL BAND

ANALOG METER FAILURE POINTS IN NORMAL BAND HAVE
BEEN EVALUATED

DIGITAL METERS ADDED FOR KEY PARAMETERS, INCLUDING
THOSE USED FOR MANUAL CONTROL POST TRIP

NUREG 666 CONCLUSIONS

TYPE 1 FAILURES:

UNAVAILABILITY OF MULTIPLE BATTERIES
ON DEMAND

4×10^{-4} /DEMAND

ASSUMING LOSS OF OFF-SITE POWER
OCCURRENCE AT 0.22/YEAR, UNAVAIL-
ABILITY OF MULTIPLE BATTERIES ON
DEMAND.

9×10^{-5} /REACTOR
YEAR

TYPE 2 FAILURES:

UNAVAILABILITY OF MULTIPLE BATTERIES
DUE TO TEST, OPERATIONAL AND MAINTEN-
ANCE ERRORS.

6×10^{-5} /REACTOR
YEAR

COMBINATION OF TYPE 1 AND TYPE 2 FAILURES REPRESENTS A CONTRIBU-
TION OF 50% OF CORE DAMAGE PROBABILITY FOR ALL ACCIDENT SEQUENCES
STUDIED.

CONTRIBUTION OF DC POWER FAILURE TO CORE DAMAGE PROBABILITY CAN BE
REDUCED FROM 50% TO 1% BY:

- PROHIBITING CERTAIN DESIGN AND OPERATIONAL
FEATURES SUCH AS BUS-TIES
- AUGMENTING TEST AND MAINTENANCE ACTIVITIES
- INCORPORATE REQUIREMENTS FOR STAGGERED TEST
AND MAINTENANCE ACTIVITIES

TMI-1 SYSTEM IMPROVEMENTS

BATTERY DISCONNECT SWITCHES TO BE LOCKED CLOSED.

BUS TIE SWITCHES TO BE LOCKED OPEN.

SUBSTATION DISTRIBUTION BUS TIE TO BE DISABLED.

PROCEDURES REVIEWED AND UPGRADED.

- SURVEILLANCE OF TERMINAL CONNECTIONS
- UPGRADING OF BATTERY DISCHARGE TEST PROCEDURE
- RESTRICT USE OF BATTERY DISCONNECT SWITCHES AND BUS TIE SWITCHES TO COLD SHUT-DOWN
- DISABLE BUS TIES BETWEEN 230 KV SWITCHYARD DIST. PANELS
- RECOVERY PROCEDURES WRITTEN FOR LOSS OF A DC SUPPLY

SIGNIFICANT TMI-1 PLANT DIFFERENCES FROM NUREG 666

STAND-BY BATTERY CHARGERS

MORE RELIABLE OFF-SITE POWER

RELATIVE REDUCTION IN
SYSTEM UNAVAILABILITY

	<u>TYPE 1 FAILURES</u>	<u>TYPE 2 FAILURES</u>	<u>COMBINED</u>
<u>SYSTEM STUDIED IN NUPEG 666</u>	1.0	1.0	1.0
<u>TMI-1 SYSTEM AT RESTART</u>			
1. RESTRICT USE OF BUS TIE TO COLD SHUT-DOWN	1.0	0.001	
2. STAND-BY BATTERY CHARGER	0.03	0.2	
3. MORE RELIABLE OFF-SITE POWER	0.2	1.0	
COMBINATION OF 1, 2, & 3	0.006	0.001	<u>0.003</u>
<u>OTHER TMI-1 RESTART IMPROVEMENTS</u>			
IMPROVED SURVEILLANCE	0.03	1.0	0.5
IMPROVED MAINT. AND TEST	0.1	0.1	0.1

I N D E X

ACRS Presentation
June 25 - 26, 1981
W. H. Behrle

<u>SLIDE NO.</u>	<u>TITLE</u>
SLIDE 1	Test Program Scope
SLIDE 2	Bases for Selection of Tests
SLIDE 3	Major Documents Consulted
SLIDE 4	Test Program Organization/Control (2 pages)
SLIDE 5	Non-Modified Systems
SLIDE 6	List of HFT's
SLIDE 7	Zero Power Physics Program
SLIDE 8	Low Nuclear Power Testing Including Natural Circulation (2 pages)
SLIDE 9	Power Escalation Testing
SLIDE 10	Test Procedure Requirements
SLIDE 11	TMI-1 Restart Integrated Schedule

ACRS PRESENTATION

JUNE 25 - 26, 1981

W. H. BEHRLE

TEST PROGRAM SCOPE

TESTING INCLUDED IN THE UNIT 1 RESTART TEST PROGRAM
CONSISTS OF:

- O CONSTRUCTION AND STARTUP TESTING OF NEWLY INSTALLED COMPONENTS AND SYSTEMS INSTALLED BY THE UNIT 1 RESTART PROGRAM.
- O CONSTRUCTION AND STARTUP TESTING OF MODIFICATIONS TO EXISTING PLANT SYSTEMS AND COMPONENTS BY THE UNIT 1 RESTART PROGRAM.
- O TESTING OF SELECTED NON-MODIFIED SYSTEMS AS DETERMINED BY STARTUP AND PLANT OPERATIONS.
- O TESTING OF SELECTED MAINTENANCE PROJECTS AS REQUESTED BY MAINTENANCE.
- O SELECTED INTEGRATED TESTING DURING PLANT STARTUP AND POWER ESCALATION TO ASSURE PROPER PLANT OPERATION AND TRANSIENT RESPONSE FOLLOWING THE 1979 EXTENDED OUTAGE.

BASES FOR SELECTION OF TESTS

- o NORMAL REFUELING TEST REQUIREMENTS
- o MODIFICATIONS MADE TO THE PLANT
- o TMI 1 INITIAL TEST PROGRAM
- o NATURAL CIRCULATION TESTING PERFORMED AT NTOL PLANTS
- o REG GUIDE 1.68 TESTING PERFORMED AT NEW PLANTS
- o PLANT REINITIALIZATION CONSIDERATIONS
- o OPERATOR TRAINING CONSIDERATIONS
- o PROCEDURE VERIFICATION CONSIDERATIONS
- o SURVEILLANCE CONSIDERATIONS
- o PLANT TRANSIENT ANALYSIS VERIFICATION

MAJOR DOCUMENTS CONSULTED

- o NUREG - 0578 - LESSONS LEARNED (SHORT TERM)
- o NUREG - 0585 - LESSONS LEARNED (LONG TERM)
- o I&E BULLETINS - 79 - 01 AND 05
- o AUGUST 9, 1979 SHUTDOWN ORDER
- o TMI #1 RESTART REPORT (THRU AMENDMENT 25)
- o NUREG - 0660 - TMI ACTION PLAN
- o NUREG - 0680 - SAFETY EVALUATION REPORT (OF TMI #1
RESTART REPORT)
- o NUREG - 0694 - TMI RELATED REQUIREMENTS FOR NTOL'S
- o NUREG - 0737 - CLARIFICATION OF TMI ACTION PLAN REQUIREMENTS
- o REG GUIDE 1.68 - INITIAL TEST PROGRAMS FOR NUCLEAR POWER
PLANTS
- o DRAFT REG GUIDE FOR LWR REFUELING AND STARTUP TESTS

TEST PROGRAM ORGANIZATION/CONTROL

THE TMI #1 RESTART TEST PROGRAM IS PERFORMED IN AN ORGANIZED FASHION BY FORMALLY APPROVED DOCUMENTS. DETAILED NUCLEAR SAFETY RELATED TEST PROCEDURES AND RESULTS ARE APPROVED BY A TECHNICAL REVIEW/APPROVAL GROUP.

- o TEST MANUAL AND INSTRUCTIONS -
 - 1) ESTABLISHES THE STARTUP AND TEST GROUP TO PREPARE, PERFORM AND DOCUMENT THE TEST PROGRAM.
 - 2) ESTABLISHES THE AUTHORITY OF THE TECHNICAL REVIEW/APPROVAL GROUP AS THE CENTRAL APPROVAL AND COORDINATING BODY.
 - 3) DEFINES RESPONSIBILITIES OF VARIOUS PARTICIPANTS AND ORGANIZATIONS TO THE TEST PROGRAM.
 - 4) PROVIDES INSTRUCTIONS FOR TEST PROCEDURE FORMAT AND CONTENT, PREREQUISITE LISTS, TEST ENGINEER'S LOG, TEST BRIEFINGS, ETC.
- o MASTER TEST INDEX (MTX) - IDENTIFIES ALL TESTS REQUIRED FOR RESTART. LISTING INCLUDES CONSTRUCTION, FUNCTIONAL AND INTEGRATED PLANT TESTING.
- o TEST SPECIFICATION - IDENTIFIES TEST SCOPE AND ACCEPTANCE CRITERIA FOR ALL FUNCTIONAL AND INTEGRATED PLANT TESTS.

TEST PROGRAM ORGANIZATION/CONTROL (CONTINUED)

o TECHNICAL REVIEW/APPROVAL GROUP - COMPOSED OF REPRESENTATIVES FROM:

- 1) ENGINEERING
- 2) PLANT OPERATIONS
- 3) STARTUP AND TEST
- 4) NSSS SUPPLIER
- 5) QA

THIS GROUP REVIEWS AND APPROVES SAFETY RELATED TEST PROCEDURES AND RESULTS.

NON-MODIFIED SYSTEMS

- o INSTRUMENT AIR
- o SECONDARY SERVICES CLOSED COOLING SYSTEM
- o SECONDARY RIVER WATER SYSTEM
- o NUCLEAR SERVICES RIVER WATER SYSTEM
- o CIRCULATING WATER SYSTEM
- o MAIN AND AUXILIARY STEAM SYSTEM
- o CONDENSER AIR REMOVAL SYSTEM
- o CONDENSATE SYSTEM
- o PENETRATION PRESSURIZATION SYSTEM
- o FLUID BLOCK SYSTEM
- o PENETRATION COOLING SYSTEM
- o INTERMEDIATE CLOSED COOLING WATER SYSTEM
- o GASEOUS WASTE DISPOSAL SYSTEM
- o RECLAIMED WATER SYSTEM

SELECTION OF NON-MODIFIED SYSTEMS FOR TESTING WAS BASED ON "IMPORTANT TO SAFETY" CONSIDERATIONS. FOR EXAMPLE, FAILURE OF CONDENSER AIR REMOVAL SYSTEM (LOSS OF VACUUM) CAUSES SHIFT FROM TURBINE BYPASS VALVES TO ATMOSPHERIC DUMP VALVES.

LIST OF HFT's

- 1) Checkout Incore Thermocouples (Mod)
- 2) Set Main Steam Safety Valves (Surv)
- 3) Test Main Steam Safety Valve Acoustic Monitors (Mod)
- 4) Verify proper operation of Pressurizer Heater Level/Pressure Interlocks, Spray Valve Flow/Pressure Interlock (RI)
- 5) Determine Pressurizer heat losses and ability to control pressure and saturation margin on one(1) Heater Bank (RI/Mod)
- 6) Lift the PORV and determine adequate response of Elbow Taps, Acoustic Monitor, Tailpipe Thermocouples and Manual Switch (Mod)
- 7) Run Steam Driven Emergency Feed Pump on recirculation and verify it does not overspeed and comes up to rated speed in less than 30 sec (Mod/Surv)
- 8) Perform Diesel Generator Loading Test combining ES with Motor Driven Emergency Feed Pump Auto Start (Mod/Surv)
- 9) Check agreement of various Non-Nuclear Instrument Channels as a function of RCS Temperature/Pressure (RI/Mod)
- 10) Perform HPI Functional Test to verify Cavitating Venturis and high capacity Makeup Valve (Mod/Surv)
- 11) Verify proper operation of T_{sat} Meter as a function of RCS Temperature/Pressure (Mod)
- 12) Verify ability of RB Coolers to maintain RB Temperature less than design (PMT)
- 13) Verify operability of RCS High Point Vents (Mod)
- 14) Verify ability to sample RCS at normal operating temperature and pressure with long-handled tools in an acceptable time period (Mod)
- 15) Verify acceptable RCP operating parameters as a function of RCS Temperature/Pressure (RI)
- 16) Flow balance the Intermediate Cooling Water System, as required (RI)
- 17) Take thermal expansion readings on hangers/supports as a function of RCS Temperature (Mod)
- 18) Perform RCS leakage measurements (Surv)
- 19) Perform CRD drop time measurements (Surv)
- 20) Perform DH-V22A/B, CF-V4A/B & 5A/B Leakage Surv Test (Mod/Surv)

ZERO POWER PHYSICS PROGRAM

AT ZERO NUCLEAR POWER, 2155 PSIG AND 532°F RCS CONDITIONS, PERFORM THE FOLLOWING PHYSICS TESTS IN ACCORDANCE WITH NORMAL REFUELING TESTING PROCEDURES:

- 1) CONTROL ROD WITHDRAWAL
- 2) DEBORATION TO CRITICAL
- 3) DETERMINATION OF SENSIBLE HEAT AND NI OVERLAP
- 4) PERFORM REACTIVITY MEASUREMENTS
- 5) DETERMINATION OF ALL RODS OUT BORON CONCENTRATION
- 6) DETERMINATION OF ALL RODS OUT TEMPERATURE COEFFICIENT
- 7) INTEGRAL CONTROL ROD WORTH MEASUREMENTS
- 8) SHUTDOWN MARGIN VERIFICATION
- 9) TEMPERATURE COEFFICIENTS
- 10) EJECTED CONTROL ROD WORTH MEASUREMENT

LOW NUCLEAR POWER TESTING
INCLUDING NATURAL CIRCULATION

- 1) PERFORM CORRELATION BETWEEN OUT OF CORE DETECTOR INDICATION VS. HEAT BALANCE POWER AS A FUNCTION OF T_{COLD} (3% POWER)
- 2) VERIFY AUTO START OF EMERGENCY FEEDWATER PUMPS AND OTSG LEVEL CONTROL AT 30" ON STARTUP RANGE UPON LOSS OF BOTH FEEDWATER PUMPS AND DEMONSTRATE ADEQUACY OF FLOW INDICATION (RM-13B) (3% POWER)
- 3) VERIFY ABILITY TO CONTROL LEVEL WITH THE NEW MANUAL LOADER STATION (RM-13D) (3% POWER)
- 4) VERIFY ADEQUATE AIR SUPPLY TO EMERGENCY FEEDWATER CONTROL VALVES (EF-V30A/B) AND TURBINE DRIVEN EMERGENCY FEED PUMP STEAM CONTROL VALVE (MS-V6) FOR 2 HOURS WITH LOSS OF INSTRUMENT AND BACKUP INSTRUMENT AIR (RM-13H) (3% POWER)
- 5) VERIFY SMOOTH TRANSITION TO NATURAL CIRCULATION FLOW WITH OTSG LEVEL CONTROL AT 50% ON OPERATING RANGE UPON LOSS OF ALL 4 RCP'S AND DEMONSTRATE ADEQUACY OF FLOW INDICATION (RM-13B) (3% POWER)
- 6) DETERMINE EFFECT OF LOSS OF PRESSURIZER HEATERS ON SATURATION MARGIN (3% POWER)
- 7) DETERMINE EFFECT OF SG LEVEL ON NATURAL CIRCULATION FLOW (3% POWER)
- 8) VERIFY THAT OP 1102-16 (RCS NATURAL CIRCULATION COOLING) PROVIDES ADEQUATE GUIDANCE TO PREVENT OVERCOOLING AS OTSG LEVEL CONTROL SETPOINT CHANGES FROM 30" ON STARTUP RANGE TO 50% ON OPERATING RANGE (FOLLOWING 40% POWER TRIP)

LOW NUCLEAR POWER TESTING INCLUDING
NATURAL CIRCULATION (CONTINUED)

- 9) DETERMINE LOWEST LEVEL IN OTSG THAT SUSTAINS NATURAL CIRCULATION FLOW WITH NO EMERGENCY FEEDWATER (FOLLOWING 100% POWER TRIP)

POWER ESCALATION TESTING

Following the Low Power Test Program, escalate power to the 15%, 40%, 75% and 100% power plateaus in steps and perform the following testing, as indicated:


- 1) Perform Turbine Overspeed Surveillance Test (0-12%-0) (Surv)
- 2) Perform Nuclear Instrumentation Calibration at power (15%, 40%, 76% and 100%) (Surv)
- 3) Perform ICS Tuning at power (20%, 40%, 80% and 95-100% and at minor levels between majors)
- 4) Perform Turbine Bypass Valve Testing at power (% open vs. steaming rate and correct bias from ICS on Turbine Trip) (0-15%)
- 5) Perform Heat Balance Surveillance Testing and verify computer program as required (15%, 40%, 76% and 100%)
- 6) Perform Feedwater System Operation and Tuning (40%, 76%, 100%)
- 7) Perform Turbine Generator Operation and Testing (15%, 40%, 76%, 100%)
- 8) Perform Power Imbalance Detector Correlation Test (40%) (Surv)
- 9) Perform Unit Load Transient Testing (40%, 80%, 100%)
- 10) Perform Unit Load Steady State Testing (15%, 40%, 76%, 100%)
- 11) Perform Saturation Monitor Checks (15%, 40%, 76%, 100%) (LM-1)
- 12) Perform Incore Thermocouple Checks (15%, 40%, 76%, 100%) (RM-4)
- 13) Perform Core Power Distribution Testing (15%, 40%, 76%, 100%) and verify computer programs.
- 14) Perform Reactivity Coefficients Testing (100%)
- 15) Verify RCP Flow (100%) (Surv)
- 16) Perform loss of both Feedwater Pumps (40%) (RM-3) (Verify letdown isolation and Bypass - RM-5)
- 17) Perform loss of one(1) Feedwater Pump runback (100%)
- 18) Perform Turbine Trip Test (100%) (RM-3)
- 19) Perform CRD misalignment runback (76%)
- 20) Check thermal expansion/hanger settings of systems affected by power operation (15%, 40%, 76%, 100%)

TEST PROCEDURE REQUIREMENTS

<u>TEST TYPE</u>	<u>NUMBER REQUIRED*</u>	<u>WRITTEN</u>	<u>APPROVED</u>	<u>PERFORMED</u>
NON-MODIFIED SYSTEMS	15	14	0	0
MODIFICATION FUNCTIONAL	29	19	10	3
HOT FUNCTIONAL	14	12	0	0
LOW POWER/POWER ESCALATION	16	3	0	0
	—	—	—	—
	74	48	10	3

*BASED ON REVIEW/PLANNING OF 57 MODIFICATIONS

IMI-1 RESTART INTEGRATED SCHEDULE



JULY AUGUST SEPTEMBER OCTOBER NOVEMBER DECEMBER

COMPARISON OF TMI #1 RESTART LOW POWER TEST PROGRAM
WITH SEQUOYAH LOW POWER TEST PROGRAM

- 10 Tests required by NRC for Sequoyah
- 8 Tests required with simulated Decay Heat and
- 1 Test required with real Decay Heat for all other NTOL's

<u>Sequoyah</u>	<u>TMI Restart</u>
1) Establish stable N/C conditions	1) Included in TP 700/2 - each shift participates/witnesses.
2) Establish N/C with simulated loss of off-site power	2) Not included in Restart Program. Was verified during actual loss of off-site power in initial startup in 1974.
3) N/C with loss of Pressurizer Heaters	3) Included in TP 700/2 - Low Power Natural Circulation Test Procedure
4) Effect of OTSG secondary side isolation on N/C flow	4) Not included in Restart Program. Single OTSG N/C flow was verified on B&W NSSS on TMI #2
5) N/C flow at reduced RCS pressure	5) No auxiliary spray is available on TMI #1. Any performance of this item in TP 700/2 will be a continuation of item 3.
6) Cooldown capability of Makeup/Letdown	6) Included in TP 651/1 - Intermediate Cooling System Flow Balance.
7) Simulated loss of all on-site and off-site AC power	7) Secondary side heat sink (Emergency Feedwater) availability without AC power is demonstrated with forced RCS flow in TP 700/2 as part of EF. Modification Testing. Primary side response would be no different than Loss of Off-Site Power Test in initial Startup Program and would cause loss of seals to RCP's which could degrade seal life.

Sequoyah

- 8) Establish N/C from stagnant conditions

- 9a) Forced circulation cooldown

- 9b) Boron mixing and cooldown

TMI Restart

- 8) NRC deleted this requirement from all NTOL's subsequent to Sequoyah. It is not included in the TMI Restart.

- 9a) Included in TP 700/2 - Low Power Natural Circulation Test Procedure.

- 9b) Not included in Restart Program. Boron mixing and cooldown were verified on B&W NSSS on TMI #2.

- 10) Verify that Plant Natural Circulation Procedures provide adequate guidance to the operator to prevent overcooling as OTSG level changes from 30" on Startup Range to 50% on Operating range.

- 11) Determine the lowest level in the OTSG that sustains Natural Circulation flow without Emergency Feedwater flow.

TMI-1 PROBABILISTIC RISK ASSESSMENT

o PURPOSE

- EVALUATE RISK TO PUBLIC
- EVALUATE PLANT RELIABILITY & AVAILABILITY

o TECHNIQUES

- DETAILED EVENT SEQUENCE DIAGRAMS & EVENT TREES
- IDENTIFY CRITICAL SYSTEMS
- SYSTEMS ANALYSIS FOR FAILURE PATHS (FAULT TREES)
- QUANTIFICATION USING TMI-1 DATA WHERE AVAILABLE

o SCOPE

- RANDOM FAILURES
- COMMON MODE
- COMMON CAUSE
- EXTERNAL HAZARDS

o USES

- IDENTIFY CHANGES SIGNIFICANT TO PUBLIC RISK
- IDENTIFY AREAS FOR RELIABILITY & AVAILABILITY IMPROVEMENTS
- RELATIVE BENEFITS OF CHANGES

o SCHEDULE

- BID SPECIFICATION -- THIRD QUARTER '81
- COMMENCE STUDY -- FOURTH QUARTER '81

REQUIREMENT

NUREG - 0737 SECTION II.F.2

"LICENSEES SHALL PROVIDE A DESCRIPTION OF ANY ADDITIONAL INSTRUMENTATION OR CONTROLS (PRIMARY OR BACKUP) PROPOSED FOR THE PLANT TO SUPPLEMENT EXISTING INSTRUMENTATION (INCLUDING PRIMARY COOLANT SATURATION MONITORS) IN ORDER TO PROVIDE AN UNAMBIGUOUS, EASY-TO-INTERPRET INDICATION OF INADEQUATE CORE COOLING (ICC)."

"THE EVALUATION IS TO INCLUDE REACTOR-WATER-LEVEL INDICATION."

GPUN APPROACH TO
EVALUATION OF WATER LEVEL MEASUREMENT

- DEFINE USE AND DEVELOP CRITERIA
 - PARTICIPATED IN B&W OWNER'S GROUP EVALUATION
 - IN-HOUSE EVALUATION VS OPERATOR GUIDELINES
 - CONSIDERING USES OTHER THAN OPERATOR ACTION

- EVALUATE POTENTIAL DETECTORS
 - PARTICIPATED IN B&W OWNER'S GROUP EVALUATION
 - IN-HOUSE EVALUATIONS
 - SPONSORING STUDY BY CONSULTANT OF POSSIBLE METHODS
 - COOPERATING IN UNIVERSITY PROPOSAL RE NEUTRON DETECTORS
 - WILL REVIEW EPRI EVALUATION (DUE OCTOBER 1981)

- SELECT APPROPRIATE ACTION
 - INSTALL AVAILABLE DETECTOR(S)
 - SUPPORT FURTHER DEVELOPMENT
 - DEFINE ALTERNATE APPROACH

POSSIBLE USES OF WATER LEVEL AND RELATED INSTRUMENTS (FOR B&W PLANTS)

LOCA RESPONSE

- REQUIRED OPERATOR ACTIONS CAN BE BASED ON EXISTING INSTRUMENTS.
- LOOP WATER LEVEL MIGHT BE USED AS CONFIRMATION/BACKUP.
- VOID FRACTION MIGHT BE USED AS NEW PUMP TRIP CRITERION.

OVER-COOLING RESPONSE

- REQUIRED OPERATOR ACTIONS CAN BE BASED ON EXISTING INSTRUMENTS.
- RCS INVENTORY COULD BE USED TO CONFIRM NOT A LOCA.

RCS VENTING (POST ACCIDENT)

- OPERATOR GUIDELINES UNDER DEVELOPMENT.
- WATER LEVEL IN HOT LEGS MAY BE USEFUL.

RESPONSE TO BUBBLE IN HEAD

- NEW OPERATOR GUIDELINES UNDER DEVELOPMENT.
- USEFULNESS OF VESSEL WATER LEVEL NOT YET DEFINED.

POST TRIP EVALUATIONS

- USEFULNESS OF SPECIFIC INSTRUMENTS DEPENDS ON SCENARIO.

LEADING CANDIDATES FOR LEVEL MEASUREMENT

<u>METHOD</u>	<u>DEVELOPER</u>	<u>COMMENTS</u>
VESSEL ΔP	WESTINGHOUSE EG&G GE	DIRECT LEVEL MEASUREMENT UNDER QUIESENT CONDITIONS. INDICATES "EQUIVALENT" LEVEL FOR 2 PHASE, LOW FLOW CONDITIONS. DIFFICULT TO INTERPRET WITH FORCED FLOW.
HOT-LEG ΔP	B&W	SIMILAR IN PRINCIPLE TO VESSEL ΔP . GOOD "ANTICIPATION" BUT NOT FULL RANGE.
HEATED T/C's	CE ORNL (EG&G)	INDICATES LEVEL AT DISCRETE INTERVALS. RESPONSE VS QUALITY OF FLUID MUST BE KNOWN. REQUIRES APPROPRIATE PENETRATIONS IN REACTOR HEAD.
NEUTRON DETECTORS	EPRI (PREVIOUSLY) PSU (POTENTIALLY)	NON-INTRUSIVE DETECTORS. TESTS INDICATE SENSITIVITY GOOD WITH WATER LEVEL WITHIN 8 FEET OF TOP OF CORE.
CORE EXIT T/C's	?	MAY BE ABLE TO CORRELATE TO WATER LEVEL IF BELOW TOP OF CORE.

CURRENT GPUN CONCLUSIONS
RE WATER LEVEL OR ALTERNATE MEASUREMENT

- NOT REQUIRED PRIOR TO TMI RESTART
 - NO NEED AS INPUT TO SAFETY SYSTEMS.
 - REQUIRED OPERATOR ACTIONS CAN BE PERFORMED BASED ON EXISTING INSTRUMENTS.

- CRITERIA FOR DETECTOR NOT YET CLEAR
 - WATER LEVEL VS VOID FRACTION VS INVENTORY NEEDS FURTHER STUDY
 - ADDED INFORMATION MIGHT BE HELPFUL FOR CONFIRMATION OR LATER EVALUATIONS.
 - ADDED INFORMATION MIGHT HELP GUIDE LONGER TERM ACTIONS (E.G., VENTING).
 - USE OF VOID FRACTION AS BASIS FOR PUMP TRIP NEEDS EVALUATION.

- NO "IDEAL" DETECTOR HAS BEEN IDENTIFIED
 - FORCED FLOW VS LOW FLOW/STAGNANT POOL IS A PROBLEM.
 - EXISTING SYSTEMS DO NOT MEET ALL NRC CRITERIA.
 - NEW APPROACHES SHOULD BE CONSIDERED.

- PREMATURE INSTALLATION IS INAPPROPRIATE
 - MAY ADD UNNECESSARY COMPLEXITY
 - COULD BE MISLEADING UNLESS USE IS CAREFULLY DEFINED.

- GPUN WILL CONTINUE ACTIVE EVALUATION OF CRITERIA AND DETECTORS.

II.F.2 - INSTRUMENTATION FOR
DETECTION OF
INADEQUATE CORE COOLING
(ICC)

MINIMUM INSTRUMENTATION FOR ICC MONITORING SYSTEM

ICC INSTRUMENTS (SEE NOTE 1)	REACTOR TYPE (SEE NOTE 2)			
	WESTINGHOUSE	CE	B&W	GE
SATURATION METER	REQUIRED	REQUIRED	REQUIRED	NOT REQUIRED
COOLANT INVENTORY (LEVEL) ABOVE CORE	REQUIRED	REQUIRED	REQUIRED*	REQUIRED
COOLANT INVENTORY (LEVEL) WITHIN CORE	DESIRABLE	NOT REQUIRED**	NOT REQUIRED**	REQUIRED
CORE EXIT T/Cs	REQUIRED	REQUIRED	REQUIRED	CORE T/C REQUIRED*

* NO FIRM DESIGN PROPOSED BY VENDOR.

** NOT REQUIRED PROVIDED THAT CORE EXIT THERMOCOUPLE INFORMATION IS PROCESSED, RECORDED, AND DISPLAYED IN AN ACCEPTABLE MANNER TO FACILITATE INTERPRETATION OF CORE COOLING CONDITIONS IN CONJUNCTION WITH ABOVE-CORE LEVEL INSTRUMENTATION.

NOTE 1: LEVEL INSTRUMENTATION MUST BE TESTED AND EVALUATED FOR LARGE BREAK LOCA SURVIVABILITY AND POST LOCA OPERABILITY.

NOTE 2: REQUIREMENTS ARE BASED ON REACTOR VENDOR PROPOSED INSTRUMENTATION, INTERCHANGEABILITY OF INSTRUMENTATION SYSTEMS IS ACCEPTABLE.

BASIS FOR STAFF POSITION
ON ICC MONITORING SYSTEMS

<u>INSTRUMENT</u>	<u>REFERENCE FOR REQUIREMENT</u>
SATURATION METER	NUREG - 0660 NUREG - 0737 R.G. 1.97
COOLANT INVENTORY (LEVEL)	NUREG - 0660 NUREG - 0737 (CLARIFICATION ITEM 6) R.G. 1.97 *
CORE EXIT T/Cs	FOR PWR: NUREG - 0737 (II.F.2 ATTACHMENT 1) R.G. 1.97 FOR BWR: LA SALLE SER R.G. 1.97

* ICC INDICATION RANGE

BWR - FROM BOTTOM OF CORE SUPPORT PLATE TO
LESSER OF TOP OF VESSEL OR CENTERLINE OF
MAIN STEAM LINE

PWR - FROM BOTTOM OF CORE TO TOP OF VESSEL

STAFF POSITION - ICC INSTRUMENTATION
FOR RESTART

- * EXISTING INSTRUMENTATION WITH COMMITMENT TO UPGRADE PER NUREG-0737 IS
ACCEPTABLE FOR RESTART
- * EVIDENCE OF REASONABLE PROGRESS ON ADDITIONAL INSTRUMENTATION (REACTOR WATER
LEVEL) IS REQUIRED

CRITERIA TO SHOW EVIDENCE OF REASONABLE PROGRESS ON ADDITIONAL
INSTRUMENTATION (REACTOR WATER LEVEL)

1. SELECTION OF A LEVEL MEASUREMENT SYSTEM CONCEPT OR AN EQUIVALENT SYSTEM FOR DEVELOPMENT
2. DEFINITION OF THE DEVELOPMENT PROGRAM AND SCHEDULE FOR DEVELOPMENT AND PROCUREMENT OF THE SELECTED SYSTEM
3. EVIDENCE OF A TANGIBLE COMMITMENT TO PERFORMANCE OR PARTICIPATION IN THE APPROPRIATE TEST PROGRAMS TO EXECUTE THE DEFINED DEVELOPMENT PROGRAM
4. JUSTIFICATION FOR THE CONCEPT SELECTED IF IT RESULTS IN SIGNIFICANT SCHEDULE DELAYS
5. CONTINGENCY PLANS AND SCHEDULE FOR PROCUREMENT OF AN ALTERNATIVE CONCEPT
6. APPROPRIATE ANALYSES TO INCORPORATE THE WATER LEVEL STATUS INFORMATION INTO THE GUIDELINES FOR OPERATOR ACTIONS WITH RESPECT TO ICC

Pogin

1981 ANNUAL RADIATION EMERGENCY EXERCISE SCENARIO

THREE MILE ISLAND

UNIT I

JUNE 2, 1981

EXERCISE EVENTS

DECLARATION OF EMERGENCY

NOTIFICATION OF OFFSITE AGENCIES

EMERGENCY ANNOUNCEMENTS

ACTIVATION OF ONSITE ORGANIZATION

ACTIVATION OF OFFSITE ORGANIZATION

FULL ACCOUNTABILITY

RCS POST ACCIDENT SAMPLE

SEARCH AND RESCUE

*EVACUATION OF PERSONNEL

MONITORING AT ASSEMBLY AREA

*CONTAMINATED PERSONS ARE DECONTAMINATED

EMERGENCY MEDICAL ASSISTANCE TO CONTAMINATED-INJURED
PERSON

OFFSITE MEDICAL RESPONSE

RESPONSE TO FIRE AT CWP HOUSE

STATE POLICE HELICOPTER NOTIFICATION AND TRAFFIC CONTROL

MAJOR SCENARIO EVENTS

T (MIN)

- 30 1. PRIMARY TO SECONDARY LEAK INDICATED BY INCREASING COUNTRATE ON CONDENSER OFFGAS MONITOR.
- 140 2. STEAM LINE RADIATION MEASUREMENTS INDICATE LEAK IN BOTH STEAM GENERATORS.
- 170 3. WASTE GAS COMPRESSOR SEAL FAILURE ALLOWS BUILDUP OF AIRBORNE RADIOACTIVITY IN AUXILIARY BUILDING.
- 220 4. STEAM GENERATOR TUBE RUPTURE INDICATED BY STEP CHANGES IN COUNTRATE ON THE OFFGAS MONITOR AND MAKE-UP FLOW RATE.
- 320 5. AUXILIARY OPERATOR IS INJURED AND CONTAMINATED WHILE INVESTIGATING MAKE-UP PUMP PROBLEM. OFFSITE MEDICAL ASSISTANCE.
- 380 6. FIRE IN CIRCULATING WATER PUMP HOUSE. OFFSITE FIRE ASSISTANCE.
- 390 7. FIRE CAUSES LOSS OF ALL CIRCULATING WATER PUMPS AND CONDENSER VACUUM REQUIRING STEAMING TO ATMOSPHERE TO CONTINUE COOLDOWN. MAJOR FUEL FAILURE OCCURS.
- 425 8. OFFSITE POWER IS LOST. "B" DIESEL GENERATOR PICKS UP VITAL LOADS.
- UNTIL 9. REACTOR COOLANT SYSTEM IS ON NATURAL CIRCULATION
TERMINATION REMOVING DECAY HEAT BY STEAMING TO ATMOSPHERE.

GPUN Problem Categorization

Problem or Issue:

— Industry Generic

- Broad applicability in industry
- Generally long-term
- GPUN has no unique expertise or resource
- Regulatory position defined or undefined
- May require major resources


— B&W 177 Owners Specific

- Applies mainly to B&W plants
- Combined resources may expedite solution
- Near or long-term
- Owners + B&W have unique capability
- Regulatory position defined or undefined

— TMI Plant Specific

- Specific to TMI
- Near, intermediate, or long-term
- Regulatory position generally defined
- Generally little or no benefit to group approach

Problem Solution



GPUN
Responsibility

Licensing &
Regulatory Affairs

Projects &
Tech Specialists

Tech Specialist

Engr. Projects
& Licensing

Tech Specialists

Engr. Projects

Example

• Degraded Core
Rule Making

• Transient
Analysis

• Valve Test
Program
• Steam
Generators

• PV Water Level

• Steam
Generators
• Asymmetric
LOCA Loads

• TMI Lessons
Learned
• GPUN Mgmt.
Directives


GPUN - Industry Participation

	GPUN
EPRI - Nuclear Power Div. Comm.	Member
● Safety & Analysis Task Force	Member
● Engineering & Operations Task Force	-
● System & Materials Task Force	
- Fuel Cycle	Member
- Plant Materials	Member
- Pressure Boundary Subcommittee	Member
● Owner Groups	
- BWR Pipe Cracking	Member
- PWR Safety and Relief Valve	Member
- Steam Generators	Member
● Code Development and Tech. Advisory Group	5 Members
 B&W Owners - Executive	
● Operator Support	Member
● ATWS	Member
● Asymmetric LOCA Loads & Analysis	Member, Chairman
● Electrical Equip. Qual.	Member
● Inservice Inspections	Member
● Steam Generator	Member
● Reactor Pressure Vessel	Member, Chairman
● TMI-2 Follow up	Member

Hydrogen Control - Vented Containment

- **Industry Generic Issue**
- **Issues are complex, regulatory positions being developed**
- **Work, Studies in progress**
- **GPUN has no special expertise, follow current Industry/NRC work**

CP/ML REVIEW TEAM ORGANIZATION



_____ Standard Organizational Reporting Path
 - - - - - Review Team Reporting Path

CONDUCT OF REVIEW

<u>MILESTONE</u>	<u>TIME</u>
APPLICANT'S INITIAL SUBMITTAL RECEIVED	--
ADDITIONAL INFORMATION REQUIREMENTS IDENTIFIED BY REVIEWERS	SECOND WEEK
MEETINGS WITH APPLICANT, AS NEEDED, TO RESOLVE ISSUES	THIRD WEEK
APPLICANT'S REVISED SUBMITTAL RECEIVED	FOURTH WEEK
DRAFT SSER INPUTS TO TECHNICAL COORDINATOR FOR REVIEW	FOURTH WEEK
SSER INPUTS ISSUED TO DL	FIFTH WEEK
DL ISSUES SSER	APPROXIMATELY EIGHTH WEEK

NTCP PLANT REVIEW SCHEDULES

<u>PLANT</u>	<u>SUBMITTAL RECEIVED</u>	<u>REVIEW COMPLETED</u>	<u>SSEP. ISSUED</u>
PILGRIM 2	04/06/81C	05/08/81C	06/81C
ALLENS CREEK 1	05/01/81C	06/05/81C	07/81E
FNP 1 - 8	06/17/81C	07/17/81E	08/81E
SKAGIT 1 & 2	08/03/81E	09/04/81E	10/81E
BLACK FOX 1 & 2	11/02/81E	12/04/81E	01/82E
PEBBLE SPRINGS 1 & 2	N/S	N/S	N/S
PERKINS 1 - 3	N/S	N/S	N/S

BOSTON EDISON
PILGRIM STATION UNIT 2
ACRS MEETING AGENDA
JULY 10, 1981

- PROJECT STATUS & ORGANIZATION R.M. BUTLER
- PROBABILISTIC RISK ASSESSMENT PROGRAM J.W. ASHKAR
- ATWS CONSIDERATION J.W. ASHKAR
- HYDROGEN CONTROL R.E. JAGELS
- DEGRADED CORE RULEMAKING ACTIVITIES R.E. JAGELS
- CONTROL ROOM DESIGN APPROACH G.M. McHUGH
- INADEQUATE CORE COOLING INSTRUMENTATION D.A. BRYANT
- SAFETY/RELIEF VALVE TESTING D.A. BRYANT

STATUS OF PILGRIM #2

● MAJOR CONTRACTS	1972
● PSAR DOCKETED	12/73
● NRC SER	6/75
● ASLB HEARINGS STARTED	10/75
● ACRS MEETINGS/REPORTS	11/75 & 10/77
● NPDES PERMIT ISSUED	8/78
● ASLB PARTIAL INITIAL DECISION	2/81
● DRAFT NTCP RULE (NUREG-0718) - TMI	3/81
● PSAR AM. #43 - TMI	4/81-5/81
● NRC SER SUPPLEMENT - TMI	6/81

● DESIGN COMPLETION	
NSSS	90%
BALANCE OF PLANT	65%
TURBINE GENERATOR	100%
● DELIVERED EQUIPMENT* IN STORAGE	\$175 MILLION
● TOTAL EXPENDITURES TO DATE	\$300 MILLION


*INCLUDES: RPV, SG, RCP, T/G, PRESSURIZER

ACRS S/C
RMB-1

PILGRIM STATION UNIT #2
MANPOWER ESTIMATE DURING CONSTRUCTION
 (IN EQUIVALENT NUMBER OF MEN)

	<u>START OF CONSTRUCTION</u>	<u>YR.1</u>	<u>YR.2</u>	<u>YR.3</u>	<u>YR.4</u>	<u>YR.5</u>	<u>COMMERCIAL OPERATION</u>
NUCLEAR OPERATIONS	0	4	40	80	120	180	200
NUCLEAR OPERATIONS SUPPORT	2	2	3	3	3	3	4
NUCLEAR ENGINEERING	21	24	24	19	20	19	18
PILGRIM 2 PROJECT	10	22	22	22	22	22	12
QUALITY ASSURANCE	4	6	7	8	9	9	8
PLANNING, SCHEDULING & COST CONTROL	2	3	3	3	3	3	2
TOTAL NUCLEAR ORGANIZATION PERSONNEL SUPPORTING PILGRIM UNIT #2	39	61	99	135	177	236	244

PILGRIM 2 - ORGANIZATION



PRA PROGRAM
SUMMARY

- PLANT/SITE-SPECIFIC PRA
 - OBJECTIVES
 - ORGANIZATION
 - PROGRAM FLOW
 - KEY ELEMENTS
 - PRA REPORT


PRA PROGRAM
OBJECTIVES

- A) SEEK DESIGN IMPROVEMENTS TO INCREASE CORE AND CONTAINMENT
HEAT REMOVAL RELIABILITY
- SIGNIFICANT RISK REDUCTION
 - DEMONSTRATED ENGINEERING TECHNOLOGY
 - ACCEPTABLE COST AND SCHEDULE IMPACT
- B) QUANTIFY MERITS OF DESIGN IMPROVEMENTS

PRA PROGRAM
ORGANIZATION

- PRA ACTIVITIES - EXPERIENCED, HIGHLY QUALIFIED
- DESIGN ALTERNATES - DESIGN GROUPS PRESENTLY RESPONSIBLE
- INDEPENDENT REVIEW - SEPARATE SENIOR LEVEL OVERSIGHT
- DESIGN DECISIONS - CURRENT PROJECT MANAGEMENT TEAM

PRA PROGRAM FLOW



PRA PROGRAM - KEY ELEMENTS

- PRELIMINARY ANALYSIS - "MASTER LOGIC TREE"
- PLANT EVENT SEQUENCES - ALLOWABLE PLANT OPERATING MODES
- DATA BASE - VERIFY ASSUMPTIONS
- EXTERNALLY CAUSED FAILURES - FREQUENCY & CONSEQUENCES QUANTIFIED
- KEY SYSTEM FAULT TREES
 - INCLUDING SUPPORT SYSTEMS (COMMON MODE FAILURE)
 - HUMAN INTERACTION
 - ENVIRONMENTAL EFFECTS
- TREATMENT OF UNCERTAINTY
- FEEDBACK INTO DESIGN
 - OUTLIER IDENTIFICATION
 - CRITICAL ITEMS LIST
 - "IMPORTANCE TO SAFETY" 10CFR50, APP. B
 - MULTIPLE FAILURE CONSIDERATIONS

PRA REPORT

- PROBABILISTIC RISK ASSESSMENT
 - METHODS
 - ASSUMPTIONS
 - DATA SOURCES
 - TYPICAL ANALYSIS
 - TREATMENT OF UNCERTAINTY

- RESULTS
 - CORE MELT FREQUENCY
 - CONTAINMENT FAILURE FREQUENCY
 - DOMINANT SEQUENCES
 - RISK CURVES - HEALTH EFFECTS
 - SYSTEM RELIABILITY IMPROVEMENTS

- FUTURE APPLICATIONS

PILGRIM 2 CONTAINMENT

(1200 MW_e PWR)

- **PRESTRESSED CONCRETE**
- **FREE VOLUME: 2.5×10^6 CU. FT.**
- **DESIGN PRESSURE: 60 PSIG**
- **TEST PRESSURE: 69 PSIG**

DEGRADED CORE HYDROGEN REQUIREMENTS

(NUREG-0718)

- 100% METAL WATER REACTION
- H₂ CONTROL TO LIMIT H₂ TO < 10%
- ASME III DIV 2, CC-3720; 45 PSIG MIN.

PRELIMINARY ANALYSIS

ASSUMPTIONS

- H₂ CONTROL METHOD - IGNITERS
- STEAM DILUTION EFFECTS CONSIDERED
- HEAT SINKS CONSIDERED
- ONE SPRAY TRAIN

RESULTS

- CONTAINMENT PRESSURE < P_{TEST} (69 PSIG)
- CONTAINMENT LINER TEMP < T_{DESIGN}

HYDROGEN CONTROL COMMITMENTS

- INCORPORATE INDUSTRY AND NRC RESEARCH/TESTING
- ADDITIONAL ANALYSES
- SUBMIT H₂ CONTROL DESIGN TO NRC 2 YRS POST-CP

POST-ACCIDENT SAMPLING

- SAMPLE STATION ACCESSIBLE WITHIN 1 HOUR
- POST-ACCIDENT SAMPLES FROM:
 - REACTOR COOLANT SYSTEM
 - CONTAINMENT SUMP
 - CONTAINMENT ATMOSPHERE
- SHIELDING OF SAMPLE/ANALYSIS FACILITIES TO LIMIT DOSES TO < GDC 19
- POST-TMI CHANGES:
 - SHIELDING
 - SYSTEM ARRANGEMENT

DEGRADED CORE CONSIDERATIONS

- HYDROGEN CONTROL SYSTEM
- 3 FT SPARE CONTAINMENT PENETRATION
- PLANT SPECIFIC PRA
- MONITOR INDUSTRY/NRC EFFORTS
- PARTICIPATE IN RULEMAKING

CONTROL ROOM DESIGN APPROACH

SUMMARY

- REVISED APPROACH
- CURRENT STATUS
- PRE-TMI WORK
- POST-TMI APPROACH

CONTROL ROOM DESIGN APPROACHPRE-TMI WORK


- SAFETY SEQUENCE ANALYSIS
- BECHTEL/CE PROPOSED LAYOUTS
- REVIEW OPERATION OF PLANT SYSTEMS
- HUMAN FACTORS GUIDELINES
- PRELIMINARY LAYOUTS

CONTROL ROOM DESIGN APPROACH

POST-TMI APPROACH

- INITIAL ACTIVITIES
 - DATA COLLECTION
 - PROGRAM FORMULATION
- IMPLEMENTATION
 - UPDATE SSD'S & PRA INPUT
 - PROVIDE DIRECT HUMAN FACTORS INPUT
 - CONDUCT OPERATIONS-ORIENTED ANALYSIS
- TEAM APPROACH
 - PROGRAM DEVELOPMENT
 - ANALYSES
 - REVISED PRELIMINARY DESIGN DEVELOPMENT
 - DESIGN REVIEWS
- NRC REVIEW PRIOR TO FABRICATION

POST-TMI PROGRAM FLOW



PILGRIM 2 RESPONSE TO 11.F.2 REQUIREMENTS FOR ICCI

- o A PRIMARY COOLANT SATURATION METER WILL BE PROVIDED
- o AN INVESTIGATIVE STUDY TO IDENTIFY APPROPRIATE ADDITIONAL ICCI WILL BE PERFORMED
 - RESULTS OF HJTC PROTOTYPICAL TEST
 - RESULTS OF APPLICABILITY TO PILGRIM 2 OF C-E GENERIC RESULTS

MODEL A17, 150, 450

BOSTON EDISON COMPANY
PLAN FOR TESTING OF
SAFETY AND RELIEF VALVES
AND DESIGN OF PIPING AND SUPPORTS
FOR PILGRIM UNIT #2

MODEL 6 J. 650. 330

SUMMARY OF COMMITMENT

PILGRIM 2 WILL:

- IMPLEMENT RESULTS OF INDUSTRY (EPRI) TESTS ON RELIEF, SAFETY, PORV BLOCK VALVES
- DESIGN DISCHARGE PIPING AND SUPPORTS FOR ALL LOADS FROM DESIGN BASIS TRANSIENTS AND ACCIDENTS

001 813 850 330

SUMMARY OF EPRI PROGRAM

- DESIGNED TO COMPLY WITH NUREG-0737 ITEM II.D.1 (PWR's)
- TESTING 10 PORV's AND 9 SAFETY VALVES (INCLUDING EXACT PILGRIM 2 VALVES)
- ENVELOPE CONDITIONS ON ALL PLANTS REPRESENTED
- TESTING UNDERWAY NOW
- FINAL OUTPUT BY JULY 1982
- PORV BLOCK VALVE PROGRAM UNDER DEVELOPMENT

EPRI PWR SAFETY AND RELIEF VALVE TEST PROGRAM

SUMMARY OF FOUR PRINCIPAL OUTPUTS:

1. SAFETY AND RELIEF VALVE TEST REPORTS FROM THE MARSHALL, WYLE, AND CE VALVE TEST PROGRAM.
2. A REPORT DOCUMENTING THE SELECTION OF THE RELIEF AND SAFETY VALVES TO BE TESTED AND JUSTIFYING THE APPLICABILITY OF THE TEST RESULTS TO VALVES UTILIZED IN OPERATING PLANTS AND PLANTS UNDER CONSTRUCTION.
3. REPORTS PROVIDING JUSTIFICATION OF THE SET OF GENERICALLY LIMITING FLUID CONDITIONS UTILIZED TO ESTABLISH THE VALVE TEST CONDITIONS BASED ON EVALUATION OF PLANT FSARs. JUSTIFICATION FOR OTHER TEST PARAMETERS WILL BE PROVIDED INCLUDING JUSTIFICATION THAT THE PRINCIPAL EFFECTS OF AS-BUILT RELIEF AND SAFETY VALVE DISCHARGE PIPING ON VALVE OPERABILITY HAVE BEEN ACCOUNTED FOR.
4. A REPORT DOCUMENTING A CODE FOR COMPUTING HYDRODYNAMIC LOADS FOR RELIEF AND SAFETY VALVE DISCHARGE PIPING UNDER STEAM AND WATER CONDITIONS.

NOTE: EPRI SLIDE

SUMMARY

- EPRI PROGRAM UNDERWAY ON PORV'S, SAFETY VALVES
- PILGRIM 2 VALVES ARE INCLUDED IN EPRI PROGRAM
- PILGRIM 2 WILL UTILIZE RESULTS AS THEY BECOME AVAILABLE
- BLOCK VALVE PROGRAM UNDER DEVELOPMENT