

Dmb
dlb

DISTRIBUTION:
Docket File-2
NRC PDR
L PDR

TERA
NSIC
ORB#1 Rdg
DEisenhut
SVarga
EReeves
CParrish
JThoma
BJYoungblood

OELD
AEOD
IE-3
ACRS-10

Docket Nos. 50-348
and 50-364

JUL 06 1981

Mr. F. L. Clayton, Jr.
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. Clayton:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE - FARLEY UNIT NOS. 1 AND 2

We have completed a generic review on this subject and conclude that no further action is necessary for Farley Unit No. 1. The concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

In addition, we consider this item to be complete for Farley Unit No. 2. Thus, License Condition 2.C(21)(h)(3) to License No. NPF-8 for Unit No. 2 is considered to be completed. In the future, an administrative change to the license will delete conditions which have been completed.

Sincerely,

Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing



cc:
See next page

8107150337 810706
PDR ADOCK 05000348
P PDR

REGULATORY DOCKET FILE COPY

Handwritten initials/signature

OFFICE	ORB#1:DL	ORB#1:DL	C-ORB#1:DL	LB#1:DL	C-LB#1:DL		
SURNAME	CParrish	EReeves	SVarga	JThoma	BYoungblood		
DATE	6/21/81	6/ /81: cab	6/20/81	7/1/81	7/2/81		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 6, 1981

Docket Nos. 50-348
and 50-364

Mr. F. L. Clayton, Jr.
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. Clayton:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY W AND CE - FARLEY UNIT NOS. 1 AND 2

We have completed a generic review on this subject and conclude that no further action is necessary for Farley Unit No. 1. The concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

In addition, we consider this item to be complete for Farley Unit No. 2. Thus, License Condition 2.C(21)(h)(3) to License No. NPF-8 for Unit No. 2 is considered to be completed. In the future, an administrative change to the license will delete conditions which have been completed.

Sincerely,

A handwritten signature in cursive script, appearing to read "Steven A. Varga".

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

cc:
See next page

Mr. F. L. Clayton, Jr.
Alabama Power Company

cc: Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Ruble A. Thomas, Vice President
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Mr. Robert . Buettner, Esquire
Balon, Bingham, Baker, Hawthorne,
Williams and Ward
Post Office Box 306
Birmingham, Alabama 35201

George S. Houston Memorial Library
212 W. Burdeshaw Street
Dothan, Alabama 36303

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 24-Route 2
Columbia, Alabama 36319