

Detroit

Donald A. Wells
Manager Quality Assurance
2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

July 2, 1981
EF2-53563

*Knap
Korbler
Smith*

Mr. James G. Keppler, Director
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Final Report of 10CFR50.55(e) Item on Defective GE-I&SE
Welds (#31).

Dear Mr. Keppler:

This is submitted as Detroit Edison's final report on the Defective GE-I&SE Welds problem (reported per 50.55(e) requirements).

The problem was originally reported to Mr. P.A. Barrett of NRC-Region III by Detroit Edison's Mr. T.A. Alessi, Director Project Quality Assurance on October 24, 1980. A review of nineteen (19) radiographs in the G-33 system, which is a drain line to the reactor vessel, revealed problems with seven (7) out of nineteen (19) welds. These radiographs were previously accepted by a contractor that has since left the site.

All of the seven (7) welds will be repaired, and documents requiring this repair have been issued to Construction. The work will be performed as allowed by Construction schedules. If you have questions concerning this matter, please contact Mr. H.A. Walker, Supervisor-Construction Quality Assurance.

Very truly yours,

D. Wells

DAW/HAW/cp

cc: Mr. Victor Stello, Jr., Director
Office of Inspection and Enforcement
Division of Reactor Inspection Programs
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Bruce Little, Resident Inspector
U.S. Nuclear Regulatory Commission
Resident Inspectors Office
6450 North Dixie Highway
Newport, Michigan 48166

*IE27
5
1/0*