NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | SCNEE3 (2) | 00-000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000287 (7) | 021681 (8) | 031281 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On February 26, 1981, the "B" Steam Generator was pressurized to 550 psig.
03 | No systems or piping were damaged by this incident. The integrity of the
04 | main steam lines, hangers, and the OTSG itself were verified. Thus, this
05 | incident was of no significance with respect to safe operation, and the
06 | health and safety of the public was not affected.
07 |
08 |

09 | SYSTEM CODE CB (11) | CAUSE CODE D (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE VALVEX (14) | COMP. SUBCODE E (15) | VALVE SUBCODE G (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 003 — OCCURRENCE CODE 01 — REPORT TYPE T — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER X999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The major cause of the incident was the result of a procedural deficiency.
11 | Valves 3SD-5 and 3SD-290 were opened in order to lower th OTSG pressure.
12 | Procedures will be revised to specify that the startup block valves be open
13 | prior to entering feedwater or condenser cleanup mode.
14 |

15 | FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER J. L. Jones PHONE: (704) 373-8197

8107200491 810312
PDR ADOCK 05000287
S PDR