

Docket Nos. 50-286
and 50-287

JUL 7 1981

Distribution
Docket File
NRC PDR
Local PDR
ORB 1 File
D. Eisenhut
J. Heltemes
S. Varga
C. Parrish
D. Neighbors
OELD
I&E (3)
NSIC
TERA
ACRS (10)



Mr. R. H. Leasburg
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26656
Richmond, Virginia 23261

Dear Mr. Leasburg:

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED BY M AND CE

We have completed a generic review on this subject and conclude that no further action is necessary since the concerns expressed in Item II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not considered applicable to NSSSs with inverted U-tube steam generators such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original Signed By#

Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

cc: See next page

5 1981

8107220043 810737
PDR ADOCK 05000280
P PDR

OFFICE	ORB 1	ORB 1				
SURNAME	DNeighbors/rs	SVarga				
DATE	7/ /81	7/ /81				

Mr. R. H. Leasburg
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager
P. O. Box 315
Surry, Virginia 23683

Swem Library
College of William and Mary
Williamsburg, Virginia 23185

Donald J. Burke, Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
Post Office Box 166
Route 1
Surry, Virginia 23883

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261