NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C A R S S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE / LICENSE NUMBER / LICENSE TYPE / CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 2 (7) | 0 6 1 9 8 1 (8) | 0 7 0 7 8 1 (9)
DOCKET NUMBER / EVENT DATE / REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the reactor shutdown, switchyard voltage decreased to 207KV. The
03 NSS busses were transferred to the diesel generators to maintain a
04 minimum voltage of 214KV.
05
06
07
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	E A (11)	C (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 1	—	0 3 4	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	X (19)	C (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Voltage decreased due to high local electrical demand. A direct indication
11 of switchyard voltage and an alarm will be installed in the control room.
12 The relevant safety analysis, while not violated, will be updated to
13 reflect actually observed switchyard voltage.
14

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	D (28)	0 0 0 (29)	N/A	A (31)	Miscellaneous low voltage alarms

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	Y (44)	Local newspapers and wire services	

NAME OF PREPARER R. W. Colombo PHONE (916) 452-3211

8107240267 810707
PDR ADOCK 05000312
S PDR