

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE-PRESIDENT
STEAM PRODUCTION

June 30, 1981

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: Oconee Nuclear Station
IE Bulletin 80-11
Docket Nos. 50-269, -270, -287




Dear Sir:

Your letter of March 13, 1981 requested interim progress reports during the analysis and evaluation phase of IE Bulletin 80-11 work. Attachment 1 details the present status of analysis.

A program of repairs has been initiated on selected walls at Oconee. The walls chosen are generally taller (approximately 18' to 19') than the typical walls at the station (approximately 12' to 14') and/or are located in areas anticipated to experience greater seismic accelerations. Analysis has not shown these walls to be unsafe in their existing configuration, but an added margin of safety will be provided by the upgrades.

We are presently responding to a series of detailed questions from the Structural Engineering Branch of the NRR staff concerning masonry wall re-evaluation techniques. You will be provided a copy of our response when it is submitted.

Very truly yours,


William O. Parker, Jr.

RLG/php

Attachment

IE 11
3
1/1

OCONEE NUCLEAR STATION
UNITS 1-3
ANALYSIS AND EVALUATION STATUS
JUNE 30, 1981

	<u>Number of Walls</u>	<u>Qualified By Analysis</u>	<u>Percent Complete</u>
Priority I	175	174	98%
Priority II	266	217	60%
Priority III	<u>42</u>	<u>7</u>	10%
TOTAL	483	398	