

RECEIVED

JUL 21 1981

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

OFFICE OF APPLICATIONS
& REPORTS SERVICES

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

HOUSTON LIGHTING & POWER COMPANY

(Allens Creek Nuclear Generating
Station, Unit 1)

\$
\$
\$
\$
\$
\$

Docket No. 50-466

DIRECT TESTIMONY OF G. L. SOZZI
ON DOHERTY CONTENTION 32
RE ECCS VAPORIZATION RATE



Q. Please state your name and job position.

A. My name is G. L. Sozzi. I am presently Manager of
LOCA System Technology within the Nuclear Fuel and Services
Engineering Department of the General Electric Company.

Q. Would you explain your job responsibilities and
your professional qualifications?

A. I am responsible for experimental and analytical
support of safety related characteristics of the Boiling
Water Reactor (BWR) system. The BWR Blowdown/Emergence Core
Cooling Program is one such investigation under my direction.

I received a B.S. degree in mechanical engineering
in 1966 from San Jose State University, an M.S. degree in
mechanical engineering from the University of California, and
I also attended Stanford University where I performed addi-
tional graduate work following my M.S. degree. I have spent

DS03
3
11

1 most of my professional career in thermal hydraulic experi-
2 mental and analytical research and development related to
3 nuclear reactor systems safety technology. A major portion
4 of my work has dealt with the two-phase flow phenomenon relat-
5 ed to the reactor loss-of-coolant accident (LOCA). This work
6 has included critical two-phase blowdown flow, two-phase
7 flashing and level swell, and heat transfer during a vessel
8 blowdown.

9 I am a member of the American Society of Mechanical
10 Engineers and a registered professional engineer in the State
11 of California.

12 Q. What is the purpose of your testimony?

13 A. My testimony addresses Doherty Contention No.
14 32 which asserts that the General Electric Emergency Core
15 Cooling Systems (ECCS) evaluation model underpredicts the
16 generation of steam during ECCS injection flow after a loss-
17 of-coolant accident (LOCA). The source of Mr. Doherty's
18 postulation was the report of some anomalous test results at
19 GE's Two Loop Test Apparatus (TLTA) facility as part of the
20 Blowdown/Emergency Core Cooling Program.

21 Q. Would you describe the TLTA tests?

22 A. The Blowdown/Emergency Core Cooling program is a
23 cooperative experimental research program jointly funded by
24 the Electric Power Research Institute, General Electric and

1 the Nuclear Regulatory Commission. Tests are conducted by
2 General Electric under this program in the Two Loop Test
3 Apparatus in San Jose, California. The purposes of the
4 present program are:

- 5 - To simulate the LOCA from the start of the accident
6 through the early interaction with ECCS in a
7 configuration which has performance characteristics
8 similar to a BWR with 8x8 fuel bundles.
- 9 - To obtain test information to support analytical
10 predictions used in the evaluation of BWR's during
11 postulated LOCA's.

12 The Two Loop Test Apparatus is an experimental
13 scaled mockup of a BWR. A single, electrically-heated, full-
14 size (8x8) fuel bundle simulates the core and is contained
15 within a pressure vessel simulating a reactor vessel. Both
16 normal and emergency cooling systems are simulated. Two
17 loops circulate water to jet pumps within the pressure vessel.
18 Other major BWR components are also mocked up including a
19 steam separator. Emergency core cooling systems include scaled
20 high and low pressure core spray, low pressure coolant injec-
21 tion, and automatic depressurization.

22 Blowdown of the reactor vessel for a simulated LOCA
23 is initiated by operating quick-opening valves in one of the
24 recirculation lines. Blowdown fluid from these lines is
25 dumped into a tank of water which condenses the steam and
26 absorbs its energy.

27 There are approximately 180 data channels dedicated

1 to the Two Loop Tests Apparatus which are recorded on magnetic
2 tape. Detailed data analysis and reduction is performed on
3 the GE computer system.

4 Q. What is the source of concern expressed in Mr.
5 Doherty's Contention?

6 A. During the Fall of 1978 a TLTA test was conducted
7 with an average power bundle (5.05MW) and with average
8 Emergency Core Cooling (ECC) injection flow. Results of
9 this test were then compared with those from a test with the
10 same initial conditions, but no ECC injection. The comparison
11 showed that the system depressurized more slowly with ECC
12 injection than without ECC injection. The slower depressuri-
13 zation with ECC injection was not anticipated by the NRC
14 Staff and as such, the Staff requested that GE review the
15 results and account for the apparent differences observed.

16 The Staff's concern was based on the preliminary
17 conclusion that the slow depressurization in the TLTA test
18 with ECC injection may have been due to greater steam genera-
19 tion in the core than expected, which could result in an
20 unanticipated delay of reflood. This possibility led to a
21 concern that the vaporization model was in error and non-
22 conservative in its effect on the calculation of peak clad
23 temperature (PCT). However, upon completion of its review
24 of the data, General Electric resolved the Staff's concern
about increased vaporization. The slower depressurization

1 for the test with ECC injection was actually due primarily
2 to the fact that the fluid exiting the break was of lower
3 quality than for the test without ECC injection. For the test
4 with ECC injection the emergency core cooling water refilled
5 the system and collected in the vicinity of the break and
6 was carried out of the break with the steam. For the
7 test without ECC injection, the fluid discharged from the
8 break was primarily steam. Some additional steam was generated
9 by the ECC fluid cooling the metal masses which are part of
10 the test assembly for the test with ECC injection. This effect
11 would not be as significant in an actual reactor because the
12 ratio of metal mass to ECC fluid mass is higher in the test
13 assembly due to the scaling parameters used in TLTA testing.

14 Q. Was GE's account of the slow depressurization
15 anomaly otherwise corroborated?

16 A. Yes, data collected on the density of fluid flow out
17 the simulated break, and calculated mass and energy balances
18 on the system confirmed that the observed differences in
19 depressurization rate were due to differences in fluid quality
20 out of the break and not due to core vaporization rate. In
21 fact, estimates of the steam flow out of the core region,
22 from measurements across the steam separator, demonstrated
23 that there was less net vapor generated from the core region
24 for the test with ECC injection.

Subsequent to these earlier tests, GE repeated

1 these tests in the TLTA with improved instrumentation. These
2 latter results provided further substantiation to the earlier
3 results, i.e., the slower depressurization rate for the tests
4 with ECC injection was due to a lower volumetric discharge
5 from the break and not due to core vaporization.

6 Finally, a comparison was made between the peak
7 cladding temperature calculated with the GE ECCS model and
8 that measured in the average power TLTA tests, with and
9 without ECC injection. The calculated peak cladding
10 temperatures exceed the measured values by approximately
11 1000°F in both cases. Thus, the calculations indicate that
12 the licensing models maintain a large and consistent margin
13 of safety in the prediction of peak cladding temperature for
14 the two test cases.

15 Q. Would you please summarize your testimony.

16 A. GE's ECCS model has conservatively accounted for
17 the phenomenon observed in the tests referenced in the
18 contention. It is clearly established that no revision in
19 the ECCS model is required.
20
21
22
23
24