



TELEPHONE REPORT

OFFICIAL COPY

FACILITY Catawba 1+2

DOCKET NUMBER 50-413

50-414

TELECON DATE 6/30/81 TIME 3:50 pm LIC OCC. NO. \_\_\_\_\_

INSPECT PER MC 2512

RTV Notified

J. BRYANT CALLED W. HENRY WITH THE FOLLOWING:

SUBJECT: CDR - SA 312 Pipe Below  
Minimum wall thickness:  
License of found lines  
indications in 1" schedule  
40 SA 312 pipe purchased  
from ARMCO; Heat No.  
490269. Indications  
are both ~~longitudinal~~ longitudinal  
and transverse and could be  
mill marks or end roll over.  
Some pipe violated allowable wall  
thickness by 5 mills. License of awaiting  
report from ARMCO

A WRITTEN REPORT IS DUE: 7/30/81

AI TS NUMBER: F02700119

8107310208 810630  
PDR ADOCK 05000413  
A PDR

IE27  
5/0