

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

T. C. NICHOLS, JR.
VICE PRESIDENT AND GROUP EXECUTIVE
NUCLEAR OPERATIONS

June 30, 1981 7 48



Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street, N. W.
Atlanta, Georgia 30303

Subject: Virgil C. Summer Nuclear Station
Docket No. 50/395
Significant Deficiency
Correction to Final Report
Nuclear Eng. File 3.105i

Dear Mr. O'Reilly:

On May 28, 1981, a final report on item concerning moisture in component cooling pump motor 1A was sent to James P. O'Reilly, Director, U. S. Nuclear Regulatory Commission, Region II.

In the final report a 10 CFR 50.55(e) - Significant Deficiency was written on the above item. In section 4.C. Corrective Action Addressing Running Component Cooling Pumps without Cooling Water, the last sentence of the paragraph should read:

The Component Cooling System Operating procedure will be revised to make sure that the chilled water system is lined up to provide cooling water to the Component Cooling Pump Motors. This is expected to be completed by the end of July, 1981.

Very truly yours,

T. C. Nichols, Jr.

TAB.TCN:1kb

cc: V. C. Summer	J. B. Knotts, Jr.
G. H. Fischer	J. L. Skolds
T. C. Nichols, Jr.	B. A. Bursey
O. W. Dixon	O. S. Bradham
J. Ruoff	H. E. Yocom
D. A. Nauman	Document Management Branch
W. A. Williams, Jr.	I&E
R. B. Clary	ISEG
A. R. Koon	NPCF
A. A. Smith	File
H. N. Cyrus	

IK27
S1/0