

1	A	L	J	M	F	2	2	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	4	5	
5	LICENSEE CODE					14	15	LICENSE NUMBER										23	25	LICENSE TYPE				30	37	38

8	L	6	0	5	0	0	0	3	5	4	7	0	6	0	3	8	1	3	0	7	0	7	8	1	3
69	REPORT SOURCE		61	BUCKET NUMBER							68	69	EVENT DATE				74	75	REPORT DATE				80		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On 6-3-81, the "A" Recombiner Oxygen Outlet Analyzer was declared inoperable and removed from service when it was noted that the Recombiner Oxygen Analyzer was not responding to changes in oxygen concentration. Subsequent investigation revealed that the analyzer was in the "Calibrate" rather than the "Measure" mode of operation. Tech. Spec. 3.3.3.11, in part, requires the Oxygen Analyzer to be operable. Tech. Spec. 3.3.3.11 action statement requirements were met. Health/safety of the public was not affected.

19	M	C	11	A	12	C	13	Z	Z	Z	Z	Z	14	Z	15	Z	16
9	SYSTEM CODE		11	CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP SUBCODE		VALVE SUBCODE		
17	8	1	—	0	2	2	—	0	3	L	—	0					
21	EVENT YEAR		22	SEQUENTIAL REPORT NO.		24	OCCURRENCE CODE		29	REPORT TYPE		31	REVISION NO.				
33	X	G	Z	Z	0	0	0	0	N	N	Z	Z	9	9	9		
33	ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRO-4 FORM 5L9		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The exact cause of this event has not been determined. However, the most probable cause was the failure of an I&C serviceman to place the Analyzer in the "Measure" mode following performance in Alignment Procedures. The Analyzer was placed in the "Measure" mode of operation and returned to service on 6-8-81 after several preventative maintenance tasks has been completed. A step will be added to FNP-2-IMP-223.15A requiring signoff to verify restoration of switches to proper position.

5	E	23	0	4	0	29	N/A	A	31	Operator Observation	32	
3	FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
16	Z	33	Z	34	N/A	N/A	N/A	N/A	N/A	N/A	35	
3	ACTIVITY CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE							
17	0	0	0	37	Z	38	N/A					
3	PERSONNEL EXPOSURES		DESCRIPTION									
13	0	0	0	40	N/A							
3	PERSONNEL INJURIES		DESCRIPTION									
13	0	0	0	40	N/A							
13	Z	42	N/A									
3	LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION									
13	Z	42	N/A									
3	PUBLICATION ISSUED		DESCRIPTION									
13	N	44	N/A									