

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | M | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
7 8 9 14 15 20 25 26 30 37 38 42 43 44 45 46 47 48 49

0 1 | REPORT SOURCE | I | 9 | 0 | 1 | 5 | 1 | 0 | 0 | 0 | 3 | 6 | 9 | 7 | 0 | 5 | 2 | 1 | 8 | 1 | 1 | 8 | 0 | 6 | 0 | 3 | 8 | 1 | 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a nondestructive examination of the shim plate welds on the personnel  
0 3 | air locks, ASME Code rejectable indications were found in the vendor seal  
0 4 | plate to door frame welds. This is reportable per Technical Specification  
0 5 | 6.9.1.12(i). The welds had previously passed numerous leak rate tests and  
0 6 | there is a redundant weld for each seal, thus the health and safety of the  
0 7 | public were not affected.

0 9 | SYSTEM CODE | S | D | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | B | 13 | COMPONENT CODE | P | E | N | E | T | R | 14 | COMP. SUBCODE | A | 15 | VALVE SUBCODE | Z | 16  
17 | LER/RO REPORT NUMBER | 8 | 1 | 1 | 22 | SEQUENTIAL REPORT NO. | 0 | 7 | 7 | 24 | OCCURRENCE CODE | 0 | 1 | 28 | REPORT TYPE | 7 | 30 | REVISION NO. | 0 | 32  
ACTION TAKEN | B | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | Y | 23 | NRC-4 FORM I.D. | N | 24 | PRIME COMP. SUPPLIER | L | 25 | COMPONENT MANUFACTURER | W | 3 | 1 | 0 | 2 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Records indicated that the welds were inspected and accepted by the fabricator,  
1 1 | however, when reinspected by the Owner, the welds were found defective. All  
1 2 | rejectable indications were repaired in accordance with the ASME Code and  
1 3 | each air lock has been leak rate and pressure tested.

1 5 | FACILITY STATUS | X | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | Initial fuel loading | 30 | METHOD OF DISCOVERY | C | 31 | DISCOVERY DESCRIPTION | Nondestructive Examination | 32  
ACTIVITY CONTENT | 33 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

1 7 | PERSONNEL EXPOSURES | NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

1 8 | PERSONNEL INJURIES | NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY | TYPE | Z | 42 | DESCRIPTION | NA | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45

NAME OF PREPARER R. W. Ouellette

PHONE: (704) 373-7530